

CONCORDIA, Argentina

WMO: 873950

Lat: 31.3022S

Lon: 58.0014W

Elev: 125

StdP: 14.63

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.2	37.4	27.0	21.0	45.7	30.1	24.3	45.4	25.6	58.4	22.5	59.2	0.5	230	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.3	95.4	73.7	92.9	73.4	90.2	72.7	78.7	88.7	77.2	87.1	75.8	85.0	9.4	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.9	135.8	84.1	74.5	129.8	82.5	73.2	123.8	80.9	42.4	88.7	40.8	87.3	39.5	84.8	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.5	20.9	18.4	28.9	100.0	2.6	2.0	27.0	101.5	25.5	102.6	24.1	103.7	22.3	105.1		
			28.1	82.2	2.6	2.1	26.3	83.7	24.8	84.9	23.4	86.1	21.5	87.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.4	78.3	76.3	72.6	66.6	60.4	55.9	54.8	58.1	61.2	66.3	70.9	75.3	(6)
	DBStd	10.26	4.71	4.90	5.38	6.71	6.85	7.51	8.34	8.47	7.30	5.92	5.35	5.20	(7)
	HDD50	91	0	0	0	0	4	24	41	18	4	0	0	0	(8)
	HDD65	1339	0	1	7	58	175	289	334	251	157	54	12	1	(9)
	CDD50	6060	877	737	701	499	328	201	191	270	338	506	626	786	(10)
	CDD65	1833	412	318	243	107	34	16	18	38	42	95	188	322	(11)
	CDH74	16422	4338	2894	1946	663	146	43	69	278	376	750	1674	3245	(12)
	CDH80	6407	1993	1170	673	172	21	4	10	71	112	206	571	1404	(13)
(14) Wind	WSAvg	6.3	6.4	6.1	5.3	5.1	4.7	5.3	5.9	7.0	8.0	7.9	7.5	7.0	(14)
(15) Precipitation	PrecAvg	53.1	4.8	5.6	5.7	5.9	4.1	3.0	2.6	2.9	3.6	5.7	5.4	5.0	(15)
	PrecMax	79.2	19.8	18.5	17.2	23.9	16.1	16.1	9.3	14.0	9.2	19.5	18.1	22.3	(16)
	PrecMin	20.9	0.3	0.3	1.0	0.6	0.0	0.1	0.2	0.0	0.3	0.5	0.2	0.8	(17)
	PrecStd	11.8	3.6	4.1	3.5	4.3	3.4	3.0	2.0	2.4	2.1	3.8	3.3	4.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.2	96.3	93.5	89.6	82.6	78.9	80.7	87.4	89.8	90.9	93.3	98.4	(19)
		MCWB	74.6	75.4	75.9	73.9	70.0	69.8	67.8	69.4	72.2	73.8	71.5	73.9	(20)
	2%	DB	95.9	92.8	89.7	84.6	77.7	73.8	75.2	81.4	82.3	85.4	89.4	94.5	(21)
		MCWB	73.3	74.4	73.3	71.9	68.7	67.6	66.2	68.1	68.4	70.4	70.5	73.0	(22)
	5%	DB	92.9	90.0	86.5	80.9	74.3	70.4	70.9	76.6	78.0	81.3	86.2	91.1	(23)
		MCWB	73.6	73.9	72.1	70.0	67.0	65.5	63.8	65.8	65.8	68.0	69.0	72.2	(24)
	10%	DB	89.8	87.3	83.9	77.4	70.9	67.6	67.4	71.9	73.6	77.9	83.0	87.7	(25)
		MCWB	72.6	73.0	70.9	68.1	64.6	63.0	61.8	63.0	62.8	66.2	68.1	71.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.3	79.7	76.7	73.6	71.4	70.0	71.7	73.7	76.3	77.2	80.0	(27)
		MCDB	90.3	89.7	89.4	85.5	80.1	76.7	77.3	82.5	84.2	88.2	87.2	91.5	(28)
	2%	WB	78.1	78.4	77.1	74.5	70.9	68.8	67.0	68.9	70.3	73.1	74.2	77.5	(29)
		MCDB	88.8	87.8	85.6	81.7	75.5	72.6	73.4	79.2	80.1	80.9	83.7	87.9	(30)
	5%	WB	76.5	76.6	74.8	72.4	68.2	66.4	65.1	66.7	67.5	70.5	72.1	75.4	(31)
		MCDB	86.6	85.6	82.3	78.0	72.6	70.0	70.4	75.4	75.5	78.1	80.6	85.3	(32)
	10%	WB	75.2	74.9	72.9	70.4	65.9	64.0	62.8	64.3	65.0	68.5	70.4	73.4	(33)
		MCDB	84.7	83.0	80.2	75.0	69.7	67.3	66.7	70.6	71.3	75.3	78.5	82.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.3	18.5	18.8	17.5	16.3	16.3	17.5	19.3	19.3	18.6	20.3	20.9	(35)
		MCDBR	24.5	22.5	22.6	21.3	19.4	16.8	19.1	23.5	25.1	23.8	25.4	26.0	(36)
		MCWBR	8.7	8.6	9.8	10.1	10.8	10.9	10.9	11.7	12.3	11.4	10.3	10.1	(37)
	5% WB	MCDBR	18.9	18.1	18.3	16.3	15.5	14.4	16.5	20.7	20.9	19.4	19.2	20.2	(38)
		MCWBR	8.6	8.7	9.7	9.0	9.7	10.2	10.3	11.2	11.5	11.0	10.2	10.1	(39)
(40) Clear-Sky Solar Irradiance	taub		0.415	0.404	0.388	0.384	0.365	0.376	0.374	0.449	0.498	0.445	0.401	0.409	(40)
	taud		2.347	2.392	2.418	2.384	2.410	2.366	2.341	2.088	1.966	2.190	2.338	2.341	(41)
	Ebn at Noon		294	291	285	267	256	243	249	241	246	275	296	297	(42)
	Edh at Noon		43	39	36	33	29	29	31	44	56	48	43	43	(43)
(44) All-Sky Solar Radiation	RadAvg		2225	1946	1673	1258	910	779	866	1115	1430	1745	2154	2257	(44)
	RadStd		193	136	145	161	85	81	90	101	143	203	201	157	(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	+0.85	+0.97	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page