

MENDOZA, ArgentinaWMO: **874180**Lat: **32.8439S**Lon: **68.7964W**Elev: **704**StdP: **93.15**Time Zone: **-3.00 (W03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.3	1.0	-11.0	1.6	13.9	-8.3	2.0	13.0	8.4	13.9	7.1	12.8	0.6	270	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	35.9	19.8	34.2	19.7	33.0	19.3	22.8	31.3	21.9	30.6	21.1	29.5	3.7	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	16.2	27.3	19.1	15.1	26.5	18.1	14.2	25.7	71.4	31.5	67.8	30.3	64.7	29.8	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.5	5.6	DB	-3.2	39.5	1.5	1.6	-4.3	40.6	-5.2	41.5	-6.1	42.4	-7.2	43.5	(4)
(5)			WB	-4.2	24.5	1.3	1.2	-5.1	25.3	-5.8	26.0	-6.6	26.7	-7.5	27.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.6	25.9	24.2	21.5	16.9	12.8	9.4	8.8	11.4	14.6	18.7	22.2	24.9	(6)	
	DBStd	6.78	2.80	3.27	3.23	3.41	3.14	2.78	3.03	3.64	3.78	3.67	3.48	3.20	(7)	
	HDD10.0	144	0	0	0	2	11	41	58	26	7	1	0	0	(8)	
	HDD18.3	1198	1	2	10	65	172	267	295	216	119	39	9	2	(9)	
	CDD10.0	2919	494	399	357	209	97	24	21	69	147	272	367	463	(10)	
	CDD18.3	932	236	168	109	23	1	0	0	2	8	52	127	207	(11)	
	CDH23.3	9951	2671	1728	947	203	16	6	3	52	146	561	1298	2322	(12)	
	CDH26.7	4241	1289	766	326	36	1	1	0	12	31	177	519	1084	(13)	
(14) Wind	WSAvg	2.0	2.5	2.3	1.9	1.6	1.3	1.4	1.5	1.8	2.2	2.5	2.7	2.7	(14)	
(15) Precipitation	PrecAvg	202	41	36	31	13	7	4	6	6	10	11	17	29	(15)	
	PrecMax	413	139	142	148	88	38	31	43	32	36	79	78	190	(16)	
	PrecMin	68	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	81	35	38	31	18	10	7	8	7	11	15	19	29	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.1	36.9	33.9	29.9	25.1	23.5	22.7	28.2	30.0	33.4	35.5	37.6	(19)	
		MCWB	20.0	20.6	20.4	18.7	15.9	11.6	11.1	13.0	15.5	17.2	17.9	19.7	(20)	
	2%	DB	36.0	34.4	31.9	27.5	23.0	19.1	19.2	24.1	26.9	30.7	33.2	35.2	(21)	
		MCWB	20.3	20.4	19.8	17.0	14.7	10.7	10.1	12.3	13.7	16.6	18.0	19.4	(22)	
	5%	DB	34.2	32.9	30.1	25.9	21.1	17.3	17.5	21.3	24.9	28.4	31.7	33.9	(23)	
		MCWB	20.3	20.0	19.0	16.5	13.8	10.0	9.5	11.3	13.0	15.4	17.5	19.0	(24)	
	10%	DB	32.8	31.2	28.2	23.9	19.2	15.9	15.8	19.1	22.8	26.4	29.9	32.1	(25)	
		MCWB	19.8	19.7	18.6	15.7	12.8	9.4	8.6	10.2	12.4	14.6	16.7	18.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.9	24.2	22.7	20.1	17.4	13.2	12.9	14.8	16.8	19.6	21.2	23.2	(27)	
		MCDB	32.0	32.0	30.4	26.0	22.5	19.5	19.5	25.3	26.4	29.8	31.4	32.5	(28)	
	2%	WB	22.8	22.8	21.4	18.5	15.7	11.9	11.2	13.0	15.1	18.0	19.8	21.8	(29)	
		MCDB	31.7	30.4	28.5	24.9	21.1	17.1	17.7	22.4	24.4	27.9	29.5	31.5	(30)	
	5%	WB	21.8	21.7	20.3	17.5	14.6	10.9	10.0	11.8	13.9	16.6	18.8	20.8	(31)	
		MCDB	30.9	29.6	27.3	23.8	19.6	16.2	16.4	20.3	23.0	25.8	28.9	30.2	(32)	
	10%	WB	20.9	20.8	19.5	16.5	13.5	9.8	9.0	10.6	12.8	15.5	17.7	19.8	(33)	
		MCDB	29.8	28.6	26.6	22.5	18.2	14.8	14.9	18.3	21.3	24.6	27.5	29.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	11.7	11.2	11.1	10.8	11.8	12.4	12.8	12.6	12.3	12.4	12.4	(35)	
		MCDBR	14.5	14.5	14.1	14.3	14.1	14.5	15.4	16.7	16.8	15.6	15.4	14.8	(36)	
	5% WB	MCWBR	5.2	5.3	5.5	6.4	7.1	7.8	8.1	8.0	7.5	6.5	6.2	5.6	(37)	
		MCWBR	12.1	11.9	11.9	12.1	12.2	12.9	14.2	15.5	14.8	13.6	13.0	12.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.403	0.393	0.370	0.361	0.317	0.295	0.290	0.316	0.355	0.368	0.378	0.397	(40)	
		taud	2.331	2.365	2.426	2.409	2.494	2.556	2.526	2.444	2.331	2.322	2.319	2.308	(41)	
	Ebn at Noon	Ebn at Noon	936	925	911	861	855	856	878	897	909	938	953	945	(42)	
		Edh at Noon	135	126	111	101	82	72	78	95	120	130	136	139	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.86	6.95	5.80	4.40	3.13	2.74	2.98	3.88	5.13	6.52	7.73	8.25	(44)	
	RadStd	RadStd	0.45	0.42	0.35	0.41	0.36	0.23	0.23	0.32	0.41	0.55	0.47	0.45	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	-2.02	+0.52	N/A	N/A	N/A	N/A	N/A	+63	(46)	
(47) Regional (5 neighbors)		N/A	N/A	N/A	+0.53	N/A	N/A	N/A	N/A	+137	+93	(47)	

Nomenclature: See separate page