

GUALEGUAYCHU, Argentina

WMO: 874970

Lat: 33.0125S

Lon: 58.6108W

Elev: 69

StdP: 14.66

Time Zone: -3.00 (W03)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.6	36.3	27.1	21.1	42.5	29.9	24.0	43.0	26.9	63.4	24.4	63.1	1.7	230	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.7	94.4	73.7	91.9	72.7	89.6	71.9	77.9	88.2	76.2	86.2	74.8	84.5	9.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.0	131.7	83.4	73.4	124.5	81.4	71.9	118.4	79.4	41.5	88.1	39.8	86.1	38.4	84.6	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.1	20.2	17.4		DB	28.5	99.4	2.4	2.9	26.7	101.5	25.4	103.2	24.0	104.8	22.3	106.9
				WB	27.8	80.6	2.4	1.4	26.0	81.5	24.6	82.3	23.3	83.1	21.5	84.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.7	76.6	74.9	71.5	65.1	58.6	53.8	53.3	56.3	59.0	64.5	69.0	74.1
	DBStd	10.31	4.89	5.28	5.78	6.61	6.86	6.93	7.68	7.75	6.47	5.97	5.83	5.58
	HDD50	120	0	0	0	1	7	33	50	22	6	1	0	0
	HDD65	1637	0	2	12	77	222	343	375	294	201	81	26	4
	CDD50	5474	826	697	666	453	273	149	151	216	275	451	569	748
	CDD65	1517	361	280	213	80	23	9	11	23	20	66	144	287
	CDH74	13901	3676	2560	1708	525	120	24	48	175	162	550	1418	2935
	CDH80	5378	1621	1033	577	145	22	1	7	47	25	146	496	1258
(14) Wind	WSAvg	6.2	5.8	5.6	5.6	5.6	4.9	5.7	6.2	6.7	7.2	7.1	7.1	6.4
(15) Precipitation	PrecAvg	43.8	4.6	5.0	5.2	4.1	3.0	1.9	2.2	2.3	2.8	4.3	4.1	4.4
	PrecMax	70.5	13.5	25.7	27.4	14.8	12.3	8.5	6.5	9.1	9.1	13.7	13.1	16.9
	PrecMin	23.5	0.1	0.4	0.2	0.0	0.0	0.0	0.0	0.3	0.6	0.1	0.0	0.0
	PrecStd	12.1	3.1	4.6	4.6	3.0	2.3	1.6	1.5	2.0	2.0	2.8	2.5	3.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.2	95.4	93.6	89.6	83.8	77.4	80.1	86.1	84.3	89.1	93.6	98.2
		MCWB	75.6	74.9	75.1	72.5	69.4	69.4	67.8	69.8	68.6	70.2	70.9	74.1
	2%	DB	94.4	92.6	89.7	84.4	77.2	72.1	72.8	78.6	79.2	83.6	89.3	93.4
		MCWB	74.3	73.5	72.6	69.8	66.9	66.3	64.8	66.3	65.6	68.4	69.2	72.1
	5%	DB	91.4	89.5	86.6	79.8	72.7	67.9	68.3	73.5	74.9	79.8	85.7	90.5
		MCWB	73.1	73.3	71.6	68.0	64.8	62.7	61.5	64.1	63.6	66.9	67.7	71.1
	10%	DB	88.4	86.4	82.9	76.1	68.9	64.7	64.5	69.1	71.2	76.2	82.2	87.3
		MCWB	72.3	72.0	70.0	66.7	62.9	59.6	59.0	61.1	61.2	64.9	66.6	69.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.5	79.7	79.8	76.0	71.6	70.8	68.9	71.8	71.9	73.8	74.5	78.3
		MCDB	90.7	90.1	90.0	83.5	80.0	75.5	76.0	82.3	80.6	83.4	86.3	90.6
	2%	WB	77.3	77.3	76.4	72.8	68.5	67.4	65.6	68.3	68.6	70.9	72.0	75.9
		MCDB	88.4	86.7	84.0	80.4	74.6	71.1	72.0	76.1	76.1	78.8	82.9	87.1
	5%	WB	75.8	75.5	74.4	70.9	66.4	64.4	63.0	65.5	65.8	68.9	70.2	74.0
		MCDB	86.9	85.0	81.3	76.5	70.7	67.6	67.2	72.4	71.7	76.6	80.1	84.8
	10%	WB	74.5	73.8	72.3	68.9	63.9	61.2	60.4	62.4	63.3	67.0	68.5	72.3
		MCDB	84.8	82.6	79.4	73.4	68.1	63.6	63.5	67.9	68.8	73.9	77.9	82.5
(35) Mean Daily Temperature Range	5% DB	MDBR	20.7	19.2	19.1	17.8	16.6	16.8	16.8	19.1	18.8	18.8	21.0	21.5
		MCDBR	24.9	23.5	23.4	23.3	21.2	18.7	20.0	24.2	24.5	24.9	26.6	26.3
		MCWBR	9.2	9.0	9.3	10.6	11.0	11.7	11.5	13.0	12.7	11.9	10.3	9.4
	5% WB	MCDBR	20.4	19.3	18.2	17.2	17.1	14.8	16.7	20.7	19.2	19.7	20.6	21.1
		MCWBR	9.5	9.0	9.6	9.4	9.8	10.8	10.4	12.2	11.4	11.1	10.1	9.1
(40) Clear-Sky Solar Irradiance	taub		0.419	0.399	0.385	0.380	0.365	0.369	0.362	0.443	0.482	0.429	0.397	0.411
	taud		2.320	2.396	2.415	2.387	2.397	2.372	2.370	2.092	1.998	2.221	2.340	2.321
	Ebn at Noon		292	291	284	266	252	241	250	240	249	279	297	296
	Edh at Noon		43	39	36	33	29	28	29	43	53	46	42	44
(44) All-Sky Solar Radiation	RadAvg		2276	1943	1665	1219	877	751	807	1064	1428	1762	2159	2305
	RadStd		145	166	168	150	75	83	93	97	115	168	162	138

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	+0.70	+0.77	+0.85	N/A	N/A	N/A	N/A

Nomenclature: See separate page