

GUALEGUAYCHU, Argentina

WMO: 874970

Lat: 33.0125S

Lon: 58.6108W

Elev: 21

StdP: 101.07

Time Zone: -3.00 (W03)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.9	2.4	-2.7	3.0	5.8	-1.2	3.4	6.1	12.0	17.4	10.9	17.3	0.8	230	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.5	34.7	23.2	33.3	22.6	32.0	22.2	25.5	31.2	24.6	30.1	23.8	29.1	4.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	18.8	28.6	23.0	17.8	27.5	22.2	16.9	26.3	78.6	31.1	74.6	30.1	71.5	29.2	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.0	7.8	-2.0	37.4	1.3	1.6	-2.9	38.6	-3.7	39.5	-4.4	40.4	-5.4	41.6		
(5)			-2.4	27.0	1.3	0.8	-3.3	27.5	-4.1	28.0	-4.9	28.4	-5.8	28.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	24.8	23.8	21.9	18.4	14.8	12.1	11.8	13.5	15.0	18.1	20.5	23.4	(6)	
(7)		DBStd	5.73	2.72	2.93	3.21	3.67	3.81	3.85	4.27	4.30	3.59	3.31	3.24	3.10	(7)	
(8)		HDD10.0	67	0	0	0	1	4	18	28	12	3	1	0	0	(8)	
(9)		HDD18.3	909	0	1	7	43	123	191	208	163	112	45	14	2	(9)	
(10)		CDD10.0	3041	459	387	370	252	152	83	84	120	153	251	316	416	(10)	
(11)		CDD18.3	843	201	156	118	44	13	5	6	13	11	37	80	159	(11)	
(12)		CDH23.3	7723	2042	1422	949	292	67	13	27	97	90	306	788	1631	(12)	
(13)		CDH26.7	2988	901	574	321	81	12	1	4	26	14	81	276	699	(13)	
(14)	Wind	WSAvg	2.8	2.6	2.5	2.5	2.5	2.2	2.5	2.8	3.0	3.2	3.2	3.2	2.9	(14)	
(15)	Precipitation	PrecAvg	1112	116	126	132	105	76	48	56	58	72	109	105	112	(15)	
(16)		PrecMax	1790	342	652	697	376	312	216	165	231	230	347	334	430	(16)	
(17)		PrecMin	598	2	10	6	0	0	0	0	0	7	15	2	0	(17)	
(18)		PrecStd	307	78	117	117	77	59	40	39	52	51	71	63	91	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.8	35.2	34.2	32.0	28.8	25.2	26.7	30.1	29.1	31.7	34.2	36.8	(19)	
(20)			MCWB	24.2	23.8	24.0	22.5	20.8	20.8	19.9	21.0	20.3	21.2	21.6	23.4	(20)	
(21)		2%	DB	34.7	33.7	32.0	29.1	25.1	22.3	22.7	25.9	26.2	28.7	31.8	34.1	(21)	
(22)			MCWB	23.5	23.1	22.6	21.0	19.4	19.1	18.2	19.1	18.7	20.2	20.7	22.3	(22)	
(23)		5%	DB	33.0	32.0	30.3	26.5	22.6	19.9	20.2	23.1	23.9	26.5	29.8	32.5	(23)	
(24)			MCWB	22.8	22.9	22.0	20.0	18.2	17.0	16.4	17.8	17.6	19.4	19.8	21.7	(24)	
(25)		10%	DB	31.4	30.2	28.3	24.5	20.5	18.2	18.1	20.6	21.8	24.6	27.9	30.7	(25)	
(26)			MCWB	22.4	22.2	21.1	19.3	17.2	15.3	15.0	16.2	16.2	18.3	19.2	21.0	(26)	
(27)		Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	26.5	26.5	24.5	22.0	21.5	20.5	22.1	22.2	23.2	23.6	25.7	(27)
(28)				MCDWB	32.6	32.3	32.2	28.6	26.7	24.2	24.4	27.9	27.0	28.6	30.2	32.5	(28)
(29)	2%		WB	25.2	25.2	24.7	22.7	20.3	19.7	18.6	20.1	20.3	21.6	22.2	24.4	(29)	
(30)			MCDWB	31.3	30.4	28.9	26.9	23.7	21.7	22.2	24.5	24.5	26.0	28.3	30.6	(30)	
(31)	5%		WB	24.3	24.1	23.5	21.6	19.1	18.0	17.2	18.6	18.8	20.5	21.2	23.3	(31)	
(32)			MCDWB	30.5	29.4	27.4	24.7	21.5	19.8	19.6	22.4	22.0	24.8	26.7	29.3	(32)	
(33)	10%		WB	23.6	23.2	22.4	20.5	17.7	16.2	15.8	16.9	17.4	19.4	20.3	22.4	(33)	
(34)			MCDWB	29.3	28.1	26.4	23.0	20.1	17.6	17.5	19.9	20.4	23.3	25.5	28.0	(34)	
(35)	Mean Daily Temperature Range		5% DB	MDBR	11.5	10.7	10.6	9.9	9.2	9.4	9.3	10.6	10.4	10.4	11.7	11.9	(35)
(36)				MCDBR	13.8	13.1	13.0	13.0	11.8	10.4	11.1	13.5	13.6	13.8	14.8	14.6	(36)
(37)		MCWBR		5.1	5.0	5.2	5.9	6.1	6.5	6.4	7.2	7.1	6.6	5.7	5.2	(37)	
(38)		5% WB	MCDWB	11.3	10.7	10.1	9.5	9.5	8.2	9.3	11.5	10.7	10.9	11.4	11.7	(38)	
(39)			MCWBR	5.3	5.0	5.3	5.2	5.5	6.0	5.8	6.8	6.3	6.1	5.6	5.1	(39)	
(40)																	(40)
(41)	Clear-Sky Solar Irradiance	taub	0.419	0.399	0.385	0.380	0.365	0.369	0.362	0.443	0.482	0.429	0.397	0.411	(41)		
(42)		taud	2.320	2.396	2.415	2.387	2.397	2.372	2.370	2.092	1.998	2.221	2.340	2.321	(42)		
(43)		Ebn at Noon	921	918	894	839	796	760	789	757	785	879	935	932	(43)		
		Edh at Noon	137	122	112	103	91	88	92	136	168	144	133	138	(43)		
(44)	All-Sky Solar Radiation	RadAvg	7.17	6.13	5.25	3.84	2.77	2.37	2.54	3.35	4.50	5.55	6.81	7.26	(44)		
(45)		RadStd	0.46	0.52	0.53	0.47	0.23	0.26	0.29	0.30	0.36	0.53	0.51	0.43	(45)		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	+0.39	+0.43	+0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page