

MALARGUE, Argentina

WMO: 875060

Lat: 35.4814S

Lon: 69.5833W

Elev: 4675

StdP: 12.38

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.5	25.3	-3.1	5.5	57.6	2.4	7.4	56.0	27.7	50.1	25.3	50.6	3.0	230	0.490

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.6	87.3	59.5	84.9	58.4	82.7	57.6	64.5	79.2	62.7	77.6	61.0	75.9	9.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.4	90.2	70.7	57.4	83.8	68.3	55.4	77.6	67.5	32.2	80.1	30.7	77.7	29.4	75.9	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.6	21.0	17.8	15.6	92.9	4.5	1.8	12.4	94.2	9.8	95.3	7.3	96.3	4.0	97.6		
(5)			14.1	68.1	4.3	2.7	11.1	70.0	8.6	71.5	6.2	73.0	3.1	75.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.4	68.7	66.6	61.9	54.0	46.4	41.6	40.8	44.5	48.4	54.7	60.6	65.6	(6)	(7)
	DBStd	11.50	4.81	5.90	5.83	6.25	6.30	6.62	6.71	7.28	7.09	6.45	5.86	5.20	(7)	(8)
	HDD50	1087	1	0	3	30	147	264	295	203	110	29	4	1	(8)	(9)
	HDD65	4218	19	48	127	330	577	702	751	636	498	323	153	54	(9)	(10)
	CDD50	2702	581	465	372	152	35	12	9	33	63	174	321	485	(10)	(11)
	CDD65	357	134	93	32	2	0	0	0	0	0	3	20	73	(11)	(12)
	CDH74	4609	1563	1014	413	53	1	0	2	11	17	90	406	1039	(12)	(13)
	CDH80	1154	471	276	70	4	0	0	0	0	0	9	62	262	(13)	(14)
(14) Wind	WSAvg	5.6	5.7	5.4	4.5	4.3	4.4	5.5	5.4	6.2	6.6	6.6	6.7	6.4	(14)	(15)
(15) Precipitation	PrecAvg	11.2	1.0	0.9	0.9	0.8	0.9	1.5	1.3	0.8	0.8	0.8	0.9	1.1	(15)	(16)
	PrecMax	21.1	4.8	4.8	4.1	3.1	4.6	5.2	5.8	5.0	5.8	3.0	5.0	4.6	(16)	(17)
	PrecMin	4.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	(18)
	PrecStd	4.5	1.1	1.0	0.9	0.8	1.1	1.3	1.4	1.0	1.0	0.7	1.1	1.1	(18)	(19)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.4	89.8	85.5	79.5	71.3	68.4	68.4	75.3	76.4	81.0	84.9	89.4	(19)	(20)
		MCWB	61.2	60.8	58.6	54.1	49.6	45.3	46.4	50.0	50.5	54.8	55.8	59.0	(20)	(21)
	2%	DB	87.7	86.3	81.9	74.8	67.1	63.4	63.2	69.3	71.1	76.2	81.6	86.0	(21)	(22)
		MCWB	59.7	60.2	58.4	53.5	49.2	44.5	43.9	47.2	48.6	52.0	54.8	57.9	(22)	(23)
	5%	DB	84.9	83.4	78.8	70.7	63.1	58.7	58.9	64.2	67.0	72.8	78.8	83.0	(23)	(24)
		MCWB	58.6	59.2	57.3	52.5	47.6	42.7	42.2	45.0	47.0	50.2	53.7	56.5	(24)	(25)
	10%	DB	82.4	80.7	75.5	67.2	59.0	54.7	54.5	59.4	63.0	69.3	75.7	80.2	(25)	(26)
		MCWB	57.7	58.1	56.4	51.4	46.4	41.3	40.5	43.1	45.5	48.7	52.2	55.7	(26)	(27)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.5	66.8	65.0	59.8	55.0	47.9	47.9	51.6	53.2	58.8	60.5	64.0	(27)	(28)
		MCDB	82.3	82.0	78.2	70.3	65.8	62.8	64.8	70.4	70.9	73.8	75.7	79.5	(28)	(29)
	2%	WB	64.2	64.7	61.9	57.1	51.6	46.0	45.3	48.4	50.4	54.8	57.9	61.6	(29)	(30)
		MCDB	80.2	79.1	74.9	68.8	61.9	58.4	60.3	65.1	67.1	70.5	75.0	78.5	(30)	(31)
	5%	WB	62.2	62.9	60.1	55.0	49.5	44.1	43.2	46.0	48.3	52.6	56.1	59.7	(31)	(32)
		MCDB	78.1	77.2	73.2	66.3	59.1	55.4	55.9	61.3	64.2	67.7	73.7	77.0	(32)	(33)
	10%	WB	60.5	61.0	58.3	53.0	47.5	42.3	41.3	43.9	46.3	50.6	54.4	58.0	(33)	(34)
		MCDB	76.6	74.8	71.2	63.7	56.3	52.8	52.6	57.5	60.4	65.1	71.8	75.7	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	26.6	25.2	24.1	22.2	20.4	20.6	22.1	23.3	23.5	24.8	26.6	26.9	(35)	(36)
		MCDBR	30.0	29.4	29.1	28.7	27.9	27.9	29.8	32.5	30.9	30.2	31.0	31.7	(36)	(37)
		MCWBR	12.4	12.0	12.3	13.9	14.5	14.5	15.9	16.1	14.7	13.8	13.7	13.6	(37)	(38)
	5% WB	MCDBR	26.2	24.7	24.7	24.4	24.4	25.0	27.3	30.0	28.9	27.6	28.3	28.0	(38)	(39)
(40) Clear-Sky Solar Irradiance	taub	taub	0.329	0.321	0.305	0.287	0.269	0.252	0.252	0.268	0.292	0.293	0.294	0.309	(40)	(41)
		taud	2.428	2.459	2.503	2.539	2.560	2.585	2.573	2.519	2.452	2.467	2.478	2.469	(41)	(42)
	Ebn at Noon	Ebn at Noon	319	315	308	297	285	283	289	299	308	321	329	327	(42)	(43)
		Edh at Noon	39	36	32	27	23	21	22	27	33	35	36	37	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2687	2358	1933	1386	900	723	796	1052	1520	2001	2489	2749	(44)	(45)
	RadStd	RadStd	140	121	105	123	103	75	66	114	125	146	123	113	(45)	(46)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	+1.40	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page