

MALARGUE, ArgentinaWMO: **875060**Lat: **35.4814S**Lon: **69.5833W**Elev: **1425**StdP: **85.34**Time Zone: **-3.00 (W03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-5.3	-3.7	-19.5	0.8	14.2	-16.4	1.1	13.3	12.4	10.0	11.3	10.3	1.3	230	0.490

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.8	30.7	15.3	29.4	14.6	28.2	14.2	18.0	26.2	17.0	25.4	16.1	24.4	4.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.2	12.9	21.5	14.1	12.0	20.2	13.0	11.1	19.7	57.0	26.7	53.5	25.4	50.6	24.4	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.5	9.4	8.0	-9.1	33.8	2.5	1.0	-10.9	34.6	-12.3	35.1	-13.7	35.7	-15.5	36.4		
			-9.9	20.0	2.4	1.5	-11.6	21.1	-13.0	22.0	-14.4	22.8	-16.1	23.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.5	20.4	19.2	16.6	12.2	8.0	5.3	4.9	6.9	9.1	12.6	15.9	18.7
	DBStd	6.39	2.67	3.28	3.24	3.47	3.50	3.68	3.73	4.04	3.94	3.58	3.26	2.89
	HDD10.0	604	1	0	2	17	82	147	164	113	61	16	2	1
	HDD18.3	2343	11	27	71	183	321	390	417	353	277	179	85	30
	CDD10.0	1501	323	258	207	84	19	7	5	18	35	97	178	269
	CDD18.3	198	74	52	18	1	0	0	0	0	2	11	41	
	CDH23.3	2561	868	563	229	29	1	0	1	6	9	50	226	577
	CDH26.7	641	262	153	39	2	0	0	0	0	5	34	146	
(14) Wind	WSAvg	2.5	2.5	2.4	2.0	1.9	2.0	2.5	2.4	2.8	2.9	2.9	3.0	2.9
(15) Precipitation	PrecAvg	285	25	24	24	21	24	37	34	21	21	20	23	28
	PrecMax	537	122	122	104	79	118	132	148	128	147	76	127	118
	PrecMin	101	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	115	29	26	22	21	27	33	36	25	26	19	29	28
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.0	32.1	29.7	26.4	21.8	20.2	20.2	24.1	24.7	27.2	29.4	31.9
		MCWB	16.2	16.0	14.8	12.3	9.8	7.4	8.0	10.0	10.3	12.7	13.2	15.0
	2%	DB	30.9	30.2	27.7	23.8	19.5	17.5	17.4	20.7	21.7	24.6	27.6	30.0
		MCWB	15.4	15.6	14.7	11.9	9.5	6.9	6.6	8.4	9.2	11.1	12.6	14.4
	5%	DB	29.4	28.6	26.0	21.5	17.3	14.8	15.0	17.9	19.5	22.7	26.0	28.3
		MCWB	14.8	15.1	14.0	11.4	8.7	5.9	5.7	7.2	8.3	10.1	12.1	13.6
	10%	DB	28.0	27.0	24.2	19.6	15.0	12.6	12.5	15.2	17.2	20.7	24.3	26.8
		MCWB	14.3	14.5	13.6	10.8	8.0	5.2	4.7	6.1	7.5	9.3	11.2	13.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.7	19.4	18.3	15.5	12.8	8.9	8.9	10.9	11.8	14.9	15.8	17.8
		MCDB	27.9	27.8	25.7	21.3	18.8	17.1	18.2	21.3	21.6	23.2	24.3	26.4
	2%	WB	17.9	18.2	16.6	13.9	10.9	7.8	7.4	9.1	10.2	12.7	14.4	16.4
		MCDB	26.8	26.2	23.8	20.4	16.6	14.6	15.7	18.4	19.5	21.4	23.9	25.8
	5%	WB	16.8	17.2	15.6	12.8	9.7	6.7	6.2	7.8	9.0	11.5	13.4	15.4
		MCDB	25.6	25.1	22.9	19.1	15.0	13.0	13.3	16.3	17.9	19.8	23.2	25.0
	10%	WB	15.8	16.1	14.6	11.7	8.6	5.7	5.1	6.6	7.9	10.3	12.4	14.5
		MCDB	24.8	23.8	21.8	17.6	13.5	11.6	11.5	14.2	15.8	18.4	22.1	24.3
(35) Mean Daily Temperature Range	5% DB	MDBR	14.8	14.0	13.4	12.3	11.3	11.5	12.3	12.9	13.0	13.8	14.8	15.0
		MCDBR	16.7	16.3	16.1	15.9	15.5	15.5	16.6	18.1	17.2	16.8	17.2	17.6
		MCWBR	6.9	6.7	6.8	7.7	8.1	8.1	8.8	8.9	8.1	7.6	7.6	7.5
	5% WB	MCDBR	14.6	13.7	13.7	13.6	13.6	13.9	15.2	16.7	16.1	15.3	15.7	15.6
		MCWBR	6.7	6.0	6.3	7.3	7.7	8.1	8.7	8.7	8.1	7.5	7.4	7.5
(40) Clear-Sky Solar Irradiance	taub		0.329	0.321	0.305	0.287	0.269	0.252	0.252	0.268	0.292	0.293	0.294	0.309
	taud		2.428	2.459	2.503	2.539	2.560	2.585	2.573	2.519	2.452	2.467	2.478	2.469
	Ebn at Noon		1007	992	972	935	900	893	912	942	970	1011	1037	1031
	Edh at Noon		122	114	101	85	73	66	70	85	104	111	115	118
(44) All-Sky Solar Radiation	RadAvg		8.47	7.43	6.09	4.37	2.84	2.28	2.51	3.32	4.79	6.31	7.85	8.67
	RadStd		0.44	0.38	0.33	0.39	0.33	0.24	0.21	0.36	0.39	0.46	0.39	0.35

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	+0.78	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page