

BUENOS AIRES SAN FERNANDO, Argentina

WMO: 875530

Lat: 34.4550S

Lon: 58.5844W

Elev: 10

StdP: 101.20

Time Zone: -3.00 (W03)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.8	3.0	-2.9	3.0	6.7	-1.2	3.4	7.5	9.1	11.4	8.3	11.2	1.1	230	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.4	33.1	23.2	31.9	23.0	30.5	22.5	25.3	30.3	24.5	29.4	23.8	28.4	4.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.9	18.8	28.2	23.0	17.8	27.2	22.2	16.9	26.4	77.4	31.0	74.0	29.1	71.0	28.7	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.5	6.8	DB	-1.1	36.2	1.0	1.3	-1.8	37.1	-2.4	37.9	-3.0	38.6	-3.7	39.6	(4)
(5)			WB	-1.9	27.1	0.7	0.9	-2.4	27.7	-2.8	28.2	-3.2	28.7	-3.7	29.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	24.6	23.5	21.2	18.1	14.7	11.4	10.8	12.6	14.5	17.3	20.7	22.9	(6)	
	DBStd	5.67	2.63	2.80	3.13	3.46	3.13	3.28	3.46	3.96	3.24	3.13	2.92	3.19	(7)	
	HDD10.0	72	0	0	0	1	2	20	31	16	3	0	0	0	(8)	
	HDD18.3	993	1	1	11	44	118	208	234	184	121	57	11	3	(9)	
	CDD10.0	2873	453	378	346	243	148	63	56	97	138	228	321	401	(10)	
	CDD18.3	753	195	146	99	37	7	2	2	7	6	26	82	146	(11)	
	CDH23.3	5925	1797	1138	647	163	17	3	6	58	47	153	591	1305	(12)	
(13)	CDH26.7	1876	645	359	144	31	0	0	0	16	9	31	166	476	(13)	
(14)	Wind	WSAvg	3.2	3.5	3.3	3.0	2.6	2.5	2.6	2.8	3.1	3.6	3.6	3.7	3.5	(14)
(15) Precipitation	PrecAvg	1129	119	127	113	109	76	56	62	63	67	118	116	105	(15)	
	PrecMax	1779	244	298	336	197	296	119	158	218	179	272	239	266	(16)	
	PrecMin	681	34	36	23	15	3	5	9	3	18	30	17	26	(17)	
	PrecStd	238	57	75	70	55	60	35	36	57	42	64	58	63	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	33.8	31.8	30.1	25.2	23.1	23.9	29.0	27.2	30.0	32.8	35.2	(19)	
		MCWB	24.6	24.4	23.0	22.8	19.6	19.0	18.6	21.0	19.7	21.1	22.4	22.7	(20)	
	2%	DB	33.1	32.0	29.9	26.9	23.0	20.1	20.1	24.2	24.2	27.0	30.2	33.0	(21)	
		MCWB	23.6	24.0	22.5	20.3	18.1	16.3	15.7	18.5	17.1	19.6	21.6	22.4	(22)	
	5%	DB	31.8	30.7	28.1	25.0	21.1	18.8	17.9	21.1	22.0	25.0	28.8	31.1	(23)	
		MCWB	23.2	23.3	21.3	19.9	17.5	15.6	14.6	16.3	15.9	18.3	20.5	21.8	(24)	
	10%	DB	30.1	29.0	26.8	23.2	19.9	17.0	16.1	18.9	20.1	23.0	26.9	29.2	(25)	
		MCWB	22.6	22.7	21.6	19.0	16.8	14.0	13.2	14.9	14.7	17.4	19.8	21.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	26.4	25.2	23.5	20.7	19.6	18.3	21.4	21.0	23.4	24.0	25.7	(27)	
		MCDB	32.2	31.0	28.9	28.8	23.5	21.5	21.6	27.6	25.4	28.8	29.7	30.6	(28)	
	2%	WB	25.4	25.1	24.0	22.1	19.3	17.8	16.9	19.4	18.6	21.1	22.8	24.5	(29)	
		MCDB	30.9	29.8	27.5	25.1	21.6	19.8	19.4	24.0	22.4	25.2	28.0	29.9	(30)	
	5%	WB	24.4	24.2	23.0	21.1	18.3	16.2	15.3	17.5	17.3	19.6	21.7	23.6	(31)	
		MCDB	29.6	28.7	26.4	23.7	20.5	17.8	17.3	20.1	20.4	23.0	26.9	28.7	(32)	
	10%	WB	23.6	23.5	22.1	20.1	17.3	14.6	14.0	15.7	16.1	18.5	20.7	22.6	(33)	
		MCDB	28.4	27.5	25.6	22.7	19.4	16.6	15.9	18.0	19.2	22.0	25.2	27.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	8.8	9.2	8.8	8.0	9.0	8.5	9.3	8.8	8.6	9.6	10.0	(35)	
		MCDBR	11.7	10.8	10.6	11.0	9.6	10.0	10.7	11.6	11.9	11.6	12.7	12.9	(36)	
	5% WB	MCWBR	5.3	5.2	5.2	5.9	5.7	6.8	6.9	6.9	6.8	6.2	6.1	5.9	(37)	
		MCWBR	9.9	9.3	8.9	8.6	7.5	7.5	8.3	10.0	9.2	9.3	10.3	10.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.412	0.396	0.375	0.378	0.368	0.370	0.364	0.434	0.461	0.420	0.398	0.400	(40)	
		taud	2.360	2.424	2.469	2.410	2.405	2.382	2.384	2.138	2.077	2.261	2.353	2.371	(41)	
	Ebn at Noon		926	919	901	835	783	748	779	759	799	885	933	941	(42)	
		Edh at Noon	131	118	106	100	88	85	89	128	153	138	131	131	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.20	6.29	5.28	3.82	2.68	2.26	2.36	3.21	4.38	5.54	6.71	7.49	(44)	
	RadStd		0.41	0.56	0.48	0.45	0.23	0.24	0.27	0.33	0.30	0.51	0.44	0.37	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (6 neighbors)	+0.27	N/A	N/A	+0.60	+0.40	+0.40	N/A	N/A	+82	+42	(47)

Nomenclature: See separate page