

BUENOS AIRES EZEIZA, Argentina

WMO: 875760

Lat: 34.8186S

Lon: 58.5422W

Elev: 66

StdP: 14.66

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.0	35.0	25.1	19.2	41.6	28.1	22.0	42.7	22.3	54.7	20.1	54.2	3.6	270	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.9	93.1	72.4	90.2	71.9	87.9	71.0	76.5	86.7	75.0	85.0	73.6	83.0	10.1	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.6	125.2	81.4	71.9	118.1	79.4	70.7	113.3	78.4	40.0	86.7	38.6	84.9	37.3	83.3	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.7	18.3	16.3	DB	26.9	98.7	2.1	2.5	25.4	100.4	24.1	101.9	22.9	103.2	21.4	105.0	
			WB	25.9	79.8	2.2	1.6	24.3	81.0	23.0	82.0	21.8	82.9	20.2	84.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.7	75.2	73.3	69.4	63.0	57.0	51.8	50.6	53.6	56.7	62.0	67.7	72.6	(6)
(7)		DBStd	10.66	5.64	5.83	6.09	6.47	6.91	6.59	7.06	7.61	6.62	6.12	6.56	6.28	(7)
(8)		HDD50	209	0	0	0	1	14	53	79	45	16	1	0	0	(8)
(9)		HDD65	2079	3	7	28	111	264	400	451	365	261	132	45	12	(9)
(10)		CDD50	4838	780	653	601	392	231	107	97	156	216	373	530	702	(10)
(11)		CDD65	1231	318	239	164	52	15	4	4	11	11	38	126	249	(11)
(12)		CDH74	11273	3255	2179	1276	315	57	5	15	92	84	302	1144	2549	(12)
(13)		CDH80	4017	1342	793	358	54	6	0	2	20	12	62	352	1016	(13)
(14)	Wind	WSAvg	7.8	8.3	7.8	7.3	6.9	6.4	7.0	7.4	7.9	8.7	8.6	8.6	8.3	(14)
(15)	Precipitation	PrecAvg	38.5	3.7	4.1	4.1	3.5	2.8	1.9	2.4	2.2	2.4	4.1	3.9	3.8	(15)
(16)		PrecMax	58.9	10.1	12.8	18.0	8.3	12.0	5.0	6.7	7.7	7.2	14.3	8.4	11.3	(16)
(17)		PrecMin	24.8	0.2	0.7	0.2	0.1	0.0	0.0	0.3	0.0	0.2	0.6	0.3	0.6	(17)
(18)		PrecStd	7.8	2.4	2.6	3.1	2.2	2.6	1.4	1.4	1.9	1.6	2.6	2.3	2.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.9	94.1	90.8	86.0	79.9	73.6	75.4	82.6	80.9	86.3	91.6	96.3	(19)
(20)		0.4%	MCWB	74.1	74.3	72.5	71.4	68.0	67.1	65.1	68.7	66.3	68.0	70.6	72.7	(20)
(21)		2%	DB	93.2	91.0	87.4	80.7	74.9	69.1	68.9	75.5	75.8	80.7	87.4	92.3	(21)
(22)		2%	MCWB	72.7	73.8	71.5	67.8	65.0	62.5	61.3	63.8	62.6	65.6	68.9	71.1	(22)
(23)		5%	DB	90.1	88.0	84.1	77.4	71.3	65.8	64.8	70.1	71.9	77.1	84.1	89.2	(23)
(24)		5%	MCWB	72.0	72.7	70.3	66.8	63.7	59.7	58.1	60.3	60.1	64.3	66.9	70.0	(24)
(25)		10%	DB	87.4	85.0	80.9	74.6	68.0	62.6	61.8	65.9	68.4	73.6	80.7	86.0	(25)
(26)		10%	MCWB	71.2	71.2	69.4	65.2	61.3	56.9	56.0	57.6	58.2	62.2	65.9	69.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.0	78.3	77.0	73.9	69.9	68.7	65.8	69.2	70.2	72.1	74.0	77.1	(27)
(28)		0.4%	MCDWB	89.0	89.2	84.0	81.7	76.2	72.8	73.4	80.4	79.1	81.7	85.5	87.8	(28)
(29)		2%	WB	76.3	76.3	74.4	71.0	67.1	64.6	63.1	65.4	65.7	68.3	71.4	74.6	(29)
(30)		2%	MCDWB	87.8	86.2	82.0	77.1	72.5	68.2	67.8	73.7	72.2	75.7	82.4	85.8	(30)
(31)		5%	WB	74.6	74.7	72.6	68.9	65.0	61.3	60.1	62.3	62.6	66.2	69.5	73.0	(31)
(32)		5%	MCDWB	85.4	83.8	80.1	74.3	69.6	64.4	63.7	67.7	68.8	73.5	79.6	83.6	(32)
(33)		10%	WB	73.2	73.1	71.0	66.9	62.8	58.1	57.3	59.2	60.1	64.3	67.7	71.3	(33)
(34)		10%	MCDWB	83.1	81.4	78.2	72.4	66.9	61.2	60.7	64.3	66.2	71.3	77.3	81.3	(34)
(35)	Mean Daily Temperature Range		MDBR	20.9	19.7	19.4	18.6	17.1	16.6	16.5	18.2	18.6	18.6	20.5	21.7	(35)
(36)		5% DB	MCDBR	24.0	22.2	22.0	21.5	18.5	17.2	18.3	21.9	22.3	22.7	23.9	25.1	(36)
(37)		5% DB	MCWBR	9.7	9.0	9.8	11.3	10.6	11.7	11.7	12.5	12.3	11.6	10.3	10.3	(37)
(38)		5% WB	MCDBR	20.6	19.4	18.3	17.1	15.1	13.6	15.0	18.8	18.3	18.7	20.3	21.3	(38)
(39)		5% WB	MCWBR	10.1	9.7	9.8	10.5	9.5	11.1	11.2	12.0	11.6	11.1	10.7	10.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.412	0.396	0.373	0.372	0.370	0.367	0.361	0.427	0.455	0.417	0.399	0.398	(40)	
(41)		taud	2.343	2.405	2.459	2.409	2.378	2.374	2.377	2.144	2.080	2.252	2.331	2.361	(41)	
(42)		Ebn at Noon	293	291	286	266	247	238	247	242	255	281	295	299	(42)	
(43)		Edh at Noon	42	38	34	31	29	27	28	40	49	44	43	42	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2278	1986	1655	1202	842	707	740	1003	1372	1745	2124	2380	(44)	
(45)		RadStd	129	177	145	136	70	71	83	103	95	166	137	115	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+0.50	N/A	N/A	+1.01	N/A	+0.67	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.41	N/A	N/A	+1.08	N/A	N/A	N/A	+148	+76

Nomenclature: See separate page