

BUENOS AIRES NEWBERY, ArgentinaWMO: **875820**Lat: **34.5589S**Lon: **58.4197W**Elev: **20**StdP: **14.69**Time Zone: **-3.00 (W03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.6	42.7	24.6	18.8	49.0	28.1	22.1	49.8	24.6	51.6	22.3	52.3	8.1	230	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.3	88.9	73.8	86.1	73.4	84.2	72.5	77.5	84.6	76.1	83.1	74.7	81.6	9.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.3	132.7	82.7	73.6	125.3	81.1	72.0	118.6	79.6	41.1	85.0	39.6	83.2	38.3	81.7	88.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.5	21.6	19.3	DB	36.1	95.0	1.8	3.0	34.9	97.1	33.8	98.9	32.8	100.5	31.5	102.7	(4)
(5)			WB	32.4	81.3	2.0	2.2	31.0	82.9	29.8	84.2	28.6	85.5	27.2	87.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.6	76.2	74.8	71.4	65.4	59.6	54.4	52.9	55.6	58.5	63.9	69.2	73.9	(6)	
	DBStd	9.61	4.59	4.81	4.85	5.43	5.37	5.22	5.53	5.85	5.31	5.22	5.49	5.37	(7)	
	HDD50	70	0	0	0	0	3	16	32	15	4	0	0	0	(8)	
	HDD65	1551	0	1	8	59	179	319	375	298	204	82	22	4	(9)	
	CDD50	5401	813	693	664	462	301	149	124	188	258	431	577	741	(10)	
	CDD65	1412	349	275	208	71	13	2	2	6	8	49	149	280	(11)	
	CDH74	8396	2685	1811	902	161	14	2	3	16	18	131	697	1956	(12)	
	CDH80	1872	704	387	112	19	1	0	0	2	2	16	118	511	(13)	
(14) Wind	WSAvg	9.6	10.5	10.1	9.5	8.7	8.2	8.0	8.5	9.0	10.4	10.8	10.9	10.5	(14)	
(15) Precipitation	PrecAvg	41.3	4.3	4.1	4.9	3.9	3.0	2.2	2.3	2.5	2.5	4.1	3.9	3.9	(15)	
	PrecMax	57.2	11.0	10.6	23.1	9.5	15.3	7.3	7.5	8.0	7.9	12.4	9.3	11.2	(16)	
	PrecMin	25.6	0.6	1.0	1.0	0.2	0.0	0.2	0.4	0.0	0.0	0.7	0.8	0.8	(17)	
	PrecStd	8.3	2.6	2.4	3.8	2.6	3.2	1.7	1.3	1.9	1.7	2.5	2.1	2.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.8	90.8	86.1	82.6	75.5	70.6	70.4	75.8	76.7	82.1	87.0	93.0	(19)	
		MCWB	76.9	74.7	73.7	71.2	66.7	64.6	63.3	65.9	64.2	68.9	71.0	72.3	(20)	
	2%	DB	89.0	86.4	82.7	78.2	71.6	66.8	66.0	70.0	71.8	77.2	83.0	88.0	(21)	
		MCWB	74.7	74.9	72.5	69.3	65.2	61.6	60.6	61.8	61.7	66.3	69.2	72.5	(22)	
	5%	DB	86.1	84.3	80.7	75.3	69.1	64.4	62.9	66.6	68.9	74.4	80.5	84.9	(23)	
		MCWB	73.8	74.1	71.8	67.6	63.8	59.6	58.2	59.8	60.5	65.0	69.0	71.9	(24)	
	10%	DB	83.9	82.2	78.7	73.2	67.1	62.1	60.7	64.2	66.3	71.8	77.8	82.5	(25)	
		MCWB	72.9	73.0	70.9	66.6	62.4	57.8	56.2	58.2	59.0	63.6	67.5	71.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	79.2	77.4	74.1	69.2	67.2	64.4	67.5	68.4	72.7	74.8	78.3	(27)	
		MCDB	87.9	85.9	82.1	79.7	73.6	69.9	69.0	74.2	73.5	79.2	82.1	86.3	(28)	
	2%	WB	77.6	77.3	75.2	71.4	67.0	63.7	61.9	64.3	65.1	69.1	72.7	75.9	(29)	
		MCDB	85.3	84.0	80.3	75.6	70.2	65.8	64.9	68.7	69.5	74.4	80.1	83.9	(30)	
	5%	WB	76.1	75.6	73.4	69.5	65.1	61.2	59.8	61.8	62.7	67.2	70.9	74.4	(31)	
		MCDB	83.6	82.1	78.6	73.4	68.1	63.5	62.2	65.5	66.7	72.2	78.0	82.0	(32)	
	10%	WB	74.5	74.2	72.0	67.8	63.4	58.7	57.4	59.3	60.6	65.4	69.1	72.7	(33)	
		MCDB	81.8	80.5	77.4	71.9	66.5	61.1	59.8	62.8	64.7	70.4	76.0	80.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.3	11.4	10.9	10.9	9.7	10.0	9.8	11.0	11.0	11.2	12.5	13.3	(35)	
		MCDBR	15.2	13.6	12.7	13.7	11.8	12.1	12.3	14.7	14.9	14.6	15.8	16.3	(36)	
	5% WB	MCWBR	9.6	8.2	7.7	9.0	8.0	9.1	8.7	9.7	9.2	9.4	9.4	9.7	(37)	
		MCWBR	13.2	11.8	10.6	11.1	9.5	9.7	10.1	12.6	11.5	11.8	13.3	13.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.411	0.397	0.376	0.378	0.371	0.369	0.363	0.434	0.461	0.420	0.397	0.401	(40)	
		taud	2.375	2.433	2.478	2.421	2.405	2.400	2.395	2.145	2.086	2.272	2.365	2.378	(41)	
	Ebn at Noon		294	291	285	265	247	238	247	240	253	281	296	298	(42)	
		Edh at Noon	41	37	33	31	28	27	28	40	48	43	41	41	(43)	
(44) All-Sky Solar Radiation	RadAvg		2285	1996	1671	1210	847	712	744	1011	1382	1756	2129	2379	(44)	
	RadStd		131	179	151	141	73	74	86	103	95	163	142	118	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.43	N/A	-1.48	+1.12	+0.88	N/A	N/A	N/A	+191	+112	(46)
(47)	Regional (6 neighbors)	+0.49	N/A	N/A	+1.08	+0.72	+0.72	N/A	N/A	+148	+76	(47)

Nomenclature: See separate page