

SANTA ROSA, Argentina

WMO: 876230

Lat: 36.5931S

Lon: 64.2800W

Elev: 627

StdP: 14.37

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.9	30.9	15.0	12.0	45.8	18.0	13.9	44.8	24.0	52.0	21.2	52.1	2.7	290	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.2	95.7	69.9	92.7	69.0	89.8	68.3	74.9	87.5	73.1	85.9	71.4	84.3	11.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.4	118.7	80.7	69.3	110.1	78.7	67.4	103.2	77.2	38.9	87.7	37.2	85.5	35.7	84.5	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.6	20.8	18.5	DB	21.7	101.8	3.6	3.4	19.1	104.3	17.0	106.3	14.9	108.3	12.3	110.8	(4)
(5)			WB	20.4	77.9	3.2	1.9	18.1	79.3	16.3	80.4	14.5	81.5	12.2	82.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.0	75.3	72.7	68.1	60.6	53.6	47.9	46.9	50.7	55.4	60.9	67.5	72.8	(6)	
	DBStd	11.60	5.74	6.51	6.60	6.67	6.45	5.32	5.92	6.76	6.70	6.23	6.28	6.23	(7)	
	HDD50	368	0	0	0	5	33	100	131	72	25	2	0	0	(8)	
	HDD65	2603	2	12	43	161	358	514	561	447	293	158	44	10	(9)	
	CDD50	4376	784	636	561	324	145	36	35	93	188	340	526	708	(10)	
	CDD65	1135	321	228	139	30	5	0	0	2	6	31	120	253	(11)	
	CDH74	12396	3543	2309	1319	317	41	0	1	42	126	423	1367	2908	(12)	
	CDH80	5173	1682	997	478	68	4	0	0	8	22	103	485	1326	(13)	
(14) Wind	WSAvg	7.9	8.5	8.1	8.0	6.9	6.5	6.0	6.7	8.0	8.6	9.0	9.2	9.0	(14)	
(15) Precipitation	PrecAvg	27.9	3.2	3.2	3.7	2.3	1.3	0.6	0.7	1.0	1.7	3.2	3.5	3.7	(15)	
	PrecMax	46.2	8.0	8.5	13.0	6.7	5.4	2.3	6.9	5.7	5.2	9.7	11.2	14.9	(16)	
	PrecMin	14.1	0.4	0.2	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.3	0.4	(17)	
	PrecStd	7.8	1.9	2.0	2.6	1.8	1.3	0.6	1.1	1.3	1.4	2.4	2.1	2.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.9	97.8	94.1	86.0	79.2	69.0	70.6	80.3	82.7	88.2	93.9	99.1	(19)	
		MCWB	71.8	72.3	71.1	67.0	64.5	54.9	56.6	59.8	60.3	65.4	66.2	70.0	(20)	
	2%	DB	95.6	93.5	89.3	81.7	72.9	64.7	65.1	72.3	77.4	82.6	89.3	94.9	(21)	
		MCWB	70.2	70.5	69.9	64.7	60.4	52.3	52.1	55.1	58.8	62.9	65.7	68.6	(22)	
	5%	DB	92.3	90.0	85.6	77.5	68.4	61.2	61.4	67.7	73.3	78.6	85.8	91.3	(23)	
		MCWB	69.1	69.9	68.2	62.4	57.6	50.5	50.3	53.5	56.1	61.2	64.0	67.8	(24)	
	10%	DB	89.1	86.3	81.7	73.5	64.8	58.2	58.3	63.5	69.3	75.0	82.0	87.6	(25)	
		MCWB	68.6	68.6	66.6	60.3	56.1	49.8	49.3	50.6	54.0	58.9	62.4	66.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.8	77.4	75.8	71.3	67.1	58.9	60.2	63.9	64.4	69.8	71.6	75.7	(27)	
		MCDB	88.9	87.9	86.6	78.2	75.2	62.7	63.7	72.8	77.5	81.9	85.6	88.9	(28)	
	2%	WB	74.5	74.6	72.8	67.8	63.3	55.8	56.4	58.0	60.9	66.2	68.7	72.6	(29)	
		MCDB	88.2	86.9	83.3	75.0	69.9	60.1	60.7	66.7	73.2	78.1	81.8	87.0	(30)	
	5%	WB	72.6	72.8	70.4	65.5	60.4	53.2	53.1	55.3	58.3	63.6	66.7	70.6	(31)	
		MCDB	86.6	84.9	81.7	73.7	65.7	58.3	58.4	64.7	69.0	74.2	80.3	85.3	(32)	
	10%	WB	70.8	71.0	68.3	63.0	57.6	51.1	50.4	52.6	55.9	61.1	64.8	68.8	(33)	
		MCDB	84.4	82.4	79.3	71.5	63.0	56.0	56.3	61.2	65.9	71.7	77.3	83.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	24.2	23.3	22.1	21.1	19.3	20.0	20.4	21.8	22.7	22.0	24.0	24.9	(35)	
		MCDBR	29.1	27.9	27.3	27.6	24.7	25.0	26.0	27.9	29.6	28.9	29.4	30.1	(36)	
	5% WB	MCWBR	10.6	10.5	11.6	13.6	13.4	14.5	14.9	14.8	14.5	13.8	12.4	11.5	(37)	
		MCWBR	24.0	23.8	23.7	21.2	20.0	20.5	20.3	23.8	25.1	25.0	25.1	25.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.399	0.383	0.365	0.356	0.334	0.318	0.325	0.352	0.404	0.388	0.376	0.391	(40)	
		taud	2.330	2.379	2.432	2.421	2.454	2.494	2.448	2.362	2.193	2.300	2.347	2.330	(41)	
	Ebn at Noon		297	294	287	269	257	253	257	266	268	289	302	301	(42)	
		Edh at Noon	43	39	34	30	26	23	25	32	43	42	42	43	(43)	
(44) All-Sky Solar Radiation	RadAvg		2457	2138	1694	1195	798	694	744	1026	1410	1800	2312	2537	(44)	
	RadStd		119	102	110	154	85	84	74	100	108	146	121	152	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+1.26	N/A	N/A	-79	-238	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page