

AZUL, Argentina

WMO: 876410

Lat: 36.8322S

Lon: 59.8864W

Elev: 482

StdP: 14.44

Time Zone: -3.00 (W03)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.6	29.4	21.3	16.3	39.2	23.8	18.3	37.9	30.3	48.1	27.1	48.8	1.6	270	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.9	91.0	68.9	88.2	68.3	85.5	67.6	73.6	83.8	71.8	82.0	70.3	80.3	12.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.5	114.5	78.0	68.7	107.5	76.1	67.2	101.9	74.7	37.6	84.0	35.9	81.8	34.6	80.6	81.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.3	23.6	21.9	DB	21.4	97.0	2.7	2.6	19.4	98.9	17.8	100.4	16.3	101.9	14.3	103.8	(4)
(5)			WB	21.4	77.1	2.6	2.1	19.5	78.6	18.0	79.8	16.6	81.0	14.7	82.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.8	71.0	69.3	64.4	57.9	51.8	46.5	45.2	48.5	51.8	56.8	62.7	68.4	(6)	
	DBStd	10.72	5.87	6.01	6.32	6.52	6.25	5.34	5.97	6.54	5.97	5.89	6.31	6.41	(7)	
	HDD50	534	0	0	0	10	52	131	173	106	48	12	2	0	(8)	
	HDD65	3266	17	27	91	226	410	555	614	512	397	262	115	40	(9)	
	CDD50	3380	652	540	445	247	108	26	24	60	102	223	383	570	(10)	
	CDD65	636	203	147	71	13	1	0	0	1	1	8	46	145	(11)	
	CDH74	6694	2203	1368	572	97	6	0	0	15	16	98	603	1716	(12)	
	CDH80	2308	866	477	133	7	0	0	0	4	2	15	148	656	(13)	
(14) Wind	WSAvg	8.0	8.9	7.4	7.2	6.5	6.5	7.1	7.2	8.3	9.3	9.3	9.5	9.1	(14)	
(15) Precipitation	PrecAvg	36.9	4.2	4.3	4.6	3.2	2.3	1.5	1.7	2.2	2.3	3.4	3.5	3.5	(15)	
	PrecMax	54.4	9.4	16.6	11.7	8.4	5.4	3.8	4.2	11.5	5.3	7.2	7.8	8.6	(16)	
	PrecMin	24.4	2.1	0.7	1.0	0.2	0.3	0.2	0.0	0.0	0.1	0.8	0.6	0.9	(17)	
	PrecStd	9.1	2.2	3.6	2.6	2.2	1.5	1.1	1.1	2.6	1.6	1.6	2.0	2.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.8	92.9	88.5	80.8	74.1	66.0	66.2	74.7	75.8	82.0	88.0	94.4	(19)	
		MCWB	69.8	69.4	69.7	65.5	63.3	58.9	58.5	61.9	61.4	64.8	67.8	68.5	(20)	
	2%	DB	91.4	88.8	83.6	76.9	69.3	62.2	61.5	68.0	70.8	76.4	84.1	90.2	(21)	
		MCWB	69.1	70.7	67.9	64.5	60.7	55.4	54.8	57.7	57.8	62.2	65.1	67.7	(22)	
	5%	DB	88.2	85.9	79.8	73.8	65.5	59.1	58.6	63.1	67.6	72.9	80.8	87.0	(23)	
		MCWB	68.0	69.1	66.6	62.7	57.9	53.0	52.9	54.0	55.6	60.1	64.2	66.9	(24)	
	10%	DB	85.1	82.5	76.8	70.7	62.4	56.4	55.5	59.9	64.1	69.6	77.1	83.3	(25)	
		MCWB	67.4	68.6	65.4	61.4	56.8	51.0	50.6	52.5	54.0	58.7	62.3	66.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.2	76.4	73.8	71.7	66.4	63.0	61.2	65.1	66.1	67.2	70.5	74.2	(27)	
		MCDB	87.0	85.7	81.9	78.4	71.5	64.8	64.8	72.6	71.5	76.4	82.8	86.4	(28)	
	2%	WB	73.0	73.7	71.1	68.2	63.1	58.5	57.6	60.3	60.8	64.1	67.8	71.7	(29)	
		MCDB	84.6	82.3	79.1	72.1	66.9	60.0	59.9	64.1	67.6	72.6	79.6	83.2	(30)	
	5%	WB	71.1	71.7	68.9	65.4	60.4	54.5	54.2	56.8	58.0	62.3	65.9	69.8	(31)	
		MCDB	82.5	81.0	76.7	70.6	63.6	57.1	56.7	60.8	64.1	70.1	76.9	81.7	(32)	
	10%	WB	69.7	69.9	67.1	63.0	57.9	51.9	51.5	53.9	55.7	60.4	64.0	67.8	(33)	
		MCDB	80.7	78.7	74.2	69.1	61.2	55.6	54.6	58.9	61.5	67.5	73.8	79.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	24.9	22.7	21.7	21.5	19.0	18.8	17.7	19.2	20.3	20.9	23.9	25.1	(35)	
		MCDBR	28.8	26.6	24.9	25.6	22.3	21.3	21.1	23.8	26.1	26.5	28.4	29.5	(36)	
	5% WB	MCWBR	11.2	10.6	11.5	13.9	13.1	14.0	13.9	14.4	14.5	14.3	12.8	11.5	(37)	
		MCWBR	23.8	21.9	20.5	19.1	16.5	15.7	15.7	18.6	20.4	21.9	24.4	25.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.403	0.388	0.373	0.362	0.353	0.335	0.338	0.390	0.431	0.404	0.390	0.392	(40)	
		taud	2.315	2.365	2.400	2.382	2.372	2.432	2.397	2.222	2.100	2.239	2.307	2.319	(41)	
	Ebn at Noon		295	292	284	266	248	245	251	251	259	284	298	300	(42)	
		Edh at Noon	43	39	35	31	28	24	27	36	47	44	43	43	(43)	
(44) All-Sky Solar Radiation	RadAvg		2346	2037	1626	1176	799	667	702	973	1340	1739	2178	2467	(44)	
	RadStd		116	147	111	117	62	68	73	106	94	170	121	108	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	+1.35	N/A	N/A	N/A	N/A	N/A	+67

Nomenclature: See separate page