

BAHIA BLANCA, Argentina

WMO: 877500

Lat: 38.7147S

Lon: 62.1631W

Elev: 272

StdP: 14.55

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.0	30.6	18.8	14.3	44.1	21.6	16.3	43.2	43.0	55.7	36.9	53.1	7.4	320	0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.1	95.5	68.7	92.8	67.9	89.6	67.0	73.3	87.5	71.5	85.0	69.9	83.6	18.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.1	108.2	78.8	67.3	101.4	76.7	65.6	95.6	75.1	37.1	87.7	35.4	84.9	34.1	83.9	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.2	31.1	28.0	23.1	101.4	3.3	2.3	20.7	103.1	18.7	104.4	16.9	105.7	14.5	107.4		
(5)			21.9	77.0	3.2	1.9	19.5	78.3	17.6	79.4	15.8	80.5	13.5	81.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.2	74.3	71.9	67.4	59.9	53.6	48.1	47.0	50.1	53.9	59.3	65.9	71.4
	DBStd	11.46	6.30	6.88	6.92	6.64	6.49	5.80	6.30	6.78	6.90	6.59	6.77	6.87
	HDD50	397	0	0	0	4	33	102	135	82	35	6	0	0
	HDD65	2769	5	16	53	179	358	508	557	464	339	201	69	20
	CDD50	4113	754	614	540	302	146	45	43	84	152	294	476	663
	CDD65	1010	294	210	129	27	5	0	0	2	6	24	95	218
	CDH74	11257	3379	2236	1268	245	33	0	2	21	64	299	1144	2566
	CDH80	4737	1615	996	454	50	3	0	0	4	7	67	392	1149
Wind	WSAvg	13.9	15.8	14.6	13.4	12.8	12.1	13.2	13.1	13.5	13.7	13.9	14.5	15.7
Precipitation	PrecAvg	24.6	2.4	2.7	3.1	2.3	1.6	1.0	1.1	1.2	1.9	2.8	2.5	2.5
	PrecMax	43.0	6.7	9.8	10.3	8.3	4.4	4.0	3.5	5.4	4.8	8.9	9.5	8.3
	PrecMin	13.0	0.1	0.0	0.5	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0
	PrecStd	5.6	1.6	2.1	2.0	1.9	1.2	0.9	1.0	1.1	1.3	1.9	1.5	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.0	98.1	94.8	85.2	78.8	67.9	70.0	76.3	80.2	86.3	93.4	98.6
		MCWB	69.5	70.3	70.0	65.4	64.1	56.1	56.5	59.5	60.2	64.7	66.1	69.8
	2%	DB	95.7	93.8	89.2	80.5	71.9	64.0	64.6	70.2	75.2	81.0	88.5	94.4
		MCWB	68.9	69.2	68.1	64.1	60.5	53.7	53.2	55.3	57.9	62.3	64.4	67.3
	5%	DB	92.5	90.0	85.0	76.0	67.9	60.9	61.1	66.2	71.4	77.0	84.5	90.5
		MCWB	68.2	67.9	66.7	62.1	58.1	51.6	51.3	53.4	55.7	60.4	63.1	66.1
	10%	DB	89.2	86.4	81.1	72.0	64.4	58.3	58.2	62.5	67.6	73.2	80.8	86.4
		MCWB	67.1	66.8	64.7	60.1	56.2	50.6	49.7	51.3	53.5	58.5	61.4	64.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.4	75.4	73.9	70.3	66.6	59.1	60.9	63.5	63.8	68.6	69.6	74.5
		MCDB	90.6	89.2	86.2	77.1	73.2	64.6	66.3	71.5	74.1	80.3	84.4	89.5
	2%	WB	72.8	72.9	71.1	66.6	63.2	56.3	56.2	57.6	60.4	65.0	67.3	71.3
		MCDB	87.8	86.4	83.7	75.5	69.3	60.8	61.0	66.1	71.3	76.0	81.8	87.0
	5%	WB	70.8	71.1	69.0	64.4	60.0	53.8	53.2	54.9	57.8	62.5	65.4	69.1
		MCDB	85.9	83.5	80.7	72.9	65.8	58.7	59.6	63.7	67.9	72.9	79.3	84.0
	10%	WB	69.1	69.4	67.0	62.0	57.4	51.5	50.5	52.3	55.3	60.3	63.5	67.0
		MCDB	83.6	81.2	77.6	69.7	62.6	57.0	56.4	60.4	65.4	70.5	76.7	81.4
Mean Daily Temperature Range	5% DB	MDBR	25.1	23.7	22.5	21.1	18.7	18.5	19.1	20.4	22.1	22.4	24.4	25.4
		MCDBR	29.5	28.5	26.2	25.9	22.2	21.0	22.4	24.2	26.8	28.3	29.1	30.4
		MCWBR	11.5	11.2	11.4	12.9	12.5	12.7	13.4	13.5	14.1	14.1	12.3	12.0
	5% WB	MCDBR	25.8	23.3	22.9	21.3	18.7	17.5	19.0	21.5	23.5	24.3	25.1	26.2
		MCWBR	11.8	11.2	11.8	12.2	12.1	12.2	13.1	13.2	13.8	14.1	12.6	12.4
Clear-Sky Solar Irradiance	taub	0.394	0.381	0.366	0.360	0.336	0.321	0.323	0.366	0.399	0.380	0.380	0.394	
	taud	2.347	2.388	2.435	2.404	2.442	2.484	2.465	2.314	2.223	2.326	2.349	2.322	
	Ebn at Noon	297	293	284	264	250	246	253	256	268	290	300	299	
	Edh at Noon	42	38	34	30	25	22	24	32	41	40	41	43	
All-Sky Solar Radiation	RadAvg	2482	2121	1669	1159	751	628	678	935	1341	1758	2264	2536	
	RadStd	95	87	72	106	61	59	57	104	82	126	120	136	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+135	-130	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page