

SAN ANTONIO OESTE, Argentina

WMO: 877840

Lat: 40.757S

Lon: 65.031W

Elev: 66

StdP: 14.66

Time Zone: -3.00 (W03)

Period: 95-09

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.1	29.1	11.9	10.1	56.5	15.7	12.2	53.1	34.2	54.2	30.5	48.2	6.6	320	0.660

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.0	95.3	64.2	92.0	63.1	88.4	62.0	69.1	83.5	67.3	81.2	65.8	79.6	19.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	92.1	73.5	62.8	85.7	72.5	60.9	80.2	71.0	33.3	83.1	31.8	81.1	30.6	79.6	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.8	27.7	25.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB													
			WB	19.0	74.0	3.2	1.9	16.7	75.4	14.9	76.5	13.1	77.6	10.8	79.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.7	72.6	71.1	66.4	58.0	50.8	46.1	45.7	48.5	52.0	59.4	64.9	69.2		
	DBStd	11.57	5.97	7.20	7.09	6.69	5.67	5.67	6.27	6.03	7.08	6.86	7.09	6.38		
	HDD50	539	0	0	0	8	60	141	164	103	58	5	0	0		
	HDD65	3154	7	20	69	230	441	567	600	512	394	199	85	30		
	CDD50	3703	702	591	509	246	84	24	29	56	119	298	449	596		
	CDD65	843	244	191	112	19	1	0	0	4	27	84	161			
	CDH74	9083	2498	2026	1108	220	14	0	0	5	56	375	1041	1740		
	CDH80	3722	1103	947	404	45	1	0	0	8	107	397	710			
(14) Wind	WSAvg	12.8	14.7	14.2	13.2	12.0	11.0	11.4	12.3	12.1	11.6	13.0	13.9	14.4		
(15) Precipitation	PrecAvg	10.2	0.7	1.0	1.3	1.2	1.0	0.7	0.8	0.6	0.6	1.0	0.6	0.7		
	PrecMax	18.5	2.7	4.8	5.4	8.3	4.5	3.0	3.3	3.2	2.8	5.0	2.6	2.8		
	PrecMin	4.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	3.5	0.7	1.1	1.5	1.5	1.0	0.7	0.8	0.7	0.7	1.0	0.6	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.8	100.5	94.7	85.0	75.6	65.9	68.9	74.1	81.1	88.7	95.7	98.2		
		MCWB	64.6	67.3	63.7	61.3	54.8	51.1	53.1	54.0	53.8	58.8	63.1	64.0		
	2%	DB	94.4	94.8	88.9	80.0	68.4	61.3	63.6	67.5	74.1	82.4	88.9	92.7		
		MCWB	63.9	64.9	63.7	59.1	54.0	49.0	49.5	51.6	52.5	56.8	60.2	62.9		
	5%	DB	90.8	90.6	84.4	75.8	64.5	58.9	60.4	63.8	69.4	77.9	84.4	88.1		
		MCWB	62.7	64.1	61.8	57.2	52.6	48.8	47.9	49.2	51.3	55.0	59.7	61.1		
	10%	DB	86.2	85.9	80.5	70.9	61.3	56.2	57.5	60.7	65.6	73.4	79.9	84.1		
		MCWB	60.9	63.3	60.9	55.5	51.2	47.6	47.0	48.0	49.8	53.6	57.7	60.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.6	72.5	69.9	65.7	58.9	54.3	56.4	56.3	57.5	63.7	67.3	69.6		
		MCDB	85.3	85.5	85.3	77.9	67.3	60.8	62.3	65.8	70.2	75.8	83.5	83.0		
	2%	WB	67.3	69.9	67.0	62.1	56.3	52.1	52.5	53.4	54.9	59.8	64.0	67.5		
		MCDB	82.1	84.7	79.6	73.8	63.8	57.2	60.3	65.1	67.6	73.9	81.0	80.9		
	5%	WB	65.7	67.9	65.1	59.2	54.7	50.3	49.9	51.1	53.0	57.6	61.8	65.3		
		MCDB	81.7	81.7	77.9	68.6	61.5	55.5	57.4	60.4	65.9	71.7	77.7	78.9		
	10%	WB	64.4	66.0	63.2	57.5	53.0	48.7	47.7	49.4	51.3	55.8	59.8	63.4		
		MCDB	79.2	78.8	75.5	67.5	59.3	54.8	55.8	57.5	62.6	69.5	74.5	77.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	22.0	21.7	20.8	21.2	19.0	17.5	19.5	20.3	21.0	21.7	22.5	22.2		
		MCDBR	31.6	31.3	29.0	28.3	23.7	20.3	22.8	24.3	27.6	30.4	31.9	32.6		
		MCWBR	11.0	11.9	13.0	12.9	12.9	11.5	13.1	13.1	13.3	13.2	11.9	12.2		
	5% WB	MCDBR	23.2	24.2	22.5	21.6	19.6	16.3	19.1	20.9	23.5	24.0	23.9	21.6		
		MCWBR	11.0	11.0	12.3	12.2	12.5	10.5	12.5	12.8	12.8	13.0	11.3	10.8		
(40) Clear-Sky Solar Irradiance	taub		0.395	0.380	0.363	0.351	0.331	0.312	0.316	0.333	0.363	0.363	0.369	0.392		
	taud		2.339	2.394	2.442	2.448	2.480	2.537	2.511	2.465	2.367	2.390	2.389	2.342		
	Ebn at Noon		296	292	283	263	247	245	251	266	278	294	302	299		
	Edh at Noon		42	37	33	28	23	20	22	27	35	37	39	42		
(44) All-Sky Solar Radiation	RadAvg		2554	2173	1672	1147	702	557	636	900	1354	1853	2331	2590		
	RadStd		104	91	76	71	62	46	56	72	103	99	99	117		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	+0.50	N/A	N/A	+1.08	+1.19	+1.01	N/A	N/A	N/A	N/A

Nomenclature: See separate page