

VIEDMA, Argentina

WMO: 877910

Lat: 40.8633S

Lon: 63.0069W

Elev: 7

StdP: 101.24

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-2.7	-1.3	-8.1	1.9	9.9	-6.3	2.2	8.8	16.0	11.6	13.9	10.1	2.6	320	0.636

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.5	34.4	19.1	32.4	18.3	30.6	17.8	21.5	28.8	20.5	27.8	19.6	26.7	7.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.3	14.1	23.9	18.2	13.1	22.9	17.2	12.3	22.3	62.5	28.9	59.1	27.4	56.0	26.8	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	12.5	11.2	-5.2	38.3	1.3	1.2	-6.2	39.2	-6.9	39.9	-7.7	40.6	-8.6	41.5
			-5.8	23.6	1.4	1.6	-6.7	24.7	-7.5	25.6	-8.3	26.5	-9.3	27.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	21.7	20.8	18.7	14.4	10.7	8.1	7.5	9.0	10.8	14.1	17.2	20.0
	DBStd	6.13	3.53	3.99	4.00	3.59	3.24	2.86	3.21	3.36	3.60	3.83	4.00	3.81
	HDD10.0	294	0	0	0	3	30	71	91	59	31	7	1	0
	HDD18.3	1828	9	19	46	128	237	307	335	288	227	141	67	26
	CDD10.0	1902	364	303	271	135	52	14	14	30	56	135	218	310
	CDD18.3	394	115	89	58	9	1	0	0	0	2	9	33	77
	CDH23.3	4360	1258	916	542	89	5	0	0	1	26	148	466	909
	CDH26.7	1704	538	384	191	16	1	0	0	0	3	40	172	360
Wind	WSAvg	5.2	6.1	5.7	5.2	4.7	4.4	4.8	4.9	4.9	5.2	5.4	5.6	5.9
Precipitation	PrecAvg	363	23	43	47	35	32	24	28	25	26	30	24	26
	PrecMax	606	115	187	177	105	96	166	119	116	102	80	83	92
	PrecMin	196	0	0	1	0	0	0	0	0	0	1	0	0
	PrecStd	103	24	39	43	26	21	26	26	28	24	23	19	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.2	36.4	34.0	28.8	23.5	18.7	19.5	22.4	26.7	30.9	34.7	36.0
		MCWB	19.5	19.3	19.6	17.4	15.5	11.1	12.0	12.7	14.7	16.9	18.3	18.9
	2%	DB	34.2	33.4	31.1	25.7	20.7	16.4	17.0	19.4	22.9	27.0	30.9	33.0
		MCWB	18.9	19.3	19.1	15.8	14.1	10.6	10.8	11.5	13.0	14.6	16.7	18.2
	5%	DB	31.9	31.1	28.7	23.6	18.4	14.7	15.1	17.4	20.3	24.3	28.2	30.8
		MCWB	18.2	18.4	18.0	14.8	12.7	9.9	9.6	10.3	11.4	13.5	15.5	17.3
	10%	DB	29.7	28.9	26.2	21.3	16.6	13.2	13.5	15.5	18.2	21.9	25.8	28.4
		MCWB	17.4	18.0	17.0	13.9	11.8	9.5	8.8	9.4	10.7	12.7	14.5	16.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.7	23.0	22.2	19.5	17.3	13.2	14.0	14.6	16.4	18.2	20.2	21.4
		MCDB	30.9	30.2	29.4	24.5	21.3	15.8	16.9	19.6	23.3	25.5	30.0	31.2
	2%	WB	21.1	21.6	20.5	17.7	15.2	12.1	11.9	12.5	14.2	16.1	18.2	19.8
		MCDB	28.7	27.9	27.7	23.2	18.4	14.1	15.0	17.4	20.0	23.1	26.6	28.8
	5%	WB	20.0	20.6	19.5	16.1	13.8	11.0	10.6	11.2	12.6	14.8	16.9	18.7
		MCDB	27.4	27.0	25.7	21.5	17.4	13.6	14.1	15.7	18.4	21.9	25.1	26.9
	10%	WB	18.9	19.5	18.3	14.8	12.5	10.0	9.3	10.1	11.4	13.6	15.6	17.6
		MCDB	26.5	26.0	23.9	19.8	15.9	12.8	12.9	14.4	16.9	20.2	23.4	26.1
Mean Daily Temperature Range	5% DB	MDBR	13.5	12.8	12.3	12.0	10.4	10.0	10.7	11.3	12.1	12.7	13.5	13.7
		MCDBR	17.5	16.4	15.3	14.9	12.8	11.9	12.6	13.7	15.8	16.8	17.4	17.6
		MCWBR	6.0	6.0	6.3	7.3	7.3	7.3	7.6	7.6	7.8	7.6	6.6	6.3
	5% WB	MCDBR	13.7	12.8	13.0	12.4	10.5	9.4	10.6	11.7	13.3	14.2	14.7	14.8
	MCWBR	6.1	5.7	6.4	7.1	6.6	6.5	7.2	7.0	7.4	7.4	6.6	6.3	
Clear-Sky Solar Irradiance	taub	0.388	0.376	0.358	0.342	0.327	0.314	0.320	0.342	0.371	0.360	0.367	0.380	
	taud	2.354	2.400	2.455	2.470	2.479	2.505	2.474	2.407	2.316	2.384	2.383	2.367	
	Ebn at Noon	939	924	897	841	784	764	783	825	866	930	954	953	
	Edh at Noon	129	118	102	86	73	65	72	90	115	118	125	129	
All-Sky Solar Radiation	RadAvg	7.85	6.62	5.11	3.50	2.18	1.74	1.95	2.78	4.16	5.70	7.18	8.01	
	RadStd	0.32	0.28	0.24	0.22	0.16	0.12	0.16	0.27	0.30	0.35	0.34	0.43	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.28	N/A	N/A	+0.60	+0.66	+0.56	N/A	N/A	N/A	N/A
Regional (1 neighbor)	+0.28	N/A	N/A	+0.60	+0.66	+0.56	N/A	N/A	N/A	N/A

Nomenclature: See separate page