

TRELEW, Argentina

WMO: 878280

Lat: 43.2089S

Lon: 65.2822W

Elev: 141

StdP: 14.62

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.6	28.4	12.9	10.7	54.6	15.8	12.3	51.1	39.1	53.3	32.9	53.1	5.4	320	0.676

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.3	93.2	64.1	89.4	62.6	86.1	61.4	67.3	84.7	65.3	81.9	63.6	79.8	19.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.2	84.0	70.4	59.8	77.1	68.9	57.5	71.0	67.9	31.9	83.9	30.3	82.1	29.0	79.7	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.5	31.2	28.1	DB	19.2	100.5	3.6	2.3	16.6	102.1	14.5	103.4	12.5	104.7	9.9	106.4	(4)
(5)			WB	18.3	71.5	3.6	2.2	15.7	73.1	13.6	74.4	11.6	75.7	9.0	77.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.1	70.2	68.2	64.4	57.5	50.3	44.7	44.0	47.4	51.4	57.3	62.6	67.4	(6)	
	DBStd	11.11	6.09	6.98	7.01	6.64	6.33	6.32	6.42	6.12	6.29	6.51	6.51	6.05	(7)	
	HDD50	671	0	0	1	11	76	180	206	125	56	14	2	0	(8)	
	HDD65	3488	21	42	97	241	458	610	650	547	410	249	119	44	(9)	
	CDD50	3242	625	509	448	235	84	20	21	44	97	241	380	538	(10)	
	CDD65	586	181	131	80	15	1	0	0	0	1	11	48	118	(11)	
	CDH74	6852	2024	1507	867	170	9	0	0	0	38	196	654	1387	(12)	
	CDH80	2575	849	644	306	34	0	0	0	0	7	40	200	495	(13)	
(14) Wind	WSAvg	13.0	15.6	14.7	13.1	11.6	10.2	10.2	11.1	12.1	12.8	14.3	15.3	15.1	(14)	
(15) Precipitation	PrecAvg	7.2	0.4	0.8	0.8	0.6	0.8	0.7	0.7	0.5	0.5	0.7	0.6	0.6	(15)	
	PrecMax	12.7	2.3	5.6	3.3	5.4	2.8	4.2	2.5	2.1	1.9	3.9	2.0	4.0	(16)	
	PrecMin	3.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	2.3	0.4	0.9	0.8	0.9	0.7	0.7	0.6	0.5	0.5	0.8	0.5	0.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.2	97.8	93.9	84.4	75.1	66.1	66.4	71.2	79.3	84.8	91.7	94.5	(19)	
		MCWB	65.1	66.3	65.1	61.4	56.2	50.8	51.6	51.9	54.5	58.7	61.9	63.3	(20)	
	2%	DB	92.7	92.4	87.3	78.7	69.4	61.6	62.1	66.3	72.2	79.0	85.3	89.3	(21)	
		MCWB	63.8	64.8	62.3	57.8	53.6	48.4	48.8	50.5	52.2	56.1	59.6	62.1	(22)	
	5%	DB	88.6	87.9	82.8	74.5	65.6	58.7	58.8	62.7	68.0	75.0	80.9	85.5	(23)	
		MCWB	62.3	62.8	60.7	56.2	51.7	47.3	47.1	48.5	50.2	54.6	57.8	60.3	(24)	
	10%	DB	84.7	83.5	78.7	70.2	62.3	55.6	55.6	59.2	64.3	71.1	77.1	82.0	(25)	
		MCWB	60.8	61.4	59.2	54.1	50.2	45.8	45.5	48.7	52.9	55.9	58.9	58.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.2	70.2	69.0	63.0	58.5	53.2	53.1	54.8	56.6	61.9	64.6	67.3	(27)	
		MCDB	88.2	87.7	86.5	79.0	69.9	61.4	62.2	66.3	72.5	79.4	84.4	84.9	(28)	
	2%	WB	66.6	67.4	65.4	60.0	55.9	50.8	50.6	51.9	53.6	58.6	61.8	64.3	(29)	
		MCDB	85.4	84.0	78.6	71.8	64.9	57.4	59.5	62.6	67.8	74.5	79.7	82.8	(30)	
	5%	WB	64.5	65.3	63.0	58.2	53.8	48.9	48.3	49.9	51.6	56.0	59.3	62.2	(31)	
		MCDB	81.6	81.6	76.9	69.4	62.3	55.7	56.9	59.7	64.6	70.6	77.2	81.0	(32)	
	10%	WB	62.5	63.3	61.0	56.3	51.8	47.1	46.3	47.9	49.9	54.0	57.4	60.2	(33)	
		MCDB	79.6	78.7	74.9	67.3	59.5	54.0	53.9	57.1	61.4	68.1	74.3	78.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	24.3	23.9	22.9	22.1	20.0	18.5	19.1	20.4	21.3	22.7	23.8	24.1	(35)	
		MCDBR	31.7	32.2	29.9	27.4	24.1	21.2	22.2	24.9	27.4	29.4	30.3	30.8	(36)	
	5% WB	MCWBR	11.9	11.7	12.5	13.1	13.5	12.4	12.7	13.7	13.5	13.4	12.7	12.0	(37)	
		MCWBR	27.6	27.6	25.7	23.3	20.7	18.7	20.3	21.8	24.0	26.2	27.7	28.1	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.369	0.366	0.344	0.330	0.314	0.297	0.301	0.317	0.340	0.342	0.352	0.367	(40)	
		taud	2.413	2.430	2.485	2.510	2.532	2.564	2.550	2.512	2.431	2.445	2.428	2.408	(41)	
	Ebn at Noon	Ebn at Noon	303	294	286	267	248	243	251	268	283	299	306	305	(42)	
		Edh at Noon	38	36	31	25	21	18	20	25	32	35	37	39	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2470	2094	1588	1060	627	482	556	827	1289	1796	2252	2498	(44)	
	RadStd	RadStd	78	93	71	58	50	33	42	60	93	80	83	134	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	+1.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+61
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page