

SAN JULIAN, Argentina

WMO: 879090

Lat: 49.3083S

Lon: 67.8031W

Elev: 203

StdP: 14.59

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.5	27.1	14.4	11.5	49.6	17.9	13.6	43.0	47.8	43.0	45.9	39.8	11.8	270	0.899

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.8	82.2	60.5	78.4	58.5	75.1	56.9	62.1	78.9	60.1	75.5	58.3	72.2	25.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.8	64.3	65.2	53.1	60.4	63.9	51.4	56.7	62.8	28.0	79.5	26.6	75.9	25.4	72.4	71.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
47.3	41.9	34.6	19.6	90.9	3.6	4.1	17.0	93.9	14.9	96.3	12.9	98.6	10.3	101.6		
			18.8	65.9	3.5	2.0	16.3	67.4	14.3	68.6	12.3	69.7	9.8	71.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.9	60.2	59.6	56.3	50.5	44.4	38.9	38.4	41.4	46.0	50.4	54.9	58.4	(6)
	DBStd	9.86	5.88	7.14	6.53	6.15	6.22	5.91	5.89	5.33	6.13	6.31	6.28	6.23	(7)
	HDD50	1501	2	5	14	66	195	336	363	272	150	72	20	6	(8)
	HDD65	5600	172	182	281	435	639	783	825	732	570	453	308	220	(9)
	CDD50	1462	317	273	209	81	21	3	3	5	30	85	168	267	(10)
	CDD65	86	22	30	11	1	0	0	0	0	1	5	16	16	(11)
	CDH74	977	271	322	108	7	0	0	0	0	1	14	74	180	(12)
	CDH80	231	63	105	19	0	0	0	0	0	0	1	11	32	(13)
	WSAvg	17.1	18.9	17.8	16.2	16.6	15.3	15.5	15.6	16.4	17.0	17.6	19.3	19.3	(14)
(15) Precipitation	PrecAvg	9.4	0.7	0.9	0.9	0.7	1.1	1.1	1.0	0.7	0.7	0.7	0.6	0.9	(15)
	PrecMax	19.8	1.7	3.0	4.2	2.6	2.6	7.2	4.1	2.4	2.4	2.6	1.9	4.4	(16)
	PrecMin	4.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	3.0	0.4	0.7	1.1	0.6	0.7	1.2	1.1	0.7	0.6	0.5	0.5	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.8	90.6	82.4	74.3	65.7	58.0	58.4	61.0	69.4	75.8	81.4	84.3	(19)
		MCWB	62.3	63.5	61.7	57.2	53.3	47.2	47.6	49.1	52.4	54.9	58.9	60.4	(20)
	2%	DB	80.6	82.5	76.9	69.2	60.8	53.6	52.9	56.9	63.4	70.1	75.5	78.8	(21)
		MCWB	59.6	60.8	57.8	54.8	50.1	45.2	44.6	46.3	49.1	52.5	56.3	57.7	(22)
	5%	DB	76.4	77.4	72.0	65.4	57.7	50.3	50.2	53.6	60.2	66.2	71.6	74.8	(23)
		MCWB	57.7	59.0	55.7	52.5	48.4	43.1	42.8	44.2	47.7	50.6	53.8	55.7	(24)
	10%	DB	72.6	72.8	68.0	61.6	54.5	47.6	47.4	50.8	57.1	62.5	67.4	71.1	(25)
		MCWB	55.8	57.3	53.7	50.2	46.2	41.6	40.9	42.7	46.2	48.8	51.4	54.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.0	65.6	62.6	58.8	54.3	48.9	48.6	50.9	53.6	56.9	60.0	63.0	(27)
		MCDB	81.6	84.1	80.6	71.3	63.3	55.6	56.7	58.6	65.7	72.7	78.5	81.6	(28)
	2%	WB	61.3	62.3	59.4	55.8	51.4	46.0	45.4	47.3	50.4	53.7	57.1	59.4	(29)
		MCDB	77.4	79.3	73.1	67.4	59.1	51.9	52.1	55.0	61.4	67.2	73.2	75.2	(30)
	5%	WB	59.0	60.2	57.3	53.4	49.2	44.0	43.3	45.3	48.5	51.6	54.9	57.2	(31)
		MCDB	74.0	75.6	69.3	63.2	56.0	49.2	48.8	52.3	58.7	63.7	69.0	72.0	(32)
	10%	WB	57.1	58.1	55.2	51.3	47.2	42.2	41.5	43.2	46.6	49.6	52.8	55.2	(33)
		MCDB	70.3	70.9	65.7	60.0	53.1	46.8	46.3	49.3	55.7	60.9	65.4	68.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	19.8	19.3	18.5	17.0	13.9	11.0	11.4	13.9	16.3	18.8	19.3	19.4	(35)
		MCDBR	26.7	27.7	24.9	21.4	17.8	13.9	14.5	17.8	21.1	24.4	25.8	26.4	(36)
		MCWBR	12.7	12.6	12.3	12.2	11.3	9.4	9.5	10.9	11.8	12.7	12.8	12.3	(37)
	5% WB	MCDBR	24.8	25.6	21.6	20.1	16.3	12.7	13.8	16.8	19.9	22.5	24.5	24.6	(38)
		MCWBR	13.0	12.9	12.1	12.6	11.2	9.4	9.8	11.3	12.0	13.0	13.2	12.5	(39)
(40) Clear-Sky Solar Irradiance	taub		0.326	0.326	0.313	0.306	0.288	0.278	0.277	0.293	0.305	0.312	0.316	0.326	(40)
	taud		2.537	2.543	2.571	2.569	2.567	2.527	2.559	2.560	2.540	2.528	2.529	2.523	(41)
	Ebn at Noon		313	303	290	263	238	223	239	264	288	304	314	316	(42)
	Edh at Noon		33	30	26	22	17	15	16	21	27	31	33	34	(43)
(44) All-Sky Solar Radiation	RadAvg		2176	1815	1271	785	441	301	359	641	1067	1631	2043	2233	(44)
	RadStd		111	74	80	34	22	23	26	42	65	47	105	144	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page