

RIO GALLEGOS, Argentina

WMO: 879250

Lat: 51.6117S

Lon: 69.3081W

Elev: 19

StdP: 101.10

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-7.0	-5.0	-10.2	1.6	1.9	-8.8	1.8	4.3	16.9	4.1	14.9	4.3	2.5	270	0.847

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.1	24.2	13.7	22.2	12.6	20.8	11.8	14.7	22.1	13.6	20.5	12.6	18.8	8.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.2	8.3	15.6	10.2	7.8	14.9	9.2	7.3	14.1	41.3	22.0	38.4	20.6	35.7	18.9	19.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.2	15.7	14.0	-10.7	29.1	3.2	1.9	-13.0	30.5	-14.8	31.6	-16.6	32.7	-18.9	34.1		
			-11.1	17.2	3.2	1.1	-13.4	18.0	-15.3	18.6	-17.0	19.3	-19.3	20.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	13.5	13.1	11.3	8.1	4.6	1.7	1.8	3.4	6.0	8.5	10.6	12.5
	DBStd	5.09	2.80	3.29	3.16	2.93	2.92	3.20	2.98	2.60	2.67	2.71	2.87	2.78
	HDD10.0	1199	3	7	22	72	169	248	256	204	123	63	26	8
	HDD18.3	3818	151	148	219	308	427	498	513	463	370	306	232	183
	CDD10.0	430	112	94	62	14	1	0	0	0	3	16	44	84
	CDD18.3	7	2	3	1	0	0	0	0	0	0	0	0	1
	CDH23.3	113	31	51	10	1	0	0	0	0	0	0	4	16
	CDH26.7	17	3	10	2	0	0	0	0	0	0	0	1	2
Wind	WSAvg	6.3	7.5	6.9	6.4	6.0	5.2	5.2	5.3	5.7	6.0	6.9	7.5	7.6
Precipitation	PrecAvg	257	29	25	22	23	22	21	19	15	13	16	21	28
	PrecMax	416	91	72	75	95	80	93	63	41	38	56	98	78
	PrecMin	127	4	1	1	2	0	0	1	1	0	0	0	2
	PrecStd	66	18	16	18	18	15	19	13	11	9	15	18	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.3	28.1	24.4	19.2	14.7	12.0	11.2	13.0	17.3	20.9	23.5	25.2
		MCWB	14.4	15.9	14.3	11.4	9.2	6.9	6.7	7.0	9.0	10.9	12.5	14.0
	2%	DB	23.8	24.8	21.2	17.0	12.2	9.2	8.7	10.7	15.0	18.2	20.9	22.2
		MCWB	13.2	14.6	12.4	10.2	7.8	5.9	5.1	5.7	7.8	9.4	11.3	12.2
	5%	DB	21.8	21.9	19.1	15.1	10.8	7.3	7.1	9.1	13.0	16.2	18.8	20.2
		MCWB	12.2	13.0	11.2	9.3	7.0	4.8	4.2	4.9	6.7	8.4	10.1	11.2
	10%	DB	19.8	19.6	17.1	13.2	9.2	6.1	5.9	7.8	11.1	14.8	16.9	18.4
		MCWB	11.1	11.7	10.3	8.3	6.2	4.1	3.4	4.2	5.9	7.6	9.2	10.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	16.8	15.0	12.7	10.1	7.7	7.0	7.7	9.7	11.5	13.3	15.0
		MCDB	24.3	26.1	22.4	17.8	13.3	10.6	9.7	11.7	16.1	19.1	21.3	22.8
	2%	WB	14.1	15.1	13.2	10.9	8.7	6.3	5.5	6.2	8.3	10.2	11.9	13.4
		MCDB	21.8	22.7	19.2	15.3	11.0	8.2	7.7	9.4	13.5	17.0	19.1	20.3
	5%	WB	12.9	13.8	12.2	10.0	7.6	5.2	4.6	5.3	7.3	9.1	10.8	12.2
		MCDB	19.6	20.5	17.6	13.8	9.6	6.9	6.5	8.1	11.8	15.3	17.2	18.5
	10%	WB	11.9	12.5	11.1	9.1	6.6	4.3	3.7	4.5	6.3	8.1	9.8	11.1
		MCDB	18.1	18.1	16.0	12.7	8.7	6.0	5.5	6.9	10.1	13.5	15.6	17.3
Mean Daily Temperature Range	5% DB	MDBR	11.1	11.2	10.5	9.5	7.7	6.4	6.5	7.4	9.5	11.4	11.3	11.0
		MCDBR	14.0	14.7	13.1	11.7	9.5	7.0	7.2	9.1	12.1	14.1	14.2	13.7
		MCWBR	6.6	7.2	6.6	7.0	6.3	5.1	5.1	5.7	6.7	7.5	7.0	6.6
	5% WB	MCDBR	12.6	14.1	12.0	10.9	8.2	6.4	6.8	8.2	11.2	13.4	12.8	12.5
		MCWBR	6.7	7.3	6.6	7.0	6.2	5.1	5.3	5.7	6.7	7.6	6.9	6.9
Clear-Sky Solar Irradiance	taub	0.321	0.317	0.307	0.299	0.280	0.274	0.280	0.295	0.305	0.313	0.313	0.317	
	taud	2.544	2.561	2.586	2.578	2.553	2.476	2.515	2.543	2.528	2.517	2.537	2.544	
	Ebn at Noon	988	956	909	818	727	660	712	808	893	950	990	1000	
	Edh at Noon	101	93	79	64	49	44	49	64	82	96	102	103	
All-Sky Solar Radiation	RadAvg	5.94	4.99	3.47	2.08	1.13	0.77	0.96	1.74	3.04	4.61	5.69	6.17	
	RadStd	0.37	0.25	0.21	0.10	0.08	0.07	0.06	0.10	0.19	0.15	0.32	0.40	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	-88	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	+0.75	N/A	N/A	N/A	-0.40	-84	N/A	N/A	N/A

Nomenclature: See separate page