

USHUAIA, Argentina

WMO: 879380

Lat: 54.8400S

Lon: 68.3033W

Elev: 187

StdP: 14.60

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.5	26.8	18.4	14.0	34.1	20.9	15.8	35.3	44.8	37.7	40.6	37.7	8.6	230	0.853

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.7	64.7	53.2	61.9	51.3	59.2	49.7	54.8	62.3	52.7	59.7	51.0	57.3	12.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
50.8	55.3	57.0	48.6	51.1	54.5	47.0	48.0	52.9	23.3	62.5	22.0	59.8	21.0	57.5	62.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.0	35.9	32.0	22.6	72.9	2.7	3.8	20.6	75.6	19.0	77.9	17.4	80.0	15.4	82.8		
(5)			21.3	59.1	2.8	1.9	19.3	60.4	17.6	61.5	16.0	62.6	14.0	63.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.9	49.1	49.4	47.3	43.6	39.8	36.1	35.9	37.4	40.1	43.4	45.4	47.7	(6)
(7)		DBStd	6.67	4.42	4.89	4.89	4.81	4.47	4.64	4.75	4.16	4.75	4.80	4.98	4.42	(7)
(8)		HDD50	2773	71	64	112	201	317	417	437	392	300	211	152	99	(8)
(9)		HDD65	8073	494	437	549	643	781	867	902	857	748	670	588	537	(9)
(10)		CDD50	173	43	46	28	7	1	0	0	0	1	6	14	27	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	3	0	3	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	13.1	15.3	14.5	13.1	12.2	10.7	10.8	11.3	11.7	12.6	14.3	15.3	15.5	(14)
(15)	Precipitation	PrecAvg	19.4	1.7	1.7	1.8	2.0	1.8	2.0	1.5	1.6	1.3	1.3	1.4	1.7	(15)
(16)		PrecMax	30.2	4.8	5.4	6.8	4.6	6.7	7.1	4.9	5.7	3.7	3.2	3.0	4.3	(16)
(17)		PrecMin	8.5	0.5	0.2	0.4	0.4	0.1	0.2	0.2	0.0	0.0	0.3	0.0	0.2	(17)
(18)		PrecStd	5.4	0.8	1.2	1.1	1.1	1.1	1.4	0.8	1.1	0.7	0.7	0.7	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.2	71.2	66.5	62.2	55.5	50.9	51.5	51.8	57.4	61.1	64.9	66.6	(19)
(20)		0.4%	MCWB	56.5	57.0	55.2	51.2	46.3	43.7	41.3	42.7	46.1	48.4	52.7	53.7	(20)
(21)		2%	DB	62.9	64.2	61.1	56.3	51.6	48.0	47.0	48.2	53.3	57.0	59.4	61.6	(21)
(22)		2%	MCWB	51.8	53.5	51.7	48.0	44.6	42.3	40.2	40.9	44.3	46.4	49.1	50.3	(22)
(23)		5%	DB	59.9	60.5	57.6	53.2	48.5	44.9	44.6	45.9	50.1	53.8	56.7	58.4	(23)
(24)		5%	MCWB	50.3	51.7	49.5	46.4	43.0	40.2	39.2	39.7	42.2	44.5	47.2	48.6	(24)
(25)		10%	DB	57.1	57.4	55.1	50.7	46.3	42.8	42.5	43.4	47.5	51.5	53.8	55.3	(25)
(26)		10%	MCWB	49.0	49.8	48.3	45.3	41.9	38.9	38.1	38.4	41.0	43.5	45.7	47.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.8	58.4	56.6	52.1	48.3	45.5	43.5	43.9	47.8	49.9	53.3	55.1	(27)
(28)		0.4%	MCDWB	66.7	67.1	64.2	59.1	54.2	50.2	49.1	49.8	55.5	58.4	62.1	64.4	(28)
(29)		2%	WB	53.5	55.1	52.8	49.2	45.7	42.7	41.2	41.8	44.9	47.3	50.1	51.7	(29)
(30)		2%	MCDWB	61.2	61.5	59.3	54.7	49.6	46.4	45.2	46.1	51.2	54.7	57.5	59.7	(30)
(31)		5%	WB	51.4	52.7	50.6	47.4	43.8	40.8	39.6	40.4	43.1	45.6	48.2	49.5	(31)
(32)		5%	MCDWB	58.1	58.8	56.1	52.0	47.1	43.6	43.1	44.1	48.0	52.1	55.2	56.4	(32)
(33)		10%	WB	49.6	50.7	49.1	45.7	42.2	39.2	38.5	39.2	41.5	44.0	46.6	47.8	(33)
(34)		10%	MCDWB	55.9	56.1	54.1	49.7	45.4	42.1	41.5	42.7	46.0	49.9	52.6	54.2	(34)
(35)	Mean Daily Temperature Range		MDBR	11.8	11.7	11.1	9.5	7.9	7.0	7.4	8.6	10.2	11.7	12.1	12.1	(35)
(36)		5% DB	MCDBR	17.2	17.7	15.7	13.8	11.4	10.2	10.4	11.6	14.4	15.7	17.0	17.2	(36)
(37)			MCWBR	9.4	10.2	9.5	8.5	7.3	6.5	6.4	7.1	8.2	8.8	9.3	9.6	(37)
(38)			5% WB	MCDWB	16.4	16.0	14.5	12.2	9.8	8.9	8.6	10.1	12.7	14.6	15.7	15.9
(39)		MCWBR		9.7	10.1	9.6	8.4	7.2	6.3	6.3	7.2	8.3	8.9	9.2	9.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.321	0.312	0.307	0.284	0.264	0.278	0.296	0.309	0.315	0.317	0.323	(40)	
(41)		taud	2.530	2.541	2.560	2.519	2.400	2.235	2.244	2.383	2.490	2.502	2.513	2.514	(41)	
(42)		Ebn at Noon	310	298	280	244	203	175	194	240	276	297	310	313	(42)	
(43)		Edh at Noon	32	29	25	20	15	14	17	22	26	30	32	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1531	1245	809	439	226	134	171	350	697	1127	1458	1623	(44)	
(45)		RadStd	74	82	61	32	23	13	16	22	49	69	96	101	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page