

PEBBLE ISLAND, Falkland Islands (Malvinas)

WMO: 888780

Lat: 51.317S

Lon: 59.600W

Elev: 52

StdP: 14.67

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 29.1	(c) 30.9	(d) 23.3	(e) 17.6	(f) 33.0	(g) 25.4	(h) 19.4	(i) 33.5	(j) 42.6	(k) 35.9	(l) 38.4	(m) 36.7	(n) 14.6	(o) 200	(p) 0.958

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.6	60.3	54.2	58.5	53.3	56.9	52.4	55.7	58.5	54.5	57.0	53.3	55.8	15.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.3	62.8	56.7	53.0	60.0	55.6	51.9	57.5	54.5	23.8	59.0	23.0	57.0	22.3	56.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 40.1	(b) 35.2	(c) 32.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 40.1	(b) 35.2	(c) 32.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.0	51.2	50.7	48.6	44.8	41.5	38.9	37.8	37.9	39.5	42.7	45.8	49.3	
	DBStd	5.91	3.00	3.87	3.77	3.80	3.72	3.34	3.17	3.13	3.22	3.21	3.07	3.66	
	HDD50	2361	23	35	69	159	265	333	377	376	314	226	127	57	
	HDD65	7655	429	399	508	607	729	783	842	841	764	691	575	487	
	CDD50	180	59	55	26	3	0	0	0	0	0	0	2	35	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	16.9	19.0	17.7	17.0	17.5	15.6	15.6	16.0	16.1	15.2	16.4	18.9	17.7	
Precipitation	PrecAvg	31.5	2.7	2.5	3.1	3.0	2.9	2.7	2.6	2.6	2.3	2.4	2.2	2.5	
	PrecMax	42.3	3.8	3.7	4.8	5.0	4.5	5.4	5.4	4.7	5.5	6.4	3.7	4.8	
	PrecMin	25.4	1.7	1.5	1.7	1.3	1.5	1.2	1.3	1.5	1.1	1.3	1.3	1.3	
	PrecStd	3.9	0.6	0.6	0.7	0.9	0.7	0.9	0.9	0.7	0.9	0.9	0.5	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.5	63.6	60.3	55.5	50.7	47.7	45.8	45.6	48.9	53.4	56.6	61.8	
		MCWB	55.4	57.1	54.4	52.0	48.2	45.7	44.1	42.6	44.4	46.6	50.1	53.6	
	2%	DB	59.8	60.3	57.1	53.1	48.8	45.9	44.4	44.0	47.1	50.7	53.9	59.2	
		MCWB	54.1	54.9	53.2	50.1	47.0	44.5	43.1	41.5	43.6	45.6	48.6	52.6	
	5%	DB	57.9	58.3	55.2	51.5	47.6	44.9	43.5	43.1	45.5	49.0	52.1	57.1	
		MCWB	52.8	53.9	51.9	49.0	46.2	43.6	42.2	40.8	42.6	44.8	47.5	51.4	
	10%	DB	56.3	56.5	53.7	50.2	46.7	43.8	42.5	42.2	44.0	47.7	50.7	55.2	
		MCWB	51.8	53.0	51.0	48.2	45.3	42.6	41.2	40.2	41.6	43.9	46.5	50.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.8	58.3	56.3	52.8	49.1	46.5	44.8	43.2	45.5	47.6	50.5	55.0
			MCDB	60.7	61.7	58.7	54.5	50.1	46.9	45.1	44.3	47.3	51.9	54.0	59.2
2%		WB	55.1	56.3	54.0	50.9	47.6	44.9	43.6	42.2	44.0	46.3	49.2	53.3	
		MCDB	58.3	59.0	55.8	52.3	48.3	45.4	44.1	43.4	46.3	49.8	52.3	57.2	
5%		WB	53.9	54.9	52.9	49.6	46.7	43.8	42.6	41.3	43.0	45.2	48.1	52.0	
		MCDB	56.6	57.2	54.5	50.8	47.5	44.5	43.3	42.5	45.1	48.3	51.0	55.5	
10%		WB	52.6	53.6	51.6	48.5	45.6	42.8	41.5	40.5	42.0	44.3	47.0	50.8	
		MCDB	55.4	55.9	53.2	49.9	46.5	43.6	42.2	41.8	43.8	47.0	49.7	54.0	
Mean Daily Temperature Range		5% DB	MDBR	8.6	8.3	7.8	6.8	5.8	5.2	5.3	5.9	6.8	8.4	8.4	9.3
			MCDBR	11.3	10.7	9.7	8.5	6.4	5.8	6.2	6.1	8.5	10.2	10.3	12.0
	MCWBR		7.6	7.6	7.1	7.1	5.8	5.4	5.8	5.3	6.1	7.0	7.0	7.8	
	5% WB	MCDBR	10.5	9.9	9.2	7.9	6.0	5.5	6.0	5.7	8.3	10.0	9.4	11.1	
		MCWBR	7.8	7.8	7.6	7.1	5.7	5.3	5.7	5.3	6.5	7.2	6.9	8.1	
Clear-Sky Solar Irradiance	taub	0.342	0.336	0.329	0.323	0.315	0.301	0.306	0.318	0.326	0.325	0.333	0.342		
	taud	2.495	2.518	2.525	2.483	2.352	2.317	2.364	2.435	2.465	2.488	2.484	2.476		
	Ebn at Noon	306	297	280	249	209	191	209	245	276	298	307	309		
	Edh at Noon	34	31	27	23	19	16	18	23	28	31	34	35		
All-Sky Solar Radiation	RadAvg	1883	1496	1048	587	309	201	244	470	869	1391	1844	2072		
	RadStd	96	109	89	42	18	14	19	40	68	73	128	175		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	+1.06	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page