

PEBBLE ISLAND, Falkland Islands (Malvinas)

WMO: 888780

Lat: 51.317S

Lon: 59.600W

Elev: 16

StdP: 101.13

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.6	-0.6	-4.8	2.5	0.6	-3.7	2.8	0.8	19.1	2.1	17.2	2.6	6.5	200	0.958

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.8	15.7	12.3	14.7	11.8	13.8	11.3	13.2	14.7	12.5	13.9	11.8	13.2	7.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.4	9.0	13.7	11.7	8.6	13.1	11.1	8.2	12.5	37.4	15.0	35.5	13.9	34.0	13.3	15.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.9	15.7	14.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	10.7	10.4	9.2	7.1	5.3	3.8	3.2	3.3	4.2	6.0	7.7	9.6
	DBStd	3.28	1.67	2.15	2.09	2.11	2.07	1.85	1.76	1.74	1.79	1.78	1.71	2.04
	HDD10.0	1312	13	19	38	88	147	185	209	209	174	126	71	32
	HDD18.3	4253	238	222	282	337	405	435	468	467	424	384	319	271
	CDD10.0	100	33	31	14	2	0	0	0	0	0	0	1	19
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.6	8.5	7.9	7.6	7.8	7.0	7.0	7.2	7.2	6.8	7.3	8.5	7.9
Precipitation	PrecAvg	800	69	63	80	75	73	69	65	67	59	60	57	64
	PrecMax	1075	97	93	122	126	114	138	137	120	139	162	94	122
	PrecMin	646	42	37	44	32	38	30	33	38	29	33	32	34
	PrecStd	99	15	14	19	24	18	23	23	17	23	22	13	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	17.5	15.7	13.1	10.4	8.7	7.7	7.6	9.4	11.9	13.7	16.6
		MCWB	13.0	14.0	12.4	11.1	9.0	7.6	6.7	5.9	6.9	8.1	10.0	12.0
	2%	DB	15.4	15.7	13.9	11.7	9.3	7.7	6.9	6.7	8.4	10.4	12.1	15.1
		MCWB	12.3	12.7	11.8	10.0	8.3	6.9	6.2	5.3	6.4	7.6	9.2	11.5
	5%	DB	14.4	14.6	12.9	10.8	8.7	7.2	6.4	6.1	7.5	9.5	11.2	13.9
		MCWB	11.5	12.2	11.0	9.5	7.9	6.4	5.7	4.9	5.9	7.1	8.6	10.8
	10%	DB	13.5	13.6	12.0	10.1	8.2	6.6	5.8	5.6	6.7	8.7	10.4	12.9
		MCWB	11.0	11.6	10.6	9.0	7.4	5.9	5.1	4.6	5.4	6.6	8.1	10.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.8	14.6	13.5	11.5	9.5	8.0	7.1	6.2	7.5	8.7	10.3	12.8
		MCDB	15.9	16.5	14.9	12.5	10.1	8.3	7.3	6.9	8.5	11.1	12.2	15.1
	2%	WB	12.8	13.5	12.2	10.5	8.7	7.2	6.5	5.7	6.7	8.0	9.6	11.8
		MCDB	14.6	15.0	13.2	11.3	9.1	7.5	6.7	6.3	7.9	9.9	11.3	14.0
	5%	WB	12.1	12.7	11.6	9.8	8.2	6.6	5.9	5.2	6.1	7.4	8.9	11.1
		MCDB	13.7	14.0	12.5	10.5	8.6	7.0	6.3	5.9	7.3	9.1	10.5	13.1
	10%	WB	11.4	12.0	10.9	9.1	7.6	6.0	5.3	4.7	5.6	6.8	8.3	10.4
		MCDB	13.0	13.3	11.8	9.9	8.1	6.5	5.7	5.5	6.5	8.3	9.9	12.2
Mean Daily Temperature Range	5% DB	MDBR	4.8	4.6	4.4	3.8	3.2	2.9	3.0	3.3	3.8	4.6	4.7	5.1
		MCDBR	6.3	5.9	5.4	4.7	3.5	3.2	3.4	3.4	4.7	5.7	5.7	6.7
		MCWBR	4.2	4.2	3.9	4.0	3.2	3.0	3.2	2.9	3.4	3.9	3.9	4.3
	5% WB	MCDBR	5.8	5.5	5.1	4.4	3.3	3.1	3.4	3.2	4.6	5.5	5.2	6.2
		MCWBR	4.3	4.3	4.2	3.9	3.2	2.9	3.2	2.9	3.6	4.0	3.9	4.5
Clear-Sky Solar Irradiance	taub	0.342	0.336	0.329	0.323	0.315	0.301	0.306	0.318	0.326	0.325	0.333	0.342	
	taud	2.495	2.518	2.525	2.483	2.352	2.317	2.364	2.435	2.465	2.488	2.484	2.476	
	Ebn at Noon	965	936	882	784	658	602	660	773	869	938	969	974	
	Edh at Noon	107	97	85	71	60	52	58	72	88	99	107	111	
All-Sky Solar Radiation	RadAvg	5.93	4.72	3.31	1.85	0.97	0.64	0.77	1.48	2.74	4.38	5.81	6.53	
	RadStd	0.30	0.34	0.28	0.13	0.06	0.04	0.06	0.13	0.21	0.23	0.40	0.55	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page