

WEDDELL ISLAND, Falkland Islands (Malvinas)

WMO: 888830

Lat: 51.891S

Lon: 60.912W

Elev: 17

StdP: 101.12

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.4	-0.5	-6.4	2.2	2.0	-4.8	2.5	1.2	17.2	3.5	15.3	3.1	5.1	210	0.889

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.5	16.7	12.0	15.5	11.2	14.5	10.7	13.0	15.4	12.2	14.2	11.5	13.4	7.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
11.9	8.7	13.5	11.2	8.3	12.8	10.4	7.9	12.2	37.0	15.4	34.9	14.1	33.2	13.5	16.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.7	13.4	12.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	10.2	9.9	8.8	7.0	5.3	4.1	3.4	3.7	4.3	6.1	7.6	9.4
	DBStd	3.15	2.12	2.03	2.34	2.07	1.86	1.98	1.90	1.70	1.84	1.98	2.16	2.26
	HDD10.0	1326	24	25	50	92	146	177	206	196	171	122	78	39
	HDD18.3	4277	252	237	295	341	404	427	464	454	421	379	323	278
	CDD10.0	90	30	21	13	1	0	0	0	0	0	1	4	19
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.6	7.1	6.9	6.6	6.3	6.2	6.1	6.6	6.4	6.2	6.8	7.2	6.8
Precipitation	PrecAvg	849	69	61	88	83	76	70	71	72	65	66	63	64
	PrecMax	1072	91	80	117	122	124	118	119	119	136	133	97	104
	PrecMin	707	44	42	49	42	34	35	24	43	30	40	42	41
	PrecStd	83	12	12	16	21	17	20	20	15	21	17	13	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.5	18.0	17.1	13.4	11.0	10.0	9.1	8.8	11.0	14.2	15.7	18.2
		MCWB	13.3	13.2	12.9	10.7	8.5	7.7	6.8	6.2	7.2	9.1	10.6	12.1
	2%	DB	16.6	16.0	14.7	12.0	9.6	8.5	7.7	7.7	9.5	12.2	14.0	16.2
		MCWB	12.1	11.9	11.4	9.9	7.8	7.2	6.3	5.8	6.7	8.2	9.6	10.9
	5%	DB	15.3	14.6	13.3	11.0	8.8	7.7	6.9	7.0	8.2	10.7	12.6	14.9
		MCWB	11.4	11.1	10.8	9.4	7.3	6.7	5.7	5.4	6.0	7.3	8.8	10.6
	10%	DB	14.0	13.4	12.3	10.2	8.2	7.0	6.2	6.3	7.1	9.6	11.5	13.6
		MCWB	10.8	10.8	10.4	8.8	6.9	6.1	5.3	5.0	5.4	6.7	8.3	9.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.4	14.0	13.3	11.4	9.3	8.2	7.2	6.8	7.9	9.9	11.3	13.1
		MCDB	17.6	16.8	15.3	12.6	10.1	9.3	8.4	7.9	10.2	13.4	14.3	17.0
	2%	WB	12.9	12.8	12.4	10.5	8.4	7.5	6.6	6.2	6.9	8.6	10.2	11.9
		MCDB	15.6	14.6	13.7	11.5	9.1	8.4	7.4	7.2	8.7	11.2	13.1	15.0
	5%	WB	12.0	12.0	11.6	9.7	7.8	6.9	6.1	5.7	6.3	7.7	9.3	11.0
		MCDB	14.3	13.4	12.8	10.6	8.4	7.7	6.7	6.6	7.6	10.0	12.0	13.8
	10%	WB	11.2	11.2	10.7	9.1	7.2	6.3	5.5	5.2	5.7	7.0	8.5	10.3
		MCDB	13.3	12.8	11.9	10.0	8.0	6.9	6.2	6.1	6.9	9.0	10.9	12.9
Mean Daily Temperature Range	5% DB	MDBR	6.5	5.7	5.4	4.7	4.0	3.4	3.5	4.0	4.8	6.3	6.6	7.1
		MCDBR	8.1	7.6	6.8	5.8	4.7	3.9	4.1	4.8	6.6	8.0	8.3	9.2
		MCWBR	5.1	5.0	4.7	4.6	4.1	3.3	3.5	3.8	4.7	5.1	5.3	5.7
	5% WB	MCDBR	7.5	6.8	6.1	5.5	4.5	3.8	4.0	4.6	6.0	7.3	8.0	8.6
		MCWBR	5.2	5.1	4.6	4.6	4.1	3.4	3.6	3.9	4.6	5.0	5.5	5.9
Clear-Sky Solar Irradiance	taub	0.338	0.333	0.325	0.322	0.307	0.300	0.306	0.318	0.321	0.322	0.329	0.338	
	taud	2.521	2.539	2.549	2.491	2.393	2.313	2.359	2.440	2.496	2.511	2.510	2.502	
	Ebn at Noon	968	937	884	779	664	591	650	768	872	939	972	977	
	Edh at Noon	104	95	82	69	57	51	57	71	85	96	104	108	
All-Sky Solar Radiation	RadAvg	6.17	4.95	3.36	1.87	0.94	0.59	0.72	1.47	2.77	4.54	6.04	6.83	
	RadStd	0.25	0.31	0.27	0.11	0.06	0.04	0.05	0.13	0.22	0.21	0.36	0.48	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page