

MOUNT PLEASANT, Falkland Islands (Malvinas)

WMO: 888890

Lat: 51.8200S

Lon: 58.4481W

Elev: 244

StdP: 14.57

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 26.0	(c) 28.1	(d) 19.7	(e) 14.9	(f) 32.3	(g) 22.0	(h) 16.6	(i) 33.3	(j) 41.6	(k) 41.6	(l) 38.2	(m) 41.0	(n) 13.9	(o) 290	(p) 0.976

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 14.7	(c) 67.9	(d) 55.1	(e) 64.6	(f) 53.3	(g) 62.2	(h) 52.0	(i) 57.1	(j) 64.4	(k) 55.2	(l) 61.5	(m) 53.6	(n) 59.9	(o) 20.6	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.9	62.3	58.6	52.0	58.1	57.1	50.3	54.4	55.5	24.7	64.5	23.5	61.4	22.5	59.8	63.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
40.0	35.6	32.1	21.6	74.4	2.6	2.7	19.7	76.3	18.2	77.9	16.7	79.4	14.8	81.4
			20.4	60.3	2.6	2.0	18.6	61.7	17.1	62.9	15.7	64.0	13.8	65.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.7	51.1	50.5	48.5	44.3	40.4	37.1	36.2	37.5	39.8	43.4	46.5	49.1		
	DBStd	7.08	4.87	5.39	5.36	4.83	4.43	4.49	4.50	4.02	4.64	4.57	5.05	5.14		
	HDD50	2600	45	54	93	180	299	387	429	387	308	210	128	80		
	HDD65	7792	430	408	511	622	763	837	894	852	757	670	555	493		
	CDD50	286	81	67	47	9	1	0	0	0	1	5	23	52		
	CDD65	1	0	1	0	0	0	0	0	0	0	0	0	0		
	CDH74	8	2	5	1	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	17.2	18.2	17.3	17.1	17.1	16.0	15.4	15.8	16.7	17.2	18.5	18.8	18.3		
(15) Precipitation	PrecAvg	23.4	2.3	2.0	2.4	2.1	2.1	2.2	1.9	1.6	1.5	1.3	1.7	2.3		
	PrecMax	34.7	4.4	3.5	4.7	5.0	4.2	4.8	5.7	3.1	5.5	2.7	3.8	5.8		
	PrecMin	16.6	0.9	0.7	1.1	0.4	0.8	0.9	0.6	0.6	0.4	0.4	0.5	0.5		
	PrecStd	4.3	0.9	0.7	0.9	1.2	0.7	1.1	1.1	0.7	1.0	0.5	0.8	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.6	73.3	68.6	60.8	55.3	52.3	49.0	51.0	57.1	62.2	67.6	70.0		
		MCWB	56.4	59.1	55.9	51.5	48.1	45.3	43.5	44.1	47.1	49.7	53.0	55.3		
	2%	DB	66.5	66.5	63.7	56.9	51.0	47.3	46.2	47.7	52.9	57.3	62.5	65.2		
		MCWB	54.6	55.8	54.0	49.8	45.8	43.8	42.5	42.2	44.6	46.5	50.2	52.7		
	5%	DB	63.2	62.7	60.2	53.9	48.7	45.0	44.4	45.0	49.8	53.9	59.0	61.9		
		MCWB	52.7	53.7	52.2	48.3	45.4	42.6	41.6	41.0	43.4	45.1	48.4	50.9		
	10%	DB	60.5	59.4	57.2	51.7	47.1	43.7	42.8	43.2	46.8	51.6	55.6	58.7		
		MCWB	51.3	52.0	50.8	47.4	44.5	41.7	40.6	40.1	41.7	44.1	46.6	49.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.0	60.6	58.6	53.2	49.5	46.6	44.5	45.0	47.9	50.5	54.0	56.8		
		MCDB	68.0	69.1	65.5	58.1	52.8	49.6	46.7	48.3	55.4	59.7	64.0	66.9		
	2%	WB	56.2	57.6	55.6	51.0	47.4	44.5	43.0	43.1	45.4	48.1	51.5	54.3		
		MCDB	63.9	64.2	60.7	55.0	49.5	46.7	45.0	45.9	50.8	54.9	60.0	62.8		
	5%	WB	54.3	55.3	53.7	49.4	46.1	43.0	41.8	41.8	43.8	46.3	49.7	52.2		
		MCDB	61.1	60.6	58.4	52.8	47.9	44.7	43.7	44.1	48.1	52.0	56.9	59.3		
	10%	WB	52.6	53.3	51.7	47.9	44.7	41.7	40.6	40.5	42.3	44.8	47.7	50.4		
		MCDB	58.9	58.6	56.4	50.9	46.6	43.3	42.4	42.5	45.8	49.7	53.7	56.8		
(35) Mean Daily Temperature Range	MDBR		14.7	13.9	12.9	10.6	8.6	7.5	7.5	8.8	10.9	13.3	14.6	14.7		
	5% DB	MCDBR	19.4	18.8	17.1	13.8	10.9	8.9	9.2	11.3	15.2	17.4	20.0	20.0		
		MCWBR	10.9	11.2	10.3	9.3	8.2	7.3	7.3	8.0	9.5	10.1	11.0	10.9		
	5% WB	MCDBR	17.8	17.6	15.7	13.0	9.9	8.3	8.5	10.0	13.6	15.9	18.3	18.7		
		MCWBR	11.1	11.9	10.7	9.7	8.4	7.2	7.3	7.9	9.2	10.0	11.1	11.4		
(40) Clear-Sky Solar Irradiance	taub		0.339	0.333	0.326	0.320	0.303	0.296	0.303	0.315	0.320	0.321	0.328	0.337		
	taud		2.495	2.518	2.523	2.480	2.399	2.310	2.352	2.433	2.476	2.489	2.488	2.480		
	Ebn at Noon		307	298	280	248	213	189	207	245	277	298	308	310		
	Edh at Noon		34	31	27	22	18	16	18	23	27	31	34	35		
(44) All-Sky Solar Radiation	RadAvg		1851	1466	1020	565	293	187	228	450	840	1367	1803	2042		
	RadStd		89	108	83	41	16	12	17	36	66	77	128	180		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	+1.06	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	+1.06	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page