

MOUNT PLEASANT, Falkland Islands (Malvinas)

WMO: 888890

Lat: **51.8200S**Lon: **58.4481W**Elev: **74**StdP: **100.43**Time Zone: **-3.00 (W03)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-3.3	-2.2	-6.8	2.1	0.2	-5.6	2.4	0.7	18.6	5.3	17.1	5.0	6.2	290	0.976

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.2	19.9	12.8	18.1	11.8	16.8	11.1	14.0	18.0	12.9	16.4	12.0	15.5	9.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	8.9	14.8	11.1	8.3	14.0	10.1	7.8	13.1	39.5	18.1	36.8	16.3	34.5	15.4	17.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.9	15.9	14.4	-5.8	23.6	1.4	1.5	-6.8	24.6	-7.7	25.5	-8.5	26.3	-9.5	27.4		
(5)			-6.4	15.7	1.4	1.1	-7.4	16.5	-8.3	17.2	-9.1	17.8	-10.1	18.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	10.6	10.3	9.2	6.8	4.7	2.8	2.3	3.1	4.3	6.3	8.1	9.5
	DBStd	3.93	2.70	2.99	2.98	2.69	2.46	2.50	2.50	2.23	2.58	2.54	2.81	2.85
	HDD10.0	1444	25	30	52	100	166	215	238	215	171	117	71	44
	HDD18.3	4329	239	227	284	346	424	465	497	473	421	372	308	274
	CDD10.0	159	45	37	26	5	1	0	0	0	1	3	13	29
	CDD18.3	1	0	1	0	0	0	0	0	0	0	0	0	0
	CDH23.3	4	1	3	1	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.7	8.1	7.7	7.7	7.6	7.2	6.9	7.1	7.5	7.7	8.3	8.4	8.2
Precipitation	PrecAvg	595	58	51	61	54	54	55	48	41	38	34	42	59
	PrecMax	882	113	90	120	128	106	122	145	80	139	69	96	147
	PrecMin	421	24	19	29	11	21	22	15	16	11	9	13	12
	PrecStd	110	22	18	24	30	19	27	28	17	26	12	20	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.0	22.9	20.4	16.0	12.9	11.3	9.4	10.6	13.9	16.8	19.8	21.1
		MCWB	13.5	15.1	13.3	10.8	8.9	7.4	6.4	6.7	8.4	9.8	11.7	12.9
	2%	DB	19.2	19.2	17.6	13.8	10.5	8.5	7.9	8.7	11.6	14.0	17.0	18.5
		MCWB	12.6	13.2	12.2	9.9	7.7	6.6	5.8	5.7	7.0	8.1	10.1	11.5
	5%	DB	17.3	17.0	15.7	12.2	9.3	7.2	6.9	7.2	9.9	12.2	15.0	16.6
		MCWB	11.5	12.1	11.2	9.0	7.4	5.9	5.3	5.0	6.3	7.3	9.1	10.5
	10%	DB	15.8	15.2	14.0	10.9	8.4	6.5	6.0	6.2	8.2	10.9	13.1	14.8
		MCWB	10.7	11.1	10.4	8.5	6.9	5.4	4.8	4.5	5.4	6.7	8.1	9.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.0	15.9	14.8	11.8	9.7	8.1	7.0	7.2	8.9	10.3	12.2	13.8
		MCDB	20.0	20.6	18.6	14.5	11.5	9.8	8.2	9.1	13.0	15.4	17.8	19.4
	2%	WB	13.5	14.2	13.1	10.6	8.6	6.9	6.1	6.2	7.5	9.0	10.8	12.4
		MCDB	17.7	17.9	15.9	12.8	9.7	8.2	7.2	7.7	10.4	12.7	15.6	17.1
	5%	WB	12.4	12.9	12.0	9.7	7.8	6.1	5.5	5.5	6.5	8.0	9.8	11.2
		MCDB	16.2	15.9	14.7	11.5	8.9	7.1	6.5	6.7	8.9	11.1	13.8	15.2
	10%	WB	11.5	11.9	11.0	8.8	7.0	5.4	4.8	4.7	5.7	7.1	8.7	10.2
		MCDB	14.9	14.8	13.5	10.5	8.1	6.3	5.8	5.8	7.7	9.8	12.1	13.8
Mean Daily Temperature Range	5% DB	MDBR	8.2	7.7	7.1	5.9	4.8	4.2	4.2	4.9	6.1	7.4	8.1	8.2
		MCDBR	10.8	10.4	9.5	7.7	6.0	4.9	5.1	6.3	8.5	9.7	11.1	11.1
		MCWBR	6.1	6.2	5.7	5.2	4.6	4.0	4.1	4.5	5.3	5.6	6.1	6.1
	5% WB	MCDBR	9.9	9.8	8.7	7.2	5.5	4.6	4.7	5.6	7.6	8.8	10.1	10.4
		MCWBR	6.2	6.6	5.9	5.4	4.7	4.0	4.1	4.4	5.1	5.6	6.2	6.4
Clear-Sky Solar Irradiance	taub	0.339	0.333	0.326	0.320	0.303	0.296	0.303	0.315	0.320	0.321	0.328	0.337	
	taud	2.495	2.518	2.523	2.480	2.399	2.310	2.352	2.433	2.476	2.489	2.488	2.480	
	Ebn at Noon	967	938	882	781	672	597	654	771	873	940	972	977	
	Edh at Noon	107	97	84	70	56	51	57	71	86	98	107	110	
All-Sky Solar Radiation	RadAvg	5.84	4.62	3.22	1.78	0.92	0.59	0.72	1.42	2.65	4.31	5.68	6.44	
	RadStd	0.28	0.34	0.26	0.13	0.05	0.04	0.05	0.11	0.21	0.24	0.41	0.57	