

BASE BELGRANO II, Antarctica

WMO: 890340

Lat: 77.874S

Lon: 34.626W

Elev: 840

StdP: 14.26

Time Zone: -3.00 (W03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-30.2	-25.9	-46.9	0.4	-24.5	-41.6	0.5	-23.5	59.7	7.6	57.5	3.9	6.8	140	1.229

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	9.9	39.0	33.7	36.7	32.3	34.8	31.2	34.5	37.4	33.0	35.9	31.5	34.3	6.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
32.1	27.3	34.8	30.3	25.2	33.2	28.6	23.3	32.1	13.0	37.6	12.4	36.1	11.8	34.5	40.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 51.4	45.8	34.1	DB	-35.7	43.1	3.8	0.9	-38.4	43.7	-40.6	44.3	-42.7	44.8	-45.5	45.4	(4)
(5)			WB	-36.8	37.2	5.9	3.1	-41.0	39.4	-44.5	41.2	-47.8	42.9	-52.1	45.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	27.1	20.2	10.5	2.2	0.6	-2.1	-5.8	-4.9	-1.6	6.7	19.6	27.5		
	DBStd	14.70	4.61	6.61	8.98	10.74	9.81	9.12	9.78	10.98	10.55	8.72	6.24	4.98		
	HDD50	15226	709	833	1224	1433	1533	1564	1729	1700	1549	1343	911	698		
	HDD65	20701	1174	1253	1689	1883	1998	2014	2194	2165	1999	1808	1361	1163		
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	12.1	9.1	11.9	12.1	12.4	12.9	12.5	13.8	12.6	13.4	12.3	12.0	10.5		
	PrecAvg	10.7	0.6	0.6	0.7	0.7	0.8	1.0	1.1	1.2	1.3	1.0	1.1	0.6		
	PrecMax	16.5	1.5	1.7	1.6	1.5	1.5	3.7	2.5	2.4	3.1	3.6	3.7	1.9		
(15) Precipitation	PrecMin	6.5	0.1	0.0	0.1	0.0	0.0	0.3	0.1	0.1	0.2	0.0	0.1	0.0		
	PrecStd	2.2	0.4	0.4	0.4	0.4	0.5	0.8	0.6	0.6	0.8	0.8	0.9	0.5		
	DB	41.0	37.1	28.8	28.3	26.1	23.0	16.3	23.4	22.1	29.7	38.1	42.1			
	MCWB	34.3	32.9	26.6	27.1	24.5	20.8	14.7	20.9	20.8	25.5	32.5	35.7			
	2% DB	38.5	34.0	26.2	23.7	21.2	18.7	13.8	17.0	18.6	24.7	33.5	39.7			
(23) Mean Coincident Wet Bulb Temperatures	MCWB	33.3	31.2	24.1	22.6	19.8	16.9	12.3	15.7	16.9	22.5	30.2	34.2			
	DB	36.5	31.4	24.3	20.8	16.8	14.4	10.9	13.7	15.6	21.5	30.7	37.5			
	MCWB	32.2	29.0	22.4	19.7	15.5	12.9	9.3	12.5	13.7	19.3	28.2	32.8			
	5% DB	34.6	29.2	22.6	17.3	13.3	10.8	8.5	10.0	12.6	18.5	28.4	35.3			
	MCWB	31.1	26.8	20.8	16.1	11.9	9.3	7.2	8.7	10.9	16.7	26.1	31.3			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	36.6	33.9	27.0	27.0	24.8	21.3	15.1	21.3	21.2	26.4	34.1	37.0			
	MCDB	38.7	35.9	27.9	27.9	25.8	22.6	16.2	23.1	21.9	28.5	35.4	40.3			
	2% WB	34.2	31.6	24.7	22.9	20.2	16.8	12.4	15.8	17.3	22.6	30.9	34.8			
	MCDB	37.1	33.5	25.9	23.5	21.3	18.5	13.6	16.8	18.5	24.3	33.1	38.3			
	5% WB	32.8	29.4	22.7	19.7	15.6	13.0	9.5	12.6	13.9	19.5	28.6	33.2			
(31) Mean Daily Temperature Range	MCDB	35.7	31.1	24.1	20.7	16.6	14.4	10.8	13.6	15.4	21.2	30.2	36.6			
	10% WB	31.3	27.1	20.8	16.3	12.1	9.4	7.2	8.8	11.0	16.9	26.5	31.8			
	MCDB	34.2	28.9	22.5	17.3	13.2	10.8	8.6	9.9	12.7	18.4	28.1	34.8			
	5% DB	9.4	10.6	9.6	9.4	9.6	9.9	9.8	10.1	10.4	12.2	12.0	9.9			
	MCDBR	12.5	12.8	9.0	8.7	10.6	10.7	11.2	11.8	11.6	14.0	14.5	13.6			
(36) Clear-Sky Solar Irradiance	MCWBR	10.0	12.0	8.4	8.4	10.0	10.5	10.5	11.3	10.6	13.1	13.0	10.6			
	5% WB	12.1	12.8	8.7	8.3	10.3	10.5	11.2	11.8	10.5	13.5	14.3	12.8			
	MCWBR	10.7	12.2	8.4	8.2	10.0	10.4	10.9	11.3	10.1	12.9	13.5	11.1			
	taub	0.240	0.222	0.181	0.116	N/A	N/A	N/A	0.118	0.175	0.201	0.219	0.238			
	taud	2.252	2.257	2.187	1.904	N/A	N/A	N/A	1.877	2.126	2.218	2.250	2.243			
(42) All-Sky Solar Radiation	Ebn at Noon	304	282	238	34	0	0	0	25	233	291	312	312			
	Edh at Noon	31	24	15	1	0	0	0	1	15	25	31	33			
	RadAvg	2491	1496	503	40	0	0	0	6	259	1138	2318	2940			
(45)	RadStd	102	69	26	3	0	0	0	1	13	41	63	87			

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page