

MOUNT SIPLE, Antarctica

WMO: 893270

Lat: 73.198S

Lon: 127.052W

Elev: 755

StdP: 14.30

Time Zone: -8.00 (W08)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	-31.8	-24.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.3	36.5	N/A	34.0	N/A	31.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	-32.4	46.6	9.1	3.7	-38.9	49.3	-44.2	51.5	-49.3	53.6	-55.9	56.3
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.6	28.8	24.3	20.1	10.7	7.7	7.1	1.8	-3.1	6.2	10.0	21.7	28.4		
	DBStd	13.34	2.64	3.54	5.75	8.15	11.24	10.28	11.47	13.82	10.27	8.13	5.12	3.32		
	HDD50	13298	657	719	928	1180	1312	1287	1495	1645	1313	1241	850	671		
	HDD65	18773	1122	1139	1393	1630	1777	1737	1960	2110	1763	1706	1300	1136		
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Precipitation	PrecAvg	23.6	1.7	1.9	2.2	1.9	2.1	2.0	2.0	2.1	2.2	2.0	1.8	1.6		
	PrecMax	30.1	3.7	3.6	4.2	3.4	4.2	3.3	3.4	4.5	4.1	3.2	3.3	3.1		
	PrecMin	16.8	0.7	0.4	0.8	0.9	1.1	0.6	0.6	0.8	0.9	0.9	0.5	0.7		
	PrecStd	4.0	0.8	0.7	0.8	0.7	0.7	0.7	0.7	0.9	0.7	0.6	0.6	0.6		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.8	34.4	31.1	28.7	29.7	29.7	27.5	28.5	28.4	30.3	34.9	41.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	36.6	31.5	29.7	26.9	27.9	27.5	24.5	24.2	26.3	27.0	30.8	36.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	34.2	30.2	28.5	25.6	26.3	25.5	21.4	19.6	24.0	24.6	29.3	34.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	32.0	28.9	27.3	23.2	23.7	22.5	17.7	15.4	21.2	22.0	27.9	32.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.1	6.0	8.0	10.2	10.3	10.7	11.9	9.4	8.8	7.5	7.3		
		MCDBR	12.0	8.8	6.3	9.0	13.6	13.7	13.8	19.4	10.0	11.1	10.1	12.2		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Clear-Sky Solar Irradiance	taub		0.263	0.252	0.231	0.143	N/A	N/A	N/A	0.134	0.212	0.230	0.248	0.258		
	taud		2.355	2.384	2.362	1.945	N/A	N/A	N/A	1.900	2.255	2.321	2.347	2.359		
	Ebn at Noon		305	287	249	146	0	0	0	144	250	294	310	314		
	Edh at Noon		31	25	17	7	0	0	0	7	18	26	31	32		
All-Sky Solar Radiation	RadAvg		2043	1293	516	101	0	0	0	39	379	1129	2041	2463		
	RadStd		128	115	61	9	0	0	0	2	16	51	79	200		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page