

AMERY G3, Antarctica

WMO: 897670

Lat: 70.892S

Lon: 69.873E

Elev: 84

StdP: 100.32

Time Zone: 5.00 (E05)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	-42.4	-39.3	N/A	N/A	N/A	N/A	N/A	N/A	22.7	-29.3	21.6	-29.1	3.7	220	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.8	3.5	N/A	1.1	N/A	-0.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.1	18.2	16.1	DB	-43.1	6.4	3.4	3.2	-45.6	8.7	-47.6	10.6	-49.5	12.4	-51.9	14.7	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-20.1	-5.9	-11.8	-18.7	-23.8	-26.0	-26.2	-27.0	-27.1	-26.4	-23.6	-16.5	-8.1
	DBStd	8.70	3.92	3.72	4.28	4.29	5.23	4.26	5.26	4.57	3.48	4.82	4.45	5.34
	HDD10.0	10995	494	610	889	1013	1115	1085	1147	1149	1093	1042	796	562
	HDD18.3	14037	753	843	1147	1263	1373	1335	1405	1408	1343	1301	1046	820
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.4	3.2	5.3	7.6	9.1	8.9	9.6	9.4	9.7	9.2	7.6	5.2	3.6
Precipitation	PrecAvg	174	15	13	12	10	13	15	21	16	14	13	19	13
	PrecMax	265	42	35	45	25	42	35	65	62	39	32	50	48
	PrecMin	50	0	2	1	3	3	1	1	1	0	1	0	1
	PrecStd	52	10	8	8	6	10	8	15	13	10	9	12	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.5	-1.2	-8.1	-13.4	-10.0	-14.6	-7.4	-10.5	-16.2	-8.2	-1.6	5.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	4.4	-3.2	-10.2	-14.9	-15.4	-18.1	-16.1	-17.5	-18.1	-12.7	-4.8	3.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	2.4	-4.6	-12.1	-17.3	-17.6	-20.0	-20.4	-20.3	-20.5	-14.5	-7.0	0.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	0.4	-6.1	-13.4	-18.7	-20.0	-21.6	-22.2	-22.7	-22.5	-16.8	-9.4	-0.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	8.8	6.7	4.5	3.7	3.3	2.9	2.6	2.7	2.6	4.2	5.4	6.8
		MCDBR	11.8	8.6	5.8	4.8	5.0	5.7	4.8	6.6	5.3	7.7	10.6	9.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.249	0.230	0.196	0.138	N/A	N/A	N/A	N/A	0.137	0.187	0.203	0.230	0.249
	taud	2.219	2.242	2.228	2.013	N/A	N/A	N/A	N/A	1.973	2.162	2.182	2.169	2.162
	Ebn at Noon	990	948	868	631	0	0	0	0	607	862	978	1009	1006
	Edh at Noon	114	93	66	30	0	0	0	0	30	68	98	119	126
All-Sky Solar Radiation	RadAvg	8.66	5.74	2.75	0.68	0.00	0.00	0.00	0.00	0.28	1.79	4.70	7.87	9.71
	RadStd	0.16	0.13	0.07	0.03	0.00	0.00	0.00	0.00	0.01	0.08	0.10	0.18	0.22

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page