

ANDERSEN AFB, Guam

WMO: 912180

Lat: 13.583N

Lon: 144.917E

Elev: 187

StdP: 99.10

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 41414

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.8	23.3	17.1	12.5	25.5	18.6	13.8	25.3	13.0	25.9	12.0	25.8	5.3	60	0.509

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	4.6	31.1	26.1	30.6	25.9	30.2	25.8	27.3	29.1	26.9	29.0	26.6	28.8	5.6	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.0	23.3	28.3	26.2	22.2	27.9	26.1	22.0	27.9	88.3	28.7	86.2	29.3	84.5	29.1	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.0	9.9	9.1	21.1	32.4	1.6	1.5	19.9	33.5	19.0	34.4	18.1	35.2	17.0	36.3
			18.5	28.5	2.3	1.0	16.8	29.2	15.5	29.8	14.2	30.3	12.6	31.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.0	26.2	26.1	26.4	27.1	27.6	27.8	27.4	27.2	27.1	27.1	27.2	26.9	(6)
	DBStd	0.96	0.78	0.83	0.85	0.71	0.66	0.80	0.89	0.94	0.93	0.94	0.68	0.70	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD10.0	6213	502	452	510	514	547	533	539	533	513	532	517	523	(10)
	CDD18.3	3172	243	218	252	264	288	283	281	274	263	273	267	264	(11)
	CDH23.3	30292	1923	1688	2122	2516	3012	3068	2903	2701	2544	2706	2662	2448	(12)
(13)	CDH26.7	6418	231	218	338	524	765	852	731	654	587	602	526	390	(13)
(14)	Wind	WSAvg	5.2	6.3	6.6	6.4	5.8	5.1	4.8	3.9	3.8	4.3	5.7	6.4	(14)
(15) Precipitation	PrecAvg	2354	134	112	96	110	125	154	273	386	314	295	249	158	(15)
	PrecMax	3120	412	316	371	368	445	453	484	835	661	735	486	433	(16)
	PrecMin	1436	27	18	22	15	19	13	139	126	84	102	61	28	(17)
	PrecStd	421	99	86	90	89	110	93	82	171	146	133	116	83	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.7	30.0	30.2	31.0	31.2	31.2	31.2	31.2	31.1	30.9	30.2	30.0	(19)
		MCWB	25.1	24.5	24.4	25.4	26.0	26.0	26.1	26.5	26.4	26.5	25.9	25.5	(20)
	2%	DB	29.0	29.1	29.2	30.1	30.6	30.9	30.7	30.5	30.3	30.2	29.9	29.2	(21)
		MCWB	24.6	24.3	24.2	25.0	25.7	26.0	26.1	26.2	26.1	26.1	25.8	25.1	(22)
	5%	DB	28.5	28.6	29.0	29.7	30.1	30.2	30.1	30.0	30.0	29.9	29.3	29.0	(23)
		MCWB	24.3	24.2	24.2	24.9	25.5	25.8	26.0	26.1	26.0	26.0	25.6	25.0	(24)
	10%	DB	28.0	28.1	28.5	29.1	29.7	30.0	29.7	29.5	29.3	29.2	29.0	28.7	(25)
		MCWB	24.1	24.0	24.0	24.8	25.4	25.7	25.9	25.9	25.9	25.8	25.5	24.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	26.2	26.2	27.1	27.2	27.1	27.6	27.7	28.0	27.6	27.2	26.7	(27)
		MCDB	27.9	27.4	27.5	28.4	29.3	29.7	29.4	29.7	29.2	29.1	28.7	28.3	(28)
	2%	WB	25.7	25.6	25.5	26.2	26.5	26.6	26.8	26.9	27.1	26.9	26.6	26.1	(29)
		MCDB	27.5	27.2	27.5	28.2	29.0	29.4	29.2	29.2	28.8	28.8	28.4	28.0	(30)
	5%	WB	25.2	25.1	25.1	25.7	26.1	26.2	26.4	26.5	26.6	26.5	26.2	25.7	(31)
		MCDB	27.2	27.1	27.4	28.1	28.8	29.0	28.9	28.8	28.6	28.5	28.1	27.7	(32)
	10%	WB	24.8	24.7	24.6	25.4	25.7	26.0	26.1	26.1	26.2	26.1	25.9	25.5	(33)
		MCDB	26.8	26.8	27.2	27.9	28.4	28.8	28.6	28.5	28.3	28.2	27.9	27.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	4.0	4.2	4.4	4.5	4.5	4.6	4.7	4.9	4.9	4.5	3.9	3.9	(35)
		MCDBR	4.5	4.7	4.7	4.9	4.8	4.9	5.1	5.4	5.4	4.9	4.2	4.1	(36)
	5% WB	MCWBR	2.6	2.6	2.7	2.5	2.3	2.4	2.7	2.9	2.8	2.6	2.5	2.4	(37)
		MCWBR	4.1	4.3	4.3	4.5	4.5	4.8	4.8	5.1	5.0	4.6	4.0	3.9	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.404	0.405	0.404	0.405	0.405	0.403	0.398	0.403	0.390	0.415	0.429	0.419	(40)
		taud	2.490	2.486	2.502	2.528	2.550	2.560	2.587	2.567	2.614	2.524	2.436	2.442	(41)
	Ebn at Noon	Ebn at Noon	895	908	913	904	888	881	887	893	912	887	863	869	(42)
		Edh at Noon	107	111	111	108	104	102	99	103	98	105	112	110	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	4.95	5.64	6.36	6.82	6.69	6.40	5.65	5.17	5.13	5.05	5.11	4.90	(44)
	RadStd	RadStd	0.27	0.22	0.27	0.26	0.27	0.49	0.54	0.46	0.38	0.47	0.27	0.19	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (2 neighbors)	+0.12	N/A	N/A	+0.14	N/A	N/A	N/A	N/A	+69	+69

Nomenclature: See separate page