

KOROR, Palau

WMO: 914080

Lat: 7.3366N

Lon: 134.4770E

Elev: 54

StdP: 100.68

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 40310

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	23.8	24.0	21.1	15.8	27.4	21.8	16.6	27.2	8.4	28.5	8.0	28.6	2.2	30	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	5.6	32.1	26.6	31.7	26.5	31.4	26.5	27.6	30.5	27.2	30.4	27.0	30.3	3.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.8	22.6	29.2	26.2	21.8	28.9	26.1	21.6	28.8	88.2	30.8	86.4	30.7	85.6	30.6	32.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.9	6.1	DB	22.6	33.3	0.6	1.4	22.2	34.2	21.8	35.0	21.5	35.8	21.0	36.8	(4)
(5)			WB	21.1	29.2	0.6	1.0	20.6	29.8	20.2	30.4	19.9	31.0	19.4	31.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	27.8	27.7	27.9	28.2	28.2	27.9	27.7	27.8	27.8	28.1	28.2	28.0	(6)	
	DBStd	0.90	0.82	0.90	0.86	0.79	0.87	0.93	0.93	0.98	0.92	0.89	0.80	0.90	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6543	552	495	554	547	563	537	547	551	536	560	546	557	(10)	
	CDD18.3	3501	293	262	296	297	304	287	289	292	286	302	296	298	(11)	
	CDH23.3	37507	3026	2648	3083	3271	3356	3057	3076	3154	3135	3328	3213	3159	(12)	
	CDH26.7	11249	835	721	917	1057	1074	908	879	928	951	1058	1007	915	(13)	
(14) Wind	WSAvg	2.7	3.1	3.2	2.9	2.8	2.3	2.3	2.7	2.8	2.9	2.6	2.4	2.7	(14)	
(15) Precipitation	PrecAvg	3704	277	238	198	224	314	419	434	352	324	328	281	307	(15)	
	PrecMax	4699	715	636	558	703	514	859	884	841	601	571	526	536	(16)	
	PrecMin	2453	54	16	6	58	101	150	95	101	26	149	91	38	(17)	
	PrecStd	526	146	139	107	126	97	142	190	128	127	100	97	115	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.9	31.7	32.1	32.2	32.2	32.2	31.8	31.8	32.0	32.1	32.2	32.1	(19)	
		MCWB	26.3	26.1	26.0	26.5	26.9	27.0	26.6	26.6	26.6	26.8	26.8	26.7	(20)	
	2%	DB	31.2	31.2	31.4	31.7	31.7	31.5	31.2	31.2	31.2	31.5	31.6	31.4	(21)	
		MCWB	26.2	26.0	25.9	26.4	26.7	26.7	26.5	26.4	26.4	26.6	26.7	26.6	(22)	
	5%	DB	30.8	30.7	31.0	31.2	31.2	31.0	30.7	30.7	30.9	31.1	31.1	31.0	(23)	
		MCWB	26.1	25.9	25.9	26.3	26.7	26.6	26.3	26.2	26.3	26.5	26.6	26.5	(24)	
	10%	DB	30.2	30.1	30.4	30.8	30.8	30.4	30.1	30.1	30.2	30.6	30.7	30.3	(25)	
		MCWB	25.9	25.7	25.8	26.2	26.6	26.4	26.1	26.0	26.1	26.3	26.5	26.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.1	27.2	27.5	27.8	27.8	27.6	27.6	27.3	27.5	27.6	27.6	(27)	
		MCDB	30.2	30.4	30.6	30.6	31.1	30.7	30.0	29.6	30.5	30.8	30.7	30.5	(28)	
	2%	WB	26.7	26.6	26.7	27.0	27.2	27.2	27.0	26.9	26.7	27.0	27.1	27.0	(29)	
		MCDB	29.9	29.8	30.0	30.4	30.5	30.3	30.1	29.9	30.0	30.4	30.4	30.2	(30)	
	5%	WB	26.4	26.2	26.3	26.6	26.9	26.7	26.6	26.5	26.4	26.6	26.8	26.7	(31)	
		MCDB	29.4	29.2	29.5	29.8	30.0	29.7	29.4	29.4	29.5	29.8	29.9	29.6	(32)	
	10%	WB	26.1	26.0	26.0	26.4	26.6	26.5	26.2	26.2	26.2	26.4	26.5	26.4	(33)	
		MCDB	28.9	28.9	29.1	29.3	29.5	29.2	28.9	28.9	29.0	29.2	29.4	29.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.4	5.6	5.6	5.5	5.4	5.2	5.0	5.1	5.4	5.5	5.3	(35)	
		MCDBR	5.9	6.0	6.1	6.0	6.1	6.1	5.8	5.6	5.7	5.8	6.0	5.9	(36)	
	5% WB	MCWBR	2.8	2.7	2.7	2.7	2.8	2.7	2.7	2.7	2.7	2.6	2.7	2.7	(37)	
		MCWBR	5.5	5.5	5.7	5.7	5.7	5.7	5.4	5.3	5.3	5.5	5.7	5.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.440	0.433	0.427	0.417	0.399	0.389	0.397	0.405	0.399	0.416	0.408	0.430	(40)	
		taud	2.434	2.448	2.486	2.530	2.600	2.630	2.600	2.557	2.576	2.510	2.555	2.477	(41)	
	Edn at Noon	Edn at Noon	877	893	897	892	890	888	885	890	909	897	902	879	(42)	
		Edh at Noon	117	118	114	108	98	94	97	103	103	109	103	110	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	4.99	5.39	5.88	6.05	5.47	5.04	4.85	5.13	5.25	5.34	5.02	4.72	(44)	
	RadStd	RadStd	0.35	0.51	0.41	0.42	0.38	0.31	0.54	0.35	0.54	0.39	0.42	0.37	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	-0.18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page