

HONIARA INTL, Solomon Islands

WMO: 915200

Lat: 9.4294S

Lon: 160.0469E

Elev: 30

StdP: 14.68

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	69.7	71.0	67.2	100.0	75.0	68.2	103.8	75.3	19.2	86.8	18.2	86.7	1.5	160	0.289

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.4	90.5	79.3	89.8	79.3	89.3	79.2	81.8	87.6	81.0	87.3	80.7	87.2	11.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.2	157.0	85.8	79.2	151.6	85.0	78.9	150.4	84.8	45.6	87.7	44.9	88.1	44.4	87.2	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.4	14.7	12.6	DB	66.5	94.1	1.7	3.7	65.2	96.8	64.2	99.0	63.3	101.1	62.0	103.8
			WB	65.5	84.8	1.9	1.7	64.1	86.0	63.0	86.9	61.9	87.9	60.5	89.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.5	81.3	81.1	80.9	80.8	80.7	80.0	79.6	79.5	80.0	80.2	80.7	81.1
	DBStd	1.52	1.40	1.42	1.33	1.32	1.39	1.45	1.47	1.55	1.53	1.41	1.37	1.16
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11127	969	870	959	925	951	901	918	914	900	935	920	965
	CDD65	5652	504	450	494	475	486	451	453	449	450	470	470	500
	CDH74	51975	4961	4304	4608	4410	4453	3871	3752	3736	4080	4339	4531	4930
	CDH80	18191	1676	1432	1527	1516	1606	1360	1297	1291	1483	1571	1646	1786
(14) Wind	WSAvg	4.0	3.5	4.1	3.4	3.2	3.7	4.1	4.5	4.5	4.9	4.3	3.6	3.5
(15) Precipitation	PrecAvg	78.9	9.9	12.1	12.0	7.2	5.0	3.5	4.3	3.8	4.1	5.0	5.8	7.2
	PrecMax	114.1	32.8	24.2	25.4	13.6	15.9	10.7	12.2	6.9	9.7	15.1	15.7	17.9
	PrecMin	50.0	1.3	3.2	2.1	1.2	0.9	0.6	0.6	1.0	1.0	0.3	0.5	2.0
	PrecStd	16.3	6.3	5.8	6.1	3.3	3.4	2.2	2.3	1.3	2.2	3.3	3.6	3.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.0	91.1	90.4	90.0	90.5	90.0	89.9	90.0	90.8	91.3	90.1	90.5
		MCWB	79.8	78.3	79.9	79.9	79.8	79.4	78.6	78.2	78.6	79.0	78.8	79.7
	2%	DB	89.6	89.3	89.3	89.2	89.4	89.2	88.8	88.7	89.4	89.5	89.3	89.5
		MCWB	79.8	79.2	79.7	79.9	79.6	79.2	78.2	78.0	78.3	79.0	78.9	79.7
	5%	DB	88.2	88.1	88.1	88.0	88.2	87.9	87.7	87.7	88.1	88.1	88.1	88.2
		MCWB	79.6	79.3	79.5	79.6	79.4	78.8	78.0	78.1	78.4	78.8	79.0	79.5
	10%	DB	87.6	87.3	87.3	87.2	87.5	86.9	86.4	86.3	87.2	87.1	87.4	87.6
		MCWB	79.5	79.2	79.3	79.4	79.2	78.5	77.7	77.6	78.2	78.5	78.8	79.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.3	82.3	81.8	81.9	81.8	81.9	80.8	80.9	80.8	81.2	81.3	81.9
		MCDB	87.9	86.6	87.8	87.6	88.3	87.4	87.2	87.6	87.8	88.2	88.2	87.9
	2%	WB	81.2	80.9	80.9	80.9	80.8	80.4	79.8	79.6	79.9	80.1	80.3	81.0
		MCDB	87.3	86.5	87.0	87.2	87.5	87.2	86.4	86.7	87.1	87.2	87.1	87.4
	5%	WB	80.5	80.2	80.3	80.1	80.0	79.6	79.0	78.8	79.2	79.4	79.7	80.3
		MCDB	86.8	86.0	86.3	86.4	86.7	86.2	85.6	85.8	86.4	86.4	86.4	86.8
	10%	WB	79.8	79.6	79.6	79.6	79.4	78.9	78.3	78.0	78.5	78.8	79.1	79.7
		MCDB	85.7	85.2	85.4	85.6	85.8	85.4	84.7	84.7	85.5	85.7	85.6	85.8
(35) Mean Daily Temperature Range	5% DB	MDBR	12.4	12.3	12.3	12.8	13.5	13.9	14.1	14.3	14.6	14.4	13.9	13.4
		MCDBR	14.2	14.0	14.2	14.2	15.0	15.7	16.2	16.3	16.2	16.0	15.1	14.6
		MCWBR	6.6	6.5	6.6	6.8	7.1	7.5	7.3	7.6	7.4	7.6	7.0	7.0
	5% WB	MCDBR	13.2	12.7	13.0	13.4	14.2	14.6	14.6	14.8	15.0	14.9	14.2	13.8
		MCWBR	6.6	6.6	6.5	6.8	7.2	7.6	7.2	7.5	7.4	7.6	7.1	7.1
(40) Clear-Sky Solar Irradiance	taub		0.425	0.419	0.412	0.407	0.410	0.424	0.446	0.441	0.435	0.434	0.432	0.428
	taud		2.440	2.451	2.485	2.513	2.506	2.474	2.389	2.403	2.427	2.413	2.409	2.423
	Ebn at Noon		291	292	288	281	271	261	257	267	278	284	287	289
	Edh at Noon		39	38	36	34	32	32	36	37	38	39	40	39
(44) All-Sky Solar Radiation	RadAvg		1656	1696	1660	1585	1432	1281	1266	1447	1643	1735	1790	1742
	RadStd		208	143	141	139	97	115	79	87	110	120	100	104

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page