

ANEITYUM ISLAND, Vanuatu

WMO: 915680

Lat: 20.233S

Lon: 169.767E

Elev: 23

StdP: 14.68

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	59.7	61.5	53.6	61.2	68.6	55.3	65.2	68.8	25.0	72.5	21.9	72.9	1.5	10	0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.5	88.2	80.3	87.0	79.6	86.0	79.1	81.7	86.8	80.8	85.7	80.1	84.8	7.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.1	156.4	85.3	79.3	152.0	84.4	78.7	148.9	83.7	45.4	87.0	44.5	85.8	43.7	85.2	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.0	19.5	17.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.7	79.9	80.3	80.0	78.2	74.9	72.9	71.1	70.9	72.1	74.2	76.0	78.3
	DBStd	4.19	2.16	2.16	1.76	2.06	2.51	2.57	2.90	2.96	2.84	2.48	2.38	2.38
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDD50	9380	927	850	930	845	771	686	654	649	662	750	779	877
	CDD65	3905	462	430	465	395	306	236	189	184	212	285	329	412
	CDH74	27552	4606	4432	4482	3132	1554	654	403	466	778	1410	2078	3557
	CDH80	5297	1144	1285	1061	449	112	31	12	21	49	121	221	791
Wind	WSAvg	7.2	7.8	7.1	6.6	7.0	6.9	7.7	6.9	6.9	7.1	8.1	8.2	6.5
Precipitation	PrecAvg	89.0	9.8	10.3	13.7	11.0	8.0	5.6	4.9	3.8	3.8	4.8	5.1	8.1
	PrecMax	133.7	26.1	32.1	32.1	29.2	25.2	15.2	9.2	9.2	17.5	16.3	14.9	26.5
	PrecMin	57.8	1.8	2.3	3.6	3.0	2.2	1.6	1.2	0.8	0.4	0.3	1.0	0.9
	PrecStd	19.6	6.3	6.5	6.7	6.6	5.7	3.1	2.2	2.1	4.1	3.9	3.9	5.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.6	90.7	89.2	87.2	84.5	83.3	81.6	82.6	83.6	84.7	86.1	88.2
		MCWB	81.0	81.9	81.0	79.5	77.0	76.7	74.7	74.6	75.5	76.2	77.8	79.8
	2%	DB	87.3	88.6	87.2	85.4	82.6	80.4	79.2	79.8	81.4	82.5	84.2	86.6
		MCWB	80.0	80.9	79.9	78.7	76.2	73.9	73.1	72.6	73.6	74.7	76.8	78.8
	5%	DB	86.1	87.1	85.9	84.1	81.0	78.7	77.7	78.1	79.7	81.0	82.7	85.4
		MCWB	79.4	79.9	79.4	78.1	74.8	72.6	71.8	71.2	72.3	73.6	75.4	77.9
	10%	DB	84.9	85.9	84.8	82.7	79.6	77.3	76.2	76.6	78.1	79.7	81.3	84.2
		MCWB	78.5	79.2	78.6	77.1	73.9	71.6	70.3	69.9	71.0	72.6	74.3	77.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.6	83.7	81.9	80.8	78.9	77.7	76.2	76.2	77.2	78.2	79.5	81.1
		MCDB	87.3	89.1	87.2	85.3	82.8	81.9	79.6	81.3	82.2	83.5	84.5	86.9
	2%	WB	81.3	82.0	80.9	79.8	77.4	75.7	74.6	74.3	75.5	76.2	78.1	80.0
		MCDB	86.1	87.2	85.8	84.1	81.0	79.0	78.3	78.5	79.8	80.8	82.8	85.4
	5%	WB	80.4	80.9	80.1	79.0	76.4	74.3	73.0	72.7	74.0	74.9	76.8	79.1
		MCDB	85.0	86.0	84.7	82.9	79.8	77.6	76.7	76.9	78.2	79.5	81.3	84.1
	10%	WB	79.6	80.0	79.4	78.1	75.5	72.9	71.7	71.2	72.6	73.9	75.7	78.1
		MCDB	83.9	84.8	83.8	81.7	78.7	76.4	75.2	75.7	76.8	78.4	79.9	82.9
Mean Daily Temperature Range	5% DB	MDBR	9.7	10.5	9.2	8.5	9.5	8.5	9.9	11.0	11.4	10.7	9.9	10.8
		MCDBR	11.5	12.8	11.7	11.1	11.9	11.1	12.3	12.9	14.1	13.4	12.2	13.1
		MCWBR	6.6	7.0	6.4	6.0	6.8	6.3	7.5	7.7	8.3	7.7	6.9	7.1
	5% WB	MCDBR	11.0	11.8	11.0	9.7	10.3	10.0	11.1	11.6	12.2	11.9	10.7	11.8
	MCWBR	6.7	6.9	6.5	6.0	6.5	6.7	7.8	8.4	8.4	7.7	6.7	7.2	
Clear-Sky Solar Irradiance	taub	0.392	0.384	0.387	0.377	0.376	0.364	0.343	0.351	0.361	0.374	0.380	0.376	
	taud	2.582	2.613	2.616	2.632	2.589	2.615	2.658	2.626	2.575	2.560	2.568	2.614	
	Ebn at Noon	302	301	292	283	271	269	279	287	296	300	304	307	
	Edh at Noon	34	32	31	29	28	26	25	28	32	34	34	33	
All-Sky Solar Radiation	RadAvg	2128	2063	1782	1476	1237	1116	1195	1434	1748	1961	2084	2191	
	RadStd	144	132	100	130	103	89	75	83	152	118	147	133	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page