

ILE ART, New Caledonia

WMO: 915730

Lat: 19.721S

Lon: 163.660E

Elev: 276

StdP: 14.55

Time Zone: 11.00 (E11)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	64.0	65.1	35.9	31.2	73.5	50.3	54.5	68.7	23.3	71.9	20.8	72.3	5.3	120	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.2	86.8	78.6	85.9	78.0	85.1	77.4	81.0	84.4	80.1	83.7	79.2	82.9	12.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.1	157.7	82.8	79.0	152.3	82.4	78.1	147.6	81.9	44.9	84.6	44.0	84.0	43.1	83.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.4	21.3	18.6	DB	61.5	88.2	1.8	1.0	60.2	88.9	59.2	89.4	58.2	90.0	56.9	90.7	(4)
(5)			WB	54.2	81.5	3.0	1.6	52.1	82.6	50.3	83.6	48.6	84.5	46.5	85.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.0	80.2	80.9	79.7	77.8	74.7	73.0	70.7	71.2	72.7	75.0	77.0	79.0	(6)	
	DBStd	3.99	1.88	1.64	1.72	1.87	2.01	2.24	1.99	2.40	2.26	2.19	1.97	1.78	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD50	9475	938	865	920	834	766	691	643	656	680	774	809	899	(10)	
	CDD65	4000	473	445	455	384	301	241	178	191	230	309	359	434	(11)	
	CDH74	24509	4358	4373	3971	2602	1025	460	123	237	541	1257	2106	3456	(12)	
	CDH80	3843	967	1044	627	215	24	5	0	2	13	78	239	629	(13)	
(14) Wind	WSAvg	10.8	10.9	10.2	11.4	10.8	10.6	10.8	9.8	10.1	10.3	11.4	11.9	11.2	(14)	
(15) Precipitation	PrecAvg	61.9	7.5	8.6	9.5	7.7	5.7	3.8	3.2	2.7	2.4	2.2	3.9	4.7	(15)	
	PrecMax	100.0	13.4	18.3	22.7	20.7	14.7	7.3	16.4	7.8	6.1	9.8	10.2	12.6	(16)	
	PrecMin	40.9	1.0	2.1	1.3	0.9	1.2	0.7	0.6	0.2	0.1	0.1	0.0	0.9	(17)	
	PrecStd	17.1	3.9	5.3	5.4	5.0	3.3	1.7	3.5	2.1	1.9	2.2	2.8	2.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.9	88.3	86.4	85.1	82.2	80.5	77.7	79.6	81.8	83.3	85.3	86.9	(19)	
		MCWB	79.2	78.9	79.1	77.8	74.8	71.1	70.8	72.2	74.0	74.3	77.3	78.2	(20)	
	2%	DB	86.6	87.0	85.4	83.4	80.6	78.8	76.4	77.7	79.6	81.8	83.6	85.5	(21)	
		MCWB	78.2	78.8	78.3	76.4	73.1	71.9	69.4	70.4	71.6	73.1	75.0	77.2	(22)	
	5%	DB	85.5	86.0	84.4	82.2	79.3	77.7	75.4	76.4	78.2	80.8	82.5	84.5	(23)	
		MCWB	77.5	78.3	77.9	75.3	72.0	70.9	68.3	69.3	70.1	72.1	73.6	76.4	(24)	
	10%	DB	84.6	85.0	83.4	81.1	78.3	76.5	74.4	75.2	77.0	79.6	81.3	83.4	(25)	
		MCWB	76.9	77.6	77.2	74.8	71.3	70.2	67.5	68.4	69.2	71.3	72.7	75.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.7	81.7	83.3	79.2	77.1	76.3	73.5	74.7	75.5	76.4	79.0	80.1	(27)	
		MCDB	85.2	86.0	84.0	83.0	80.2	78.7	76.1	77.2	79.9	81.2	82.9	84.8	(28)	
	2%	WB	80.6	80.8	81.1	78.2	75.5	74.9	71.8	72.6	73.7	74.9	77.4	78.9	(29)	
		MCDB	84.5	85.1	83.1	81.7	78.8	77.3	74.7	75.9	78.0	79.7	81.3	83.7	(30)	
	5%	WB	79.7	79.8	79.9	77.3	74.5	73.6	70.6	71.2	72.2	73.9	76.4	78.0	(31)	
		MCDB	83.5	84.1	82.4	80.7	78.0	76.2	74.2	75.0	76.6	78.7	80.4	82.6	(32)	
	10%	WB	78.7	78.9	78.8	76.4	73.6	72.3	69.2	70.1	70.9	72.9	75.2	77.1	(33)	
		MCDB	82.5	83.1	81.6	79.9	77.3	75.5	73.4	74.0	75.4	77.8	79.5	81.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	8.2	6.9	6.7	6.8	6.3	7.3	7.8	8.5	8.8	8.6	8.6	(35)	
		MCDBR	9.4	9.1	8.3	7.6	7.7	6.9	8.1	8.6	9.2	9.9	9.6	9.9	(36)	
	5% WB	MCWBR	4.3	4.2	4.3	4.1	4.6	4.4	4.8	4.8	4.8	4.7	4.5	4.5	(37)	
		MCWBR	8.6	8.2	7.5	6.9	6.6	5.8	6.5	7.6	8.5	9.1	8.3	8.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.383	0.381	0.381	0.369	0.358	0.354	0.337	0.340	0.355	0.365	0.378	0.375	(40)	
		taud	2.608	2.628	2.636	2.648	2.635	2.638	2.662	2.652	2.574	2.580	2.565	2.611	(41)	
	Ebn at Noon		305	302	295	286	278	273	282	291	298	303	305	308	(42)	
		Edh at Noon	33	32	30	28	27	25	25	28	32	33	34	33	(43)	
(44) All-Sky Solar Radiation	RadAvg		2156	2057	1762	1542	1294	1179	1283	1526	1882	2082	2148	2229	(44)	
	RadStd		174	163	154	140	101	66	81	101	105	130	138	182	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page