

ILE LOOP, New Caledonia

WMO: 915740

Lat: 19.968S

Lon: 158.476E

Elev: 20

StdP: 14.69

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	67.3	68.2	51.8	57.2	70.2	53.8	61.5	70.6	29.2	70.2	27.3	70.8	15.9	140	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.9	86.9	78.7	86.0	78.2	85.2	77.7	80.8	84.4	80.1	83.8	79.5	83.3	10.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.7	154.3	83.0	79.0	150.5	82.8	78.3	147.0	82.5	44.4	84.4	43.7	84.0	43.1	83.3	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 36.7	28.2	25.4	DB	65.1	88.7	2.7	1.7	63.1	90.0	61.6	90.9	60.1	91.9	58.2	93.1	(4)
(5)			WB	57.4	81.8	1.5	1.1	56.3	82.6	55.5	83.2	54.6	83.8	53.5	84.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.2	81.1	81.7	81.3	79.2	76.5	74.1	72.4	72.3	74.0	75.8	77.8	80.0
	DBStd	3.74	1.51	1.58	1.58	1.68	1.67	1.64	1.67	1.72	1.77	1.89	1.59	1.83
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9913	965	888	970	876	823	724	693	692	719	799	835	929
	CDD65	4438	500	468	505	426	358	274	228	227	269	334	385	464
	CDH74	30171	5041	4940	5198	3506	1788	581	198	229	652	1391	2463	4184
	CDH80	4750	1078	1182	1089	339	42	1	0	0	5	68	208	738
Wind	WSAvg	14.9	14.6	16.0	16.3	18.0	15.1	14.9	14.3	13.3	13.2	14.6	13.9	14.3
Precipitation	PrecAvg	39.6	5.4	5.4	7.9	4.1	3.1	2.6	1.5	1.9	1.0	1.6	1.8	3.3
	PrecMax	59.5	14.6	13.3	17.4	11.6	11.3	6.5	6.5	5.9	3.9	7.2	7.8	14.8
	PrecMin	21.6	0.3	0.8	1.2	0.4	0.5	0.1	0.0	0.2	0.0	0.2	0.2	0.2
	PrecStd	9.7	3.8	3.3	4.0	3.0	2.2	1.6	1.5	1.4	1.1	1.7	1.6	3.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.2	88.0	87.3	85.4	82.5	79.4	78.5	78.6	80.7	83.7	84.6	87.7
		MCWB	79.3	79.7	79.2	77.8	75.2	72.9	71.4	71.1	73.1	75.6	75.2	78.4
	2%	DB	86.5	86.6	86.2	84.1	81.2	78.3	77.1	77.3	79.3	81.8	83.4	86.1
		MCWB	78.1	79.1	78.8	77.1	74.3	72.0	70.2	69.8	71.8	74.6	74.2	77.3
	5%	DB	85.5	85.6	85.2	82.9	80.1	77.4	76.0	76.3	78.3	80.5	82.3	84.9
		MCWB	77.5	78.6	78.4	76.1	73.5	71.3	69.2	69.0	70.9	73.2	73.6	76.6
	10%	DB	84.5	84.7	84.2	81.9	79.2	76.7	75.1	75.4	77.3	79.3	81.1	83.6
		MCWB	77.0	78.1	77.9	75.5	72.8	70.6	68.3	68.4	70.1	72.3	73.1	75.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.1	81.8	81.5	79.9	77.8	76.2	73.8	74.2	76.1	77.8	78.8	80.9
		MCDB	84.9	85.1	84.7	82.9	80.6	78.5	76.4	76.3	78.0	80.8	81.4	84.3
	2%	WB	80.1	80.7	80.6	78.6	76.5	74.8	72.4	72.9	74.6	76.6	77.1	79.9
		MCDB	84.2	84.4	84.2	82.0	79.6	77.1	75.7	75.4	77.4	79.6	80.8	83.5
	5%	WB	79.3	80.0	79.9	77.8	75.6	73.4	71.1	71.5	73.3	75.6	76.0	78.9
		MCDB	83.4	83.8	83.5	81.4	78.8	76.4	75.0	74.8	76.8	78.7	79.8	82.9
	10%	WB	78.6	79.4	79.1	77.0	74.5	72.0	69.9	70.2	72.0	74.6	75.1	77.7
		MCDB	82.8	83.3	82.8	80.8	78.1	75.5	74.2	74.3	76.0	77.9	79.0	81.9
Mean Daily Temperature Range	5% DB	MDBR	6.4	5.9	5.6	5.3	4.9	4.6	5.1	5.6	6.4	6.5	6.4	6.5
		MCDBR	7.8	6.8	6.5	6.1	5.7	5.1	5.7	6.3	7.2	7.6	7.7	7.9
		MCWBR	3.7	3.5	3.4	3.5	3.7	3.7	3.7	4.0	4.1	4.1	3.8	3.7
	5% WB	MCDBR	6.6	6.0	6.1	5.6	5.2	4.4	5.4	5.5	5.9	6.6	6.5	6.2
		MCWBR	3.4	3.5	3.5	3.4	3.8	4.2	4.2	4.1	4.2	4.1	3.8	3.7
Clear-Sky Solar Irradiance	taub	0.380	0.381	0.388	0.366	0.351	0.354	0.333	0.337	0.346	0.362	0.367	0.372	
	taud	2.615	2.629	2.604	2.641	2.640	2.626	2.655	2.647	2.585	2.568	2.586	2.614	
	Ebn at Noon	306	302	292	287	279	272	283	292	300	304	308	308	
	Edh at Noon	33	32	31	28	26	26	26	28	31	33	34	33	
All-Sky Solar Radiation	RadAvg	2236	2098	1817	1610	1352	1183	1325	1572	1974	2181	2299	2318	
	RadStd	160	139	147	124	86	81	77	114	84	166	154	186	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page