

ILE LOOP, New Caledonia

WMO: 915740

Lat: 19.968S

Lon: 158.476E

Elev: 6

StdP: 101.25

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.6	20.1	11.0	8.2	21.2	12.1	8.8	21.4	13.1	21.2	12.2	21.5	7.1	140	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.3	30.5	25.9	30.0	25.7	29.5	25.4	27.1	29.1	26.7	28.8	26.4	28.5	4.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	22.0	28.3	26.1	21.5	28.2	25.7	21.0	28.0	85.4	29.1	83.8	28.9	82.4	28.5	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	12.6	11.3	DB	18.4	31.5	1.5	0.9	17.3	32.2	16.4	32.7	15.6	33.3	14.5	34.0	(4)
(5)			WB	14.1	27.7	0.8	0.6	13.5	28.1	13.0	28.5	12.6	28.8	12.0	29.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.1	27.3	27.6	27.4	26.2	24.7	23.4	22.4	22.4	23.3	24.3	25.5	26.6	(6)	
	DBStd	2.08	0.84	0.88	0.88	0.93	0.93	0.91	0.93	0.96	0.99	1.05	0.88	1.02	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	5507	536	493	539	487	457	402	385	384	399	444	464	516	(10)	
	CDD18.3	2466	278	260	281	237	199	152	127	126	149	186	214	258	(11)	
	CDH23.3	16762	2801	2744	2888	1948	993	323	110	127	362	773	1368	2324	(12)	
	CDH26.7	2639	599	657	605	188	23	1	0	3	38	116	410		(13)	
(14) Wind	WSAvg	6.6	6.5	7.2	7.3	8.1	6.8	6.6	6.4	6.0	5.9	6.5	6.2	6.4	(14)	
(15) Precipitation	PrecAvg	1007	138	137	201	103	79	67	39	49	26	40	45	83	(15)	
	PrecMax	1512	370	339	441	295	287	166	165	150	100	182	199	377	(16)	
	PrecMin	548	7	21	31	10	12	2	1	6	1	5	6	6	(17)	
	PrecStd	246	96	84	102	77	56	40	37	36	27	43	40	79	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.2	31.1	30.7	29.7	28.1	26.3	25.8	25.9	27.1	28.7	29.2	31.0	(19)	
		MCWB	26.3	26.5	26.2	25.4	24.0	22.7	21.9	21.7	22.8	24.2	24.0	25.8	(20)	
	2%	DB	30.3	30.3	30.1	29.0	27.3	25.7	25.1	25.2	26.3	27.7	28.6	30.1	(21)	
		MCWB	25.6	26.2	26.0	25.0	23.5	22.2	21.2	21.0	22.1	23.6	23.5	25.2	(22)	
	5%	DB	29.7	29.8	29.6	28.3	26.7	25.2	24.4	24.6	25.7	26.9	27.9	29.4	(23)	
		MCWB	25.3	25.9	25.8	24.5	23.1	21.8	20.7	20.6	21.6	22.9	23.1	24.8	(24)	
	10%	DB	29.1	29.3	29.0	27.7	26.2	24.8	24.0	24.1	25.2	26.3	27.3	28.7	(25)	
		MCWB	25.0	25.6	25.5	24.2	22.7	21.4	20.2	20.2	21.2	22.4	22.9	24.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.3	27.6	27.5	26.6	25.5	24.6	23.2	23.4	24.5	25.4	26.0	27.2	(27)	
		MCDB	29.4	29.5	29.3	28.3	27.0	25.8	24.7	24.6	25.5	27.1	27.4	29.0	(28)	
	2%	WB	26.7	27.1	27.0	25.9	24.7	23.8	22.4	22.7	23.7	24.8	25.1	26.6	(29)	
		MCDB	29.0	29.1	29.0	27.8	26.5	25.1	24.3	24.1	25.2	26.5	27.1	28.6	(30)	
	5%	WB	26.3	26.7	26.6	25.4	24.2	23.0	21.7	21.9	23.0	24.2	24.4	26.1	(31)	
		MCDB	28.6	28.8	28.6	27.4	26.0	24.7	23.9	23.8	24.9	25.9	26.6	28.3	(32)	
	10%	WB	25.9	26.3	26.2	25.0	23.6	22.2	21.0	21.2	22.2	23.7	24.0	25.4	(33)	
		MCDB	28.2	28.5	28.2	27.1	25.6	24.2	23.4	23.5	24.4	25.5	26.1	27.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.5	3.3	3.1	2.9	2.7	2.6	2.8	3.1	3.6	3.6	3.6	3.6	(35)	
		MCDBR	4.3	3.8	3.6	3.4	3.2	2.8	3.2	3.5	4.0	4.2	4.3	4.4	(36)	
	5% WB	MCWBR	2.0	1.9	1.9	1.9	2.1	2.1	2.2	2.3	2.3	2.1	2.0	2.0	(37)	
		MCWBR	3.7	3.3	3.4	3.1	2.9	2.5	3.0	3.3	3.7	3.6	3.6	3.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.380	0.381	0.388	0.366	0.351	0.354	0.333	0.337	0.346	0.362	0.367	0.372	(40)	
		taud	2.615	2.629	2.604	2.641	2.640	2.626	2.655	2.647	2.585	2.568	2.586	2.614	(41)	
	Ebn at Noon		965	952	921	905	881	859	891	920	947	959	970	972	(42)	
		Edh at Noon	103	100	99	89	83	81	81	87	99	105	106	103	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.05	6.61	5.73	5.08	4.26	3.73	4.18	4.96	6.22	6.88	7.25	7.31	(44)	
	RadStd		0.50	0.44	0.46	0.39	0.27	0.26	0.24	0.36	0.27	0.52	0.49	0.59	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page