

KOUMAC, New Caledonia

WMO: 915770

Lat: 20.559S

Lon: 164.284E

Elev: 62

StdP: 14.66

Time Zone: 11.00 (E11)

Period: 95-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	58.8	60.2	49.8	53.1	64.6	51.4	56.4	65.5	23.5	71.7	22.1	72.1	4.0	40	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.0	88.4	77.4	87.0	77.0	86.0	76.6	79.7	85.4	78.9	84.6	78.2	83.7	9.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.0	145.8	83.1	77.2	141.9	82.4	76.5	138.5	81.9	43.3	85.6	42.5	84.8	41.8	83.9	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.8	20.5	18.4	DB	55.6	91.8	2.8	1.5	53.6	92.9	51.9	93.8	50.3	94.6	48.3	95.7	(4)
(5)			WB	52.2	80.9	1.7	1.1	51.0	81.6	49.9	82.2	49.0	82.8	47.7	83.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.7	79.6	80.4	79.3	76.9	73.6	71.1	69.0	68.8	70.7	73.0	75.6	78.2
	DBStd	4.67	2.10	1.95	1.95	2.34	2.65	2.59	2.48	2.83	2.47	2.46	2.28	1.98
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	3	0	0	0	0	0	0	1	2	0	0	0	0
	CDD50	8997	917	852	909	806	732	633	590	583	620	713	767	875
	CDD65	3525	452	432	444	356	267	183	126	120	170	248	317	410
	CDH74	24784	4319	4276	3917	2398	1198	513	225	261	587	1302	2223	3565
	CDH80	5232	1186	1245	931	393	95	25	7	8	25	118	330	869
(14) Wind	WSAvg	7.4	7.5	6.9	7.0	7.2	6.7	6.5	7.1	7.5	7.7	8.5	8.2	7.8
(15) Precipitation	PrecAvg	40.2	6.4	6.3	5.7	3.2	3.0	2.9	2.0	1.7	1.3	1.1	2.0	3.5
	PrecMax	74.1	22.8	18.6	15.7	13.4	19.1	9.8	8.7	7.6	7.3	7.0	7.0	19.3
	PrecMin	18.0	0.0	1.1	0.4	0.0	0.0	0.1	0.0	0.1	0.0	0.0	0.0	0.1
	PrecStd	12.8	5.0	4.5	3.7	2.9	3.1	2.2	1.9	1.6	1.6	1.5	1.8	3.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.7	90.5	88.8	87.8	84.7	82.8	80.8	81.1	82.7	85.4	86.8	88.5
		MCWB	77.0	78.3	78.3	76.5	73.5	73.0	69.7	70.4	70.8	71.7	75.0	76.4
	2%	DB	87.6	88.6	86.9	85.1	82.5	80.1	78.1	78.8	80.3	82.8	84.5	86.4
		MCWB	77.1	78.3	77.8	76.0	73.4	71.3	69.0	69.9	69.9	72.1	73.9	75.8
	5%	DB	86.3	87.0	85.6	83.7	80.8	78.4	76.3	76.8	78.6	81.2	83.1	85.3
		MCWB	76.5	77.9	77.2	75.4	72.6	70.3	67.6	68.3	69.3	71.2	73.1	75.3
	10%	DB	85.2	85.8	84.5	82.3	79.4	76.9	74.9	75.2	77.2	79.8	81.9	84.2
		MCWB	76.0	77.3	76.5	74.7	71.6	68.9	66.4	66.6	68.1	70.2	72.2	74.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.3	80.8	80.4	78.9	76.8	75.0	72.8	73.4	73.6	75.1	77.1	79.0
		MCDB	85.8	86.8	85.8	84.5	80.8	79.9	77.3	77.1	78.8	81.4	83.6	85.2
	2%	WB	79.1	79.8	79.2	77.7	75.3	73.5	71.1	71.4	72.2	73.7	75.7	77.7
		MCDB	84.8	85.8	84.7	82.9	79.6	78.0	76.0	76.5	77.6	80.4	81.7	84.1
	5%	WB	78.2	79.0	78.4	76.9	74.2	72.1	69.5	69.9	70.9	72.5	74.6	76.6
		MCDB	83.9	84.8	83.8	81.7	78.7	76.7	74.1	75.1	76.6	79.3	80.8	83.2
	10%	WB	77.4	78.2	77.6	75.9	73.1	70.6	68.1	68.5	69.6	71.4	73.5	75.7
		MCDB	82.9	83.9	82.7	80.6	77.8	75.4	73.2	73.8	75.5	78.2	80.2	82.3
(35) Mean Daily Temperature Range	5% DB	MDBR	11.1	11.0	10.4	11.1	11.8	11.9	12.3	12.7	13.5	13.1	12.5	11.9
		MCDBR	12.4	12.2	11.5	12.3	12.6	13.2	13.6	13.7	14.2	14.3	13.4	13.1
	5% WB	MCWBR	5.7	5.7	5.3	5.9	6.3	6.9	7.1	7.3	7.6	7.1	6.7	6.1
		MCWBR	10.7	10.9	10.4	10.7	10.4	11.3	11.4	11.3	12.3	12.7	12.1	12.0
(40) Clear-Sky Solar Irradiance	taub	taub	0.382	0.380	0.376	0.363	0.347	0.348	0.328	0.333	0.350	0.364	0.369	0.374
		taud	2.602	2.618	2.644	2.655	2.662	2.638	2.677	2.664	2.573	2.559	2.575	2.601
	Ebn at Noon	Ebn at Noon	305	302	296	287	280	274	284	293	299	304	307	308
		Edh at Noon	33	32	30	28	26	25	25	27	32	34	34	33
(44) All-Sky Solar Radiation	RadAvg	2090	1963	1714	1500	1260	1145	1261	1477	1843	2030	2081	2156	
	RadStd	159	161	144	128	92	63	74	99	89	120	149	166	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page