

ILE LIFOU, New Caledonia

WMO: 915820

Lat: 20.777S

Lon: 167.241E

Elev: 105

StdP: 14.64

Time Zone: 11.00 (E11)

Period: 96-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	51.2	53.9	49.4	52.5	56.4	51.4	56.6	60.3	20.4	72.9	18.9	73.0	0.8	190	0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.3	86.8	78.1	85.9	77.7	84.9	77.0	80.1	84.2	79.3	83.5	78.7	83.0	10.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.0	151.2	82.6	78.2	146.8	82.0	77.3	142.8	81.5	43.9	84.6	43.1	83.6	42.4	83.2	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.9	18.4	16.9	45.7	89.1	2.1	1.7	44.2	90.4	43.0	91.4	41.8	92.3	40.3	93.6		
(5)			45.3	81.2	2.0	0.8	43.8	81.8	42.6	82.3	41.5	82.8	40.0	83.3	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.9	78.9	79.7	78.7	76.7	72.9	70.6	68.1	67.9	69.8	72.4	74.7	77.3
	DBStd	5.17	2.37	2.29	2.06	2.79	3.33	3.56	3.84	4.20	3.74	3.10	3.11	2.52
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	49	0	0	0	0	1	3	17	22	5	1	0	0
	CDD50	8734	895	832	891	801	710	617	560	554	595	694	740	845
	CDD65	3306	430	412	426	351	245	170	112	111	150	229	290	380
	CDH74	22091	3920	3964	3639	2484	1057	429	187	227	464	980	1715	3025
	CDH80	3660	879	968	709	306	36	5	0	3	17	35	156	546
Wind	WSAvg	8.6	9.3	8.8	8.7	8.3	7.9	7.7	7.5	7.6	8.5	10.0	9.6	9.2
Precipitation	PrecAvg	66.7	7.6	10.0	9.6	5.4	5.0	5.7	4.1	3.4	2.7	2.7	4.3	6.1
	PrecMax	111.9	22.7	23.6	24.0	19.2	19.2	12.5	10.9	9.3	9.3	13.5	13.6	19.3
	PrecMin	30.8	1.2	2.8	1.5	0.6	0.5	1.6	0.2	0.0	0.2	0.2	0.6	0.1
	PrecStd	20.6	5.6	6.4	5.8	4.4	4.4	3.3	2.8	2.4	2.3	2.6	3.3	5.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.9	89.0	87.3	85.9	82.6	80.7	79.0	80.1	82.3	82.7	84.6	86.7
		MCWB	77.9	78.9	79.0	78.2	75.3	74.2	71.9	72.2	73.0	72.7	74.7	76.6
	2%	DB	86.3	87.1	86.0	84.3	81.0	79.0	77.3	77.7	79.3	80.9	82.9	85.3
		MCWB	77.7	78.5	78.6	77.1	74.0	72.3	70.0	70.4	70.8	71.6	74.0	76.1
	5%	DB	85.3	85.9	84.8	83.0	79.8	77.6	75.9	76.4	77.9	79.7	81.9	84.2
		MCWB	77.1	78.0	77.8	76.0	72.9	71.0	68.5	69.0	69.6	70.9	73.3	75.7
	10%	DB	84.2	84.7	83.8	81.8	78.7	76.5	74.9	75.1	76.7	78.7	80.6	83.1
		MCWB	76.3	77.3	77.1	75.1	71.9	70.2	67.5	67.6	68.5	70.2	72.2	74.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.2	81.7	81.2	79.5	77.1	76.3	74.7	74.5	75.2	75.5	77.6	79.0
		MCDB	85.0	85.1	84.5	83.3	80.2	79.1	76.4	77.4	79.5	79.5	81.3	83.5
	2%	WB	79.4	80.5	79.9	78.4	75.9	74.6	72.5	72.6	73.5	74.2	76.3	78.1
		MCDB	84.0	84.6	83.7	82.4	78.9	77.2	75.6	75.9	77.2	78.2	80.3	82.7
	5%	WB	78.7	79.5	79.0	77.5	75.0	73.5	71.1	71.1	72.1	73.1	75.2	77.2
		MCDB	83.2	83.7	83.1	81.3	77.9	76.1	74.3	74.7	75.8	77.3	79.7	82.0
	10%	WB	78.0	78.7	78.2	76.6	74.1	72.0	69.7	69.7	70.7	72.0	74.1	76.4
		MCDB	82.3	83.1	82.2	80.2	77.3	75.2	73.0	73.7	74.7	76.7	78.8	81.0
Mean Daily Temperature Range	5% DB	MDBR	10.6	10.3	9.8	10.2	11.5	11.7	13.8	14.2	13.7	12.4	11.8	11.2
		MCDBR	11.9	11.8	11.6	11.5	12.5	12.7	14.8	14.1	15.1	14.0	12.8	13.0
		MCWBR	5.5	5.5	6.0	6.2	7.1	7.7	8.8	8.3	8.5	7.2	6.2	6.1
	5% WB	MCDBR	10.1	10.2	10.4	9.5	9.4	9.6	11.0	11.4	11.3	11.1	10.2	10.7
		MCWBR	5.1	5.2	5.8	5.6	6.0	6.5	7.6	7.3	7.0	6.3	5.4	5.4
Clear-Sky Solar Irradiance	taub	0.390	0.387	0.388	0.375	0.364	0.358	0.338	0.345	0.357	0.368	0.375	0.381	
	taud	2.582	2.598	2.602	2.622	2.616	2.619	2.652	2.630	2.570	2.559	2.568	2.580	
	Ebn at Noon	303	300	292	283	274	270	280	289	297	302	305	305	
	Edh at Noon	34	33	31	29	27	26	25	28	32	34	34	34	
All-Sky Solar Radiation	RadAvg	2106	2013	1704	1465	1215	1098	1201	1437	1775	1993	2094	2192	
	RadStd	167	152	113	130	96	84	80	89	125	110	124	153	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page