

ILE LIFOU, New Caledonia

WMO: 915820

Lat: 20.777S

Lon: 167.241E

Elev: 32

StdP: 100.94

Time Zone: 11.00 (E11)

Period: 96-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	12.1	9.7	7.5	13.5	10.8	8.1	15.7	9.1	22.7	8.4	22.8	0.3	190	0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.7	30.5	25.6	29.9	25.4	29.4	25.0	26.7	29.0	26.3	28.6	25.9	28.3	4.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.6	28.1	25.6	21.0	27.8	25.2	20.4	27.5	84.3	29.2	82.3	28.7	80.6	28.5	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	8.2	7.5	DB	7.6	31.7	1.2	1.0	6.8	32.4	6.1	33.0	5.5	33.5	4.6	34.2	(4)
(5)			WB	7.4	27.3	1.1	0.5	6.6	27.7	5.9	27.9	5.3	28.2	4.5	28.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.3	26.0	26.5	26.0	24.8	22.7	21.4	20.0	19.9	21.0	22.4	23.7	25.2	(6)	
	DBStd	2.87	1.32	1.27	1.15	1.55	1.85	1.98	2.13	2.33	2.08	1.72	1.73	1.40	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	27	0	0	0	0	1	2	9	12	3	1	0	0	(9)	
	CDD10.0	4852	497	462	495	445	394	343	311	308	331	386	411	469	(10)	
	CDD18.3	1837	239	229	237	195	136	94	62	62	83	127	161	211	(11)	
	CDH23.3	12273	2178	2202	2022	1380	587	238	104	126	258	544	953	1681	(12)	
(13)	CDH26.7	2033	488	538	394	170	20	3	0	2	9	19	87	303	(13)	
(14)	Wind	WSAvg	3.8	4.2	3.9	3.9	3.7	3.5	3.4	3.4	3.8	4.5	4.3	4.1	(14)	
(15) Precipitation	PrecAvg	1694	194	254	244	137	128	145	103	86	68	69	110	155	(15)	
	PrecMax	2841	576	599	610	487	488	318	277	235	236	343	345	489	(16)	
	PrecMin	782	30	71	38	15	12	41	4	0	4	4	15	2	(17)	
	PrecStd	523	142	162	148	112	111	83	72	60	58	67	84	143	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	31.6	30.7	30.0	28.1	27.1	26.1	26.7	27.9	28.1	29.2	30.4	(19)	
		MCWB	25.5	26.1	26.1	25.7	24.1	23.4	22.2	22.3	22.8	22.6	23.7	24.8	(20)	
	2%	DB	30.2	30.6	30.0	29.0	27.2	26.1	25.1	25.4	26.3	27.1	28.3	29.6	(21)	
		MCWB	25.4	25.9	25.9	25.0	23.3	22.4	21.1	21.3	21.6	22.0	23.4	24.5	(22)	
	5%	DB	29.6	29.9	29.3	28.3	26.6	25.3	24.4	24.7	25.5	26.5	27.7	29.0	(23)	
		MCWB	25.0	25.5	25.4	24.4	22.7	21.7	20.3	20.6	20.9	21.6	22.9	24.3	(24)	
	10%	DB	29.0	29.3	28.8	27.7	25.9	24.7	23.8	24.0	24.8	25.9	27.0	28.4	(25)	
		MCWB	24.6	25.1	25.0	23.9	22.2	21.2	19.7	19.8	20.3	21.2	22.3	23.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	27.6	27.3	26.4	25.1	24.6	23.7	23.6	24.0	24.2	25.4	26.1	(27)	
		MCDB	29.5	29.5	29.2	28.5	26.8	26.1	24.7	25.2	26.4	26.4	27.4	28.6	(28)	
	2%	WB	26.3	26.9	26.6	25.8	24.4	23.7	22.5	22.5	23.1	23.4	24.6	25.6	(29)	
		MCDB	28.9	29.2	28.7	28.0	26.1	25.1	24.2	24.4	25.1	25.7	26.9	28.2	(30)	
	5%	WB	25.9	26.4	26.1	25.3	23.9	23.0	21.7	21.7	22.3	22.9	24.0	25.1	(31)	
		MCDB	28.4	28.7	28.4	27.4	25.5	24.5	23.5	23.7	24.4	25.1	26.5	27.8	(32)	
	10%	WB	25.5	26.0	25.7	24.8	23.4	22.2	20.9	21.0	21.5	22.2	23.4	24.7	(33)	
		MCDB	27.9	28.4	27.9	26.8	25.1	24.0	22.8	23.2	23.7	24.8	26.0	27.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	5.7	5.5	5.7	6.4	6.5	7.7	7.9	7.6	6.9	6.5	6.2	(35)	
		MCDBR	6.6	6.6	6.4	6.4	6.9	7.0	8.2	7.8	8.4	7.8	7.1	7.2	(36)	
	5% WB	MCWBR	3.1	3.0	3.3	3.4	3.9	4.3	4.9	4.6	4.7	4.0	3.4	3.4	(37)	
		MCWBR	5.6	5.6	5.8	5.3	5.2	5.4	6.1	6.3	6.3	6.2	5.7	6.0	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.390	0.387	0.388	0.375	0.364	0.358	0.338	0.345	0.357	0.368	0.375	0.381	(40)	
		taud	2.582	2.598	2.602	2.622	2.616	2.619	2.652	2.630	2.570	2.559	2.568	2.580	(41)	
	Ebn at Noon	Ebn at Noon	955	946	920	893	865	852	884	910	935	952	963	963	(42)	
		Edh at Noon	107	103	99	91	85	81	80	88	100	106	107	107	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.64	6.34	5.37	4.62	3.83	3.46	3.79	4.53	5.60	6.28	6.60	6.91	(44)	
	RadStd	RadStd	0.53	0.48	0.36	0.41	0.30	0.26	0.25	0.28	0.39	0.35	0.39	0.48	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page