

POINDIMIE, New Caledonia

WMO: 915830

Lat: 20.933S

Lon: 165.328E

Elev: 46

StdP: 14.67

Time Zone: 11.00 (E11)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	59.7	61.2	50.4	54.2	66.5	51.7	57.0	66.3	13.1	73.9	11.7	73.3	2.4	180	0.235

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.3	87.2	78.0	86.0	77.7	85.1	77.1	80.2	84.8	79.4	83.9	78.7	83.2	5.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	150.5	83.4	78.1	146.1	82.6	77.3	142.2	81.9	44.0	84.9	43.1	84.2	42.3	83.3	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.2	11.5	10.0	DB	57.3	90.2	1.6	1.2	56.1	91.0	55.2	91.7	54.3	92.3	53.2	93.2
			WB	53.3	81.7	1.5	1.3	52.2	82.7	51.3	83.5	50.5	84.2	49.4	85.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.9	79.3	80.1	79.4	77.4	74.2	71.7	69.7	69.7	71.2	73.2	75.0	77.8
	DBStd	4.26	1.94	1.81	1.86	2.06	2.31	2.42	2.24	2.54	2.31	2.32	2.14	1.96
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDD50	9075	908	843	910	821	752	651	611	610	637	720	751	861
	CDD65	3602	443	423	445	371	287	201	146	146	188	255	301	396
	CDH74	22287	3948	3989	3790	2445	1168	459	227	229	471	978	1577	3006
	CDH80	3748	877	963	818	350	68	9	1	4	11	39	115	493
(14) Wind	WSAvg	4.5	4.8	4.6	4.4	4.3	4.0	4.1	4.0	4.2	4.8	5.1	5.0	4.7
(15) Precipitation	PrecAvg	101.0	14.6	14.3	15.6	9.0	5.9	8.3	5.7	3.9	3.8	4.4	7.5	7.8
	PrecMax	175.7	29.4	45.3	29.9	38.7	18.7	28.7	15.5	9.4	10.6	13.7	20.6	18.9
	PrecMin	56.2	1.7	5.7	3.9	1.7	2.2	1.3	0.4	0.2	0.1	0.7	0.7	1.6
	PrecStd	29.6	7.4	8.5	7.8	8.8	3.7	6.5	4.6	2.9	2.8	3.7	4.8	4.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.3	88.9	88.2	86.3	83.6	81.2	79.5	80.1	81.7	82.8	84.5	86.5
		MCWB	77.6	78.2	79.1	77.5	73.8	72.7	69.6	70.3	71.9	72.9	74.1	76.9
	2%	DB	86.6	87.0	86.6	84.5	81.8	79.3	77.7	77.9	79.5	81.0	82.5	85.0
		MCWB	77.3	78.2	78.3	76.2	73.3	71.2	68.2	68.9	70.4	72.4	73.8	76.4
	5%	DB	85.3	85.9	85.4	83.4	80.5	78.0	76.5	76.4	78.1	79.8	81.3	83.8
		MCWB	76.9	78.2	77.6	75.4	72.3	70.3	67.2	68.1	69.6	71.6	73.1	76.0
	10%	DB	84.1	84.8	84.2	82.1	79.1	76.7	75.2	75.1	76.7	78.5	80.1	82.7
		MCWB	76.2	77.7	76.8	74.5	71.5	69.5	66.5	67.1	68.6	70.6	72.3	75.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.9	81.6	81.0	80.0	76.9	75.8	73.8	73.9	75.4	75.8	78.1	79.2
		MCDB	85.7	85.9	86.0	84.6	81.2	78.9	76.9	77.1	79.6	80.2	81.6	84.1
	2%	WB	79.6	80.4	79.9	78.3	75.6	74.4	71.9	72.0	73.1	74.5	76.1	78.2
		MCDB	84.1	84.6	84.8	82.6	79.5	77.6	74.7	75.9	77.2	79.1	80.4	82.9
	5%	WB	78.6	79.6	78.9	77.2	74.7	72.9	70.2	70.4	71.7	73.3	74.9	77.3
		MCDB	83.0	83.9	83.7	81.4	78.4	76.3	73.6	74.6	75.8	78.0	79.5	82.0
	10%	WB	77.7	78.8	78.0	76.1	73.7	71.3	68.8	69.1	70.4	72.1	73.7	76.5
		MCDB	82.2	83.2	82.5	80.4	77.4	75.0	73.0	73.4	74.7	76.9	78.4	81.1
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	9.3	9.5	9.8	10.3	10.3	11.5	11.5	11.1	10.3	9.8	9.5
		MCDBR	11.3	10.9	11.3	11.2	11.6	11.8	13.1	12.6	12.8	11.6	11.3	10.9
		MCWBR	5.4	5.5	5.5	5.5	5.9	6.2	6.8	6.5	6.7	5.6	5.9	5.2
	5% WB	MCDBR	9.5	9.6	10.2	9.2	8.7	8.6	9.0	9.8	10.3	9.8	9.8	9.6
		MCWBR	5.1	5.4	5.4	5.1	5.1	5.5	5.9	5.9	5.9	5.1	5.6	5.0
(40) Clear-Sky Solar Irradiance	taub	0.383	0.380	0.376	0.366	0.349	0.347	0.328	0.334	0.349	0.365	0.371	0.377	(40)
	taud	2.588	2.608	2.631	2.636	2.646	2.638	2.670	2.653	2.573	2.550	2.555	2.579	(41)
	Ebn at Noon	305	302	295	286	279	274	284	292	299	303	306	307	(42)
	Edh at Noon	34	32	30	28	26	25	25	27	32	34	35	34	(43)
(44) All-Sky Solar Radiation	RadAvg	2082	1944	1684	1454	1215	1105	1217	1439	1800	1997	2073	2151	(44)
	RadStd	168	162	135	126	97	67	82	98	98	110	137	159	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page