

POINDIMIE, New Caledonia

WMO: 915830

Lat: 20.933S

Lon: 165.328E

Elev: 14

StdP: 101.16

Time Zone: 11.00 (E11)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	16.2	10.2	7.7	19.2	10.9	8.1	19.1	5.8	23.3	5.2	23.0	1.1	180	0.235

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.2	30.6	25.5	30.0	25.4	29.5	25.0	26.8	29.3	26.3	28.8	25.9	28.4	2.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.5	28.5	25.6	20.9	28.1	25.2	20.3	27.7	84.5	29.4	82.3	29.0	80.5	28.5	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.9	5.1	4.4	14.0	32.3	0.9	0.6	13.4	32.8	12.9	33.2	12.4	33.5	11.8	34.0		
			11.8	27.6	0.8	0.7	11.2	28.2	10.7	28.6	10.3	29.0	9.7	29.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.8	26.3	26.7	26.3	25.2	23.5	22.0	20.9	20.9	21.8	22.9	23.9	25.4
	DBStd	2.37	1.08	1.00	1.04	1.15	1.28	1.35	1.25	1.41	1.28	1.29	1.19	1.09
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDD10.0	5042	504	468	506	456	418	362	339	339	354	400	417	478
	CDD18.3	2001	246	235	247	206	159	112	81	81	104	142	167	220
	CDH23.3	12382	2193	2216	2106	1358	649	255	126	127	262	543	876	1670
(14) Wind	WSAvg	2.0	2.2	2.1	2.0	1.9	1.8	1.8	1.8	1.9	2.1	2.3	2.2	2.1
	PrecAvg	2565	370	364	396	228	151	212	145	100	97	113	190	199
	PrecMax	4463	748	1151	760	982	474	728	393	238	269	349	522	480
	PrecMin	1427	43	146	98	42	57	33	11	4	2	17	18	41
	PrecStd	753	188	217	197	223	94	165	117	73	70	95	121	112
	DB	31.3	31.6	31.2	30.2	28.7	27.3	26.4	26.7	27.6	28.2	29.2	30.3	(19)
	MCWB	25.3	25.7	26.2	25.3	23.2	22.6	20.9	21.3	22.2	22.7	23.4	24.9	(20)
(22) Mean Coincident Wet Bulb Temperatures	DB	30.3	30.6	30.4	29.2	27.7	26.3	25.4	25.5	26.4	27.2	28.1	29.4	(21)
	MCWB	25.2	25.7	25.7	24.6	23.0	21.8	20.1	20.5	21.4	22.4	23.2	24.6	(22)
	DB	29.6	29.9	29.7	28.6	26.9	25.6	24.7	24.7	25.6	26.5	27.4	28.8	(23)
	MCWB	24.9	25.7	25.3	24.1	22.4	21.3	19.5	20.0	20.9	22.0	22.9	24.4	(24)
	DB	29.0	29.3	29.0	27.9	26.2	24.8	24.0	23.9	24.9	25.8	26.7	28.2	(25)
	MCWB	24.6	25.4	24.9	23.6	21.9	20.8	19.2	19.5	20.3	21.4	22.4	24.0	(26)
	WB	27.2	27.6	27.2	26.6	25.0	24.3	23.2	23.3	24.1	24.3	25.6	26.2	(27)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	29.8	30.0	30.0	29.2	27.3	26.0	25.0	25.1	26.5	26.8	27.6	28.9	(28)
	WB	26.4	26.9	26.6	25.7	24.2	23.5	22.2	22.2	22.9	23.6	24.5	25.7	(29)
	MCDB	28.9	29.2	29.4	28.1	26.4	25.3	23.7	24.4	25.1	26.2	26.9	28.3	(30)
	WB	25.9	26.4	26.1	25.1	23.7	22.7	21.2	21.4	22.1	23.0	23.8	25.2	(31)
	MCDB	28.4	28.8	28.7	27.4	25.8	24.6	23.1	23.7	24.3	25.6	26.4	27.8	(32)
	WB	25.4	26.0	25.6	24.5	23.2	21.8	20.5	20.6	21.3	22.3	23.2	24.7	(33)
	MCDB	27.9	28.4	28.1	26.9	25.2	23.9	22.8	23.0	23.7	24.9	25.8	27.3	(34)
(35) Mean Daily Temperature Range	MDBR	5.3	5.2	5.3	5.4	5.7	5.7	6.4	6.4	6.1	5.7	5.5	5.3	(35)
	5% DB	6.3	6.1	6.3	6.2	6.5	6.5	7.3	7.0	7.1	6.4	6.3	6.1	(36)
	MCWBR	3.0	3.1	3.1	3.1	3.3	3.4	3.8	3.6	3.7	3.1	3.3	2.9	(37)
	5% WB	5.3	5.3	5.7	5.1	4.9	4.8	5.0	5.4	5.7	5.5	5.4	5.3	(38)
	MCWBR	2.8	3.0	3.0	2.8	2.8	3.1	3.3	3.3	3.3	2.9	3.1	2.8	(39)
(40) Clear-Sky Solar Irradiance	taub	0.383	0.380	0.376	0.366	0.349	0.347	0.328	0.334	0.349	0.365	0.371	0.377	(40)
	taud	2.588	2.608	2.631	2.636	2.646	2.638	2.670	2.653	2.573	2.550	2.555	2.579	(41)
	Ebn at Noon	961	952	931	902	880	863	894	922	943	956	966	968	(42)
	Edh at Noon	106	102	96	89	82	79	79	86	100	107	109	107	(43)
(44) All-Sky Solar Radiation	RadAvg	6.56	6.13	5.31	4.58	3.83	3.48	3.84	4.54	5.67	6.30	6.54	6.78	(44)
	RadStd	0.53	0.51	0.43	0.40	0.31	0.21	0.26	0.31	0.31	0.35	0.43	0.50	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page