

ILE DE MARE, New Caledonia

WMO: 915870

Lat: 21.481S

Lon: 168.036E

Elev: 157

StdP: 14.61

Time Zone: 11.00 (E11)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	48.6	51.0	46.4	46.8	51.0	48.7	51.1	54.2	18.6	73.1	17.2	72.8	2.7	260	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.5	86.3	77.4	85.3	76.8	84.4	76.2	79.9	83.7	79.1	83.0	78.3	82.2	10.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.7	149.8	82.5	77.9	145.7	81.8	77.1	141.9	81.1	43.6	83.8	42.8	83.3	42.0	82.3	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.5	16.6	15.4	DB	44.1	88.2	1.4	1.6	43.1	89.4	42.2	90.3	41.4	91.2	40.4	92.4	(4)
(5)			WB	43.5	81.1	1.4	1.0	42.4	81.9	41.6	82.5	40.8	83.0	39.7	83.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.9	77.4	78.5	77.5	74.9	71.2	68.6	66.2	65.6	67.0	69.7	72.2	75.1	(6)	
	DBStd	5.55	2.87	2.64	2.43	3.05	3.77	3.61	3.76	4.05	3.75	3.31	3.48	3.15	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	114	0	0	0	0	2	10	32	44	22	4	0	0	(9)	
	CDD50	8011	848	798	852	746	657	558	503	484	510	611	667	777	(10)	
	CDD65	2649	383	378	387	296	194	117	70	63	82	150	217	312	(11)	
	CDH74	17723	3328	3496	3151	1868	789	270	105	131	255	648	1276	2406	(12)	
	CDH80	2805	683	812	586	207	24	4	0	1	4	11	92	381	(13)	
(14) Wind	WSAvg	7.6	8.5	8.4	7.7	7.6	7.2	6.9	6.6	6.8	7.5	8.0	8.1	8.2	(14)	
(15) Precipitation	PrecAvg	63.0	7.2	7.4	10.2	6.2	5.7	4.8	4.2	3.1	2.9	3.3	3.8	5.2	(15)	
	PrecMax	96.4	18.2	30.1	19.5	19.4	14.2	9.6	17.8	8.1	14.1	7.8	18.0	18.1	(16)	
	PrecMin	41.9	1.4	0.6	2.3	0.2	0.6	0.9	0.6	0.6	0.1	0.5	0.6	0.5	(17)	
	PrecStd	14.3	5.0	6.0	4.7	4.4	3.9	2.4	3.8	1.9	3.1	2.4	3.8	4.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.2	88.0	87.0	85.6	82.2	80.3	78.5	79.1	80.1	81.4	83.7	86.0	(19)	
		MCWB	77.6	78.5	78.1	77.5	74.4	72.8	70.6	70.6	70.5	71.2	73.5	75.7	(20)	
	2%	DB	85.6	86.5	85.5	83.6	80.6	78.3	76.4	76.9	78.0	79.9	82.3	84.6	(21)	
		MCWB	77.1	77.7	77.3	75.5	73.4	71.1	68.8	69.3	68.7	70.7	73.2	75.3	(22)	
	5%	DB	84.6	85.5	84.4	82.3	79.2	76.9	75.0	75.4	76.7	78.8	81.0	83.4	(23)	
		MCWB	76.2	77.2	76.7	74.7	72.1	70.0	67.6	68.0	67.7	70.1	72.4	74.5	(24)	
	10%	DB	83.6	84.4	83.2	81.0	77.9	75.5	73.8	74.0	75.4	77.6	79.7	82.3	(25)	
		MCWB	75.4	76.5	76.0	73.9	71.1	69.0	66.7	66.5	66.9	69.1	71.3	73.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.3	81.7	80.5	78.9	76.5	75.8	73.7	74.1	74.1	75.2	77.3	78.9	(27)	
		MCDB	84.5	85.9	84.5	82.9	79.8	77.8	76.0	76.6	76.7	79.0	80.5	83.1	(28)	
	2%	WB	79.2	80.1	79.4	77.8	75.2	73.8	71.9	71.9	72.3	73.5	75.9	77.6	(29)	
		MCDB	83.2	83.8	83.3	81.7	78.4	76.3	74.8	75.1	75.3	76.9	79.5	82.1	(30)	
	5%	WB	78.4	79.2	78.5	76.7	74.2	72.2	70.3	70.3	70.7	72.3	74.3	76.5	(31)	
		MCDB	82.3	83.1	82.4	80.5	77.5	75.1	73.3	73.8	74.1	76.2	78.6	81.0	(32)	
	10%	WB	77.4	78.4	77.6	75.5	73.0	70.7	68.7	68.6	69.3	71.1	73.1	75.5	(33)	
		MCDB	81.5	82.4	81.4	79.3	76.5	74.0	72.0	72.4	73.2	75.6	78.0	79.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	11.5	11.4	12.1	13.5	14.0	15.6	17.0	17.3	15.5	14.4	13.8	(35)	
		MCDBR	13.4	13.1	13.5	13.9	14.3	16.0	17.3	18.2	19.6	18.3	15.8	16.1	(36)	
	5% WB	MCWBR	6.6	6.7	7.5	7.9	8.4	9.9	10.5	11.2	11.8	10.4	8.2	8.3	(37)	
		MCWBR	10.4	10.6	11.4	11.4	10.7	11.4	11.7	13.6	13.7	13.4	12.4	11.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.387	0.383	0.380	0.370	0.355	0.351	0.333	0.338	0.352	0.361	0.367	0.371	(40)	
		taud	2.578	2.602	2.621	2.631	2.634	2.627	2.660	2.641	2.575	2.572	2.579	2.605	(41)	
	Ebn at Noon		304	301	294	285	277	272	281	290	298	304	308	309	(42)	
		Edh at Noon	34	33	31	28	26	25	25	28	32	33	34	33	(43)	
(44) All-Sky Solar Radiation	RadAvg		2138	2055	1711	1460	1207	1075	1184	1415	1775	1988	2134	2217	(44)	
	RadStd		162	146	113	140	97	85	80	103	117	102	124	158	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page