

ILE DE MARE, New Caledonia

WMO: 915870

Lat: 21.481S

Lon: 168.036E

Elev: 48

StdP: 100.75

Time Zone: 11.00 (E11)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	10.6	8.0	6.7	10.6	9.3	7.3	12.3	8.3	22.8	7.7	22.7	1.2	260	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.4	30.2	25.2	29.6	24.9	29.1	24.6	26.6	28.7	26.1	28.3	25.7	27.9	4.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.4	28.0	25.5	20.8	27.6	25.1	20.3	27.3	83.6	28.8	81.7	28.5	79.8	28.0	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
8.3	7.4	6.9	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			6.7	31.2	0.8	0.9	6.1	31.9	5.7	32.4	5.2	32.9	4.7	33.5
			6.4	27.3	0.8	0.6	5.8	27.7	5.3	28.0	4.9	28.4	4.3	28.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.2	25.2	25.8	25.3	23.8	21.8	20.3	19.0	18.7	19.5	21.0	22.4	23.9	(6)	
	DBStd	3.08	1.59	1.47	1.35	1.69	2.10	2.01	2.09	2.25	2.08	1.84	1.93	1.75	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	63	0	0	0	0	1	6	18	24	12	2	0	0	(9)	
	CDD10.0	4451	471	443	473	414	365	310	279	269	283	339	371	432	(10)	
	CDD18.3	1472	213	210	215	164	108	65	39	35	46	83	121	173	(11)	
	CDH23.3	9846	1849	1942	1751	1038	438	150	58	73	142	360	709	1337	(12)	
(13)	CDH26.7	1558	379	451	326	115	13	2	0	1	2	6	51	212	(13)	
(14)	Wind	WSAvg	3.4	3.8	3.8	3.4	3.4	3.2	3.1	3.0	3.0	3.3	3.6	3.6	(14)	
(15) Precipitation	PrecAvg	1601	182	188	258	158	144	123	106	78	74	83	96	131	(15)	
	PrecMax	2448	462	764	495	492	360	244	451	206	358	197	458	460	(16)	
	PrecMin	1064	35	14	58	6	16	23	15	15	3	13	14	12	(17)	
	PrecStd	362	126	153	120	111	99	60	97	48	80	60	97	124	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.6	31.1	30.5	29.8	27.9	26.8	25.8	26.1	26.7	27.5	28.7	30.0	(19)	
		MCWB	25.3	25.9	25.6	25.3	23.6	22.7	21.4	21.4	21.4	21.8	23.1	24.3	(20)	
	2%	DB	29.8	30.3	29.7	28.7	27.0	25.7	24.7	24.9	25.5	26.6	27.9	29.2	(21)	
		MCWB	25.1	25.4	25.1	24.2	23.0	21.7	20.5	20.7	20.4	21.5	22.9	24.0	(22)	
	5%	DB	29.2	29.7	29.1	28.0	26.2	24.9	23.9	24.1	24.8	26.0	27.2	28.6	(23)	
		MCWB	24.6	25.1	24.8	23.7	22.3	21.1	19.8	20.0	19.8	21.2	22.4	23.6	(24)	
	10%	DB	28.6	29.1	28.5	27.2	25.5	24.2	23.2	23.3	24.1	25.3	26.5	27.9	(25)	
		MCWB	24.1	24.7	24.4	23.3	21.7	20.6	19.3	19.2	19.4	20.6	21.9	23.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	27.6	26.9	26.0	24.7	24.3	23.2	23.4	23.4	24.0	25.2	26.1	(27)	
		MCDB	29.1	29.9	29.2	28.3	26.6	25.4	24.4	24.8	24.8	26.1	26.9	28.4	(28)	
	2%	WB	26.2	26.7	26.3	25.4	24.0	23.2	22.2	22.1	22.4	23.1	24.4	25.3	(29)	
		MCDB	28.5	28.8	28.5	27.6	25.8	24.6	23.8	24.0	24.0	25.0	26.4	27.8	(30)	
	5%	WB	25.8	26.2	25.9	24.8	23.5	22.3	21.3	21.3	21.5	22.4	23.5	24.7	(31)	
		MCDB	28.0	28.4	28.0	26.9	25.3	23.9	22.9	23.2	23.4	24.6	25.9	27.2	(32)	
	10%	WB	25.2	25.8	25.4	24.2	22.8	21.5	20.4	20.4	20.7	21.7	22.8	24.2	(33)	
		MCDB	27.5	28.0	27.5	26.3	24.7	23.3	22.2	22.4	22.9	24.2	25.5	26.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.7	6.4	6.3	6.7	7.5	7.8	8.7	9.4	9.6	8.6	8.0	7.7	(35)	
		MCDBR	7.5	7.3	7.5	7.7	7.9	8.9	9.6	10.1	10.9	10.2	8.8	8.9	(36)	
	5% WB	MCWBR	3.7	3.7	4.1	4.4	4.7	5.5	5.8	6.2	6.5	5.8	4.6	4.6	(37)	
		MCWBR	5.8	5.9	6.4	6.3	5.9	6.3	6.5	7.6	7.6	7.4	6.9	6.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.387	0.383	0.380	0.370	0.355	0.351	0.333	0.338	0.352	0.361	0.367	0.371	(40)	
		taud	2.578	2.602	2.621	2.631	2.634	2.627	2.660	2.641	2.575	2.572	2.579	2.605	(41)	
	Ebn at Noon	Ebn at Noon	957	949	927	897	872	856	887	915	940	959	971	973	(42)	
		Edh at Noon	107	103	97	89	82	80	79	87	100	105	106	104	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.74	6.48	5.39	4.60	3.81	3.39	3.73	4.46	5.60	6.27	6.73	6.99	(44)	
	RadStd	RadStd	0.51	0.46	0.35	0.44	0.31	0.27	0.25	0.33	0.37	0.32	0.39	0.50	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page