

LA TONTOUTA, New Caledonia

WMO: 915900

Lat: 22.017S

Lon: 166.222E

Elev: 11

StdP: 101.19

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 12.3	(c) 13.2	(d) 9.1	(e) 7.2	(f) 17.9	(g) 9.9	(h) 7.6	(i) 17.6	(j) 9.9	(k) 22.1	(l) 9.1	(m) 22.0	(n) 0.9	(o) 140	(p) 0.317

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 8.8	(c) 33.9	(d) 24.6	(e) 32.9	(f) 24.3	(g) 32.0	(h) 23.9	(i) 26.5	(j) 31.1	(k) 25.9	(l) 30.3	(m) 25.4	(n) 29.6	(o) 5.0	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 25.1	(b) 20.3	(c) 28.7	(d) 24.7	(e) 19.7	(f) 28.1	(g) 24.1	(h) 19.1	(i) 27.4	(j) 82.8	(k) 31.3	(l) 80.1	(m) 30.5	(n) 77.9	(o) 29.4	(p) 28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 10.1	(b) 8.9	(c) 7.8	(e) 10.1	(f) 35.9	(g) 1.3	(h) 1.0	(i) 9.2	(j) 36.7	(k) 8.4	(l) 37.3	(m) 7.7	(n) 37.9	(o) 6.8	(p) 38.6		
			DB			1.1	0.7	8.6	28.1	8.0	28.5	7.4	28.9	6.6	29.5	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.3	26.5	26.7	26.1	24.4	22.3	20.7	19.5	19.5	20.9	22.7	24.2	25.9
	DBStd	3.11	1.60	1.61	1.56	1.65	1.78	1.73	1.60	1.75	1.82	1.87	1.76	1.71
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	15	0	0	0	0	0	1	6	7	1	0	0	0
	CDD10.0	4837	511	468	498	431	381	321	293	294	327	393	427	492
	CDD18.3	1811	253	234	239	181	123	72	41	43	79	135	177	234
	CDH23.3	14014	2369	2184	1968	1188	595	271	149	191	477	994	1459	2167
	CDH26.7	4626	922	836	687	321	95	29	9	16	77	274	488	871
Wind	WSAvg	2.8	3.2	2.9	3.0	2.7	2.4	2.3	2.3	2.4	2.7	3.2	3.4	3.3
Precipitation	PrecAvg	951	121	142	121	74	69	97	64	57	33	45	61	68
	PrecMax	1892	379	316	339	191	258	233	144	251	157	213	342	261
	PrecMin	419	14	15	2	3	4	21	8	12	3	0	0	3
	PrecStd	297	93	91	77	59	60	51	36	42	34	53	67	60
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.9	34.8	34.1	32.4	30.6	29.2	27.9	28.3	30.4	32.2	33.9	35.0
		MCWB	25.0	26.0	25.4	24.7	23.1	22.2	20.9	21.0	21.9	22.8	22.8	24.5
	2%	DB	33.1	33.2	32.3	31.0	28.9	27.2	26.1	26.8	28.7	30.9	32.1	33.4
		MCWB	24.5	25.3	25.1	24.1	22.3	21.0	19.6	20.0	20.9	22.1	22.5	23.7
	5%	DB	32.1	32.1	31.2	29.8	27.8	26.1	25.0	25.2	27.2	29.5	30.8	32.1
		MCWB	24.0	24.8	24.7	23.5	21.7	20.3	19.0	18.8	20.0	21.2	22.0	23.2
	10%	DB	31.0	31.0	30.2	28.7	26.4	24.9	23.9	24.2	26.0	28.1	29.2	31.0
		MCWB	23.7	24.5	24.2	23.0	20.9	19.5	18.3	18.2	19.2	20.6	21.3	22.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.9	27.3	27.0	26.4	24.6	23.4	22.1	22.3	23.2	24.0	24.6	26.0
		MCDB	31.7	32.5	31.8	30.4	28.1	26.9	25.8	25.8	28.2	30.3	29.7	31.7
	2%	WB	26.0	26.5	26.2	25.2	23.6	22.2	20.9	21.2	22.0	22.9	23.7	25.1
		MCDB	30.6	31.4	30.5	29.2	26.7	25.5	24.2	24.8	26.6	28.6	29.4	30.8
	5%	WB	25.3	25.9	25.6	24.4	22.7	21.4	20.1	20.3	21.1	22.1	23.0	24.5
		MCDB	29.6	30.3	29.7	28.1	25.8	24.5	23.1	23.7	25.3	27.7	28.5	29.9
	10%	WB	24.7	25.3	25.0	23.7	22.0	20.6	19.3	19.4	20.2	21.3	22.3	23.8
		MCDB	28.8	29.2	28.8	27.1	25.2	23.6	22.6	22.6	24.4	26.5	27.6	28.9
Mean Daily Temperature Range	5% DB	MDBR	9.3	8.8	8.5	8.6	8.8	8.8	9.3	9.8	10.8	11.0	10.8	10.5
		MCDBR	10.8	10.5	10.1	10.3	10.1	10.4	10.8	11.3	12.3	12.7	12.6	12.3
		MCWBR	4.3	4.3	4.5	4.7	4.7	5.0	5.5	5.7	5.8	5.4	5.1	4.8
	5% WB	MCDBR	9.0	9.1	8.9	8.8	8.4	8.7	9.1	9.4	11.0	11.5	10.9	10.4
		MCWBR	4.1	4.2	4.2	4.5	4.4	4.7	5.1	5.1	5.5	5.2	4.8	4.6
Clear-Sky Solar Irradiance	taub	0.389	0.385	0.385	0.369	0.352	0.344	0.326	0.332	0.352	0.366	0.371	0.378	
	taud	2.548	2.578	2.580	2.610	2.617	2.628	2.657	2.631	2.539	2.522	2.531	2.555	
	Ebn at Noon	955	947	921	896	873	861	893	920	938	954	966	966	
	Edh at Noon	110	105	101	91	83	79	79	87	103	110	111	110	
All-Sky Solar Radiation	RadAvg	6.60	6.21	5.32	4.53	3.74	3.39	3.72	4.46	5.66	6.37	6.69	6.87	
	RadStd	0.51	0.46	0.40	0.38	0.27	0.23	0.25	0.31	0.31	0.30	0.45	0.48	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (6 neighbors)	N/A	N/A	-0.61	N/A	N/A	-0.60	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page