

NOUMEA, New Caledonia

WMO: 915920

Lat: 22.2761S

Lon: 166.4528E

Elev: 233

StdP: 14.57

Time Zone: 11.00 (E11)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	61.2	62.3	49.4	52.6	67.0	50.8	55.5	67.3	25.1	68.5	23.2	69.3	7.0	40	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.9	89.1	76.9	87.5	76.6	85.9	76.1	79.2	85.5	78.3	84.3	77.6	83.3	11.7	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.4	143.8	82.7	76.6	140.0	81.9	75.9	136.8	81.3	43.0	85.7	42.1	84.6	41.3	83.6	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.4	23.2	21.4	DB	59.2	93.0	1.0	1.6	58.4	94.1	57.8	95.1	57.3	96.0	56.5	97.2	
			WB	54.1	80.6	1.5	1.2	53.0	81.5	52.2	82.2	51.4	82.9	50.3	83.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.2	79.2	80.0	78.8	76.3	73.0	70.6	68.6	68.4	70.5	72.9	75.0	78.1
	DBStd	4.81	2.63	2.60	2.63	2.65	2.47	2.50	2.33	2.51	2.63	2.81	2.71	2.96
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	3	0	0	0	0	0	0	1	2	0	0	0	0
	CDD50	8849	906	841	892	789	713	618	577	570	614	708	751	870
	CDD65	3376	441	421	427	339	248	168	113	106	164	243	301	405
	CDH74	19510	3688	3824	3344	1834	618	222	92	100	317	863	1500	3108
CDH80	3759	836	941	645	223	29	8	3	3	19	100	215	737	
Wind	WSAvg	11.7	13.3	12.4	12.8	11.9	10.7	10.6	10.5	10.4	10.8	12.2	12.9	12.3
Precipitation	PrecAvg	40.8	4.1	4.9	5.9	4.5	3.7	4.1	2.9	2.7	1.6	1.8	1.9	2.7
	PrecMax	63.4	14.6	16.0	15.6	10.9	9.5	15.4	9.0	8.9	5.4	8.2	7.6	11.4
	PrecMin	26.7	0.7	0.6	0.3	0.3	0.5	0.5	0.8	0.4	0.0	0.0	0.0	0.2
	PrecStd	8.1	3.0	2.9	3.7	3.0	2.0	2.6	1.7	1.5	1.3	1.8	1.5	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.9	91.4	89.9	87.0	82.9	81.2	79.3	79.7	82.3	86.0	88.2	90.9
		MCWB	77.5	77.6	78.4	76.6	73.3	71.5	69.2	68.9	70.4	73.0	73.4	75.6
	2%	DB	88.1	88.9	87.2	84.5	80.3	78.4	76.3	76.8	79.4	82.8	84.6	88.1
		MCWB	76.9	77.8	77.8	75.8	72.2	69.8	67.1	68.0	69.5	71.4	72.8	75.5
	5%	DB	86.1	86.9	85.3	82.6	78.6	76.4	74.4	74.7	77.3	80.4	82.3	86.1
		MCWB	76.4	77.3	77.2	74.9	71.0	68.8	65.9	66.4	68.2	70.4	72.3	75.0
	10%	DB	84.2	85.0	83.5	80.8	77.2	74.8	72.8	73.0	75.5	78.5	80.3	84.0
		MCWB	75.5	76.6	76.2	73.7	70.0	67.7	65.0	65.1	67.1	69.2	71.1	74.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.5	80.1	78.3	75.3	73.6	71.6	71.4	73.5	74.7	76.1	78.1
		MCDB	86.8	87.5	86.5	84.4	79.8	78.0	76.3	76.5	79.4	82.2	83.8	86.0
	2%	WB	78.8	79.2	79.0	76.9	74.0	72.0	69.5	69.9	71.2	73.0	74.7	77.1
		MCDB	84.7	85.7	84.9	82.6	77.9	75.9	74.0	74.2	76.7	79.9	81.5	85.0
	5%	WB	77.8	78.3	78.1	75.7	72.9	70.6	68.0	68.4	69.9	71.7	73.6	76.2
		MCDB	83.3	84.4	83.5	80.6	76.7	74.6	72.2	72.9	75.2	78.8	80.1	83.6
	10%	WB	76.8	77.5	77.2	74.7	71.8	69.3	66.7	67.0	68.6	70.5	72.3	75.2
		MCDB	82.0	83.2	82.1	79.3	75.8	73.6	71.1	71.6	73.8	77.0	78.6	82.1
Mean Daily Temperature Range	5% DB	MDBR	9.0	8.9	8.2	8.0	8.1	8.1	8.5	9.0	9.7	9.9	9.9	10.1
		MCDBR	11.4	11.5	10.4	9.8	9.4	9.9	10.4	10.6	11.7	12.6	12.6	12.9
	5% WB	MCWBR	4.9	4.9	4.7	4.7	4.9	5.1	5.3	5.6	5.9	5.8	5.9	5.4
		MCWBR	9.7	9.9	9.3	8.9	8.1	8.5	8.7	9.1	10.0	11.3	11.2	11.3
Clear-Sky Solar Irradiance	taub		0.378	0.377	0.375	0.361	0.345	0.340	0.322	0.324	0.343	0.355	0.360	0.367
	taud		2.597	2.615	2.625	2.647	2.650	2.647	2.676	2.678	2.582	2.570	2.577	2.608
	Ebn at Noon		306	303	295	287	279	274	284	294	300	306	310	310
	Edh at Noon		33	32	30	28	25	24	24	26	31	33	34	33
All-Sky Solar Radiation	RadAvg		2097	1976	1691	1430	1173	1059	1164	1404	1791	2029	2135	2187
	RadStd		157	141	127	121	85	73	76	100	98	95	142	151

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page