

ILE DES PINS, New Caledonia

WMO: 915960

Lat: 22.590S

Lon: 167.452E

Elev: 341

StdP: 14.52

Time Zone: 11.00 (E11)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	57.7	59.2	48.4	50.9	64.4	50.0	54.1	64.2	23.0	70.9	20.8	70.4	4.2	150	0.392

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.9	85.4	76.9	84.2	76.2	83.2	75.4	79.2	82.8	78.3	81.8	77.4	80.9	12.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.2	148.3	81.3	77.2	143.6	80.4	76.4	139.5	79.7	43.1	83.0	42.1	82.0	41.3	81.1	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.3	20.2	18.5	DB	54.3	87.8	1.9	1.9	52.9	89.2	51.8	90.2	50.7	91.3	49.3	92.6
			WB	51.3	80.1	1.7	1.2	50.1	80.9	49.1	81.6	48.1	82.2	46.9	83.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.5	77.3	78.5	77.4	75.1	71.7	69.1	67.2	66.7	68.4	70.6	72.7	75.7
	DBStd	4.68	2.15	2.25	2.08	2.35	2.64	2.56	2.39	2.60	2.60	2.48	2.53	2.32
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	20	0	0	0	0	0	1	6	11	2	0	0	0
	CDD50	8214	847	799	848	752	673	574	534	518	553	640	680	796
	CDD65	2759	382	379	383	302	208	125	75	64	105	175	230	331
	CDH74	13043	2596	2922	2484	1272	405	100	25	31	118	381	816	1893
	CDH80	1544	369	513	316	82	6	0	0	0	1	5	30	222
Wind	WSAvg	10.2	11.1	11.4	10.6	10.5	9.7	9.4	9.2	9.0	9.6	10.6	10.7	10.7
Precipitation	PrecAvg	57.2	6.8	7.2	8.5	6.3	4.5	4.6	3.8	3.8	2.9	2.1	2.9	3.9
	PrecMax	94.0	16.8	25.1	19.6	23.5	10.2	11.4	18.8	8.6	12.3	4.8	13.6	10.6
	PrecMin	40.4	1.5	2.1	3.3	1.2	1.1	1.3	0.4	1.2	0.3	0.5	0.5	0.8
	PrecStd	13.0	3.9	5.2	4.1	4.6	2.3	2.7	3.7	1.8	2.8	1.4	2.7	2.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.2	88.0	86.5	84.3	80.8	78.6	76.4	76.7	79.1	80.5	82.5	85.6
		MCWB	77.4	79.5	77.7	76.9	73.4	72.5	68.9	69.1	70.0	71.0	73.6	75.2
	2%	DB	84.5	85.7	84.4	82.1	79.0	76.5	74.5	74.6	76.7	78.8	80.8	83.8
		MCWB	76.0	77.7	76.5	75.2	72.1	70.5	67.7	67.4	68.3	70.2	72.5	74.4
	5%	DB	83.3	84.4	83.0	80.8	77.6	75.1	73.1	73.2	75.2	77.5	79.5	82.5
		MCWB	75.1	76.9	75.9	74.3	71.2	68.9	66.3	66.3	67.1	69.2	71.3	73.7
	10%	DB	82.1	83.2	81.8	79.5	76.3	73.8	71.9	71.9	73.9	76.2	78.2	81.1
		MCWB	74.4	76.0	75.2	73.4	70.4	67.9	65.4	65.0	66.3	68.2	70.1	72.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	80.8	79.7	78.3	75.9	74.7	72.3	72.5	72.7	74.0	76.5	77.4
		MCDB	83.0	85.1	83.2	81.9	78.1	76.7	74.0	73.7	75.9	77.3	78.9	81.5
	2%	WB	78.5	79.7	78.3	77.2	74.5	72.7	70.4	70.4	71.0	72.5	74.6	76.5
		MCDB	81.9	83.5	82.0	80.3	76.7	74.9	72.8	72.7	74.2	76.4	78.1	80.7
	5%	WB	77.5	78.7	77.5	76.1	73.3	71.0	69.0	68.8	69.7	71.3	73.3	75.6
		MCDB	80.9	82.2	80.9	79.2	76.0	73.6	71.7	71.7	73.0	75.4	77.4	80.0
	10%	WB	76.6	77.7	76.7	75.0	72.1	69.5	67.4	67.2	68.3	70.1	72.1	74.7
		MCDB	80.0	81.3	80.0	78.1	75.1	72.5	70.4	70.4	71.9	74.2	76.3	79.1
Mean Daily Temperature Range	5% DB	MDBR	9.4	8.9	8.7	8.6	9.0	8.9	9.4	10.3	10.9	10.6	10.6	10.3
		MCDBR	10.6	10.0	9.8	9.6	9.8	9.7	10.4	11.1	11.8	11.7	11.3	11.6
		MCWBR	4.3	4.2	4.3	4.5	5.1	5.4	5.7	6.2	5.8	5.3	4.9	4.4
	5% WB	MCDBR	8.4	8.9	8.3	8.3	7.8	7.5	7.8	8.4	9.4	9.9	9.7	9.5
		MCWBR	4.1	4.3	4.3	4.3	4.9	5.2	5.7	5.9	5.5	5.0	4.7	4.4
Clear-Sky Solar Irradiance	taub	0.375	0.376	0.372	0.360	0.348	0.340	0.321	0.326	0.341	0.352	0.355	0.364	
	taud	2.617	2.622	2.640	2.653	2.641	2.649	2.689	2.672	2.596	2.587	2.603	2.622	
	Ebn at Noon	307	303	296	286	278	274	284	293	301	306	312	311	
	Edh at Noon	33	32	30	28	26	24	24	27	31	33	33	33	
All-Sky Solar Radiation	RadAvg	2139	2043	1728	1450	1184	1049	1162	1404	1800	2033	2187	2258	
	RadStd	159	147	130	128	90	83	80	107	103	108	144	149	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page