

ILE DES PINS, New Caledonia

WMO: 915960

Lat: 22.590S

Lon: 167.452E

Elev: 104

StdP: 100.08

Time Zone: 11.00 (E11)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.3	15.1	9.1	7.3	18.0	10.0	7.7	17.9	10.3	21.6	9.3	21.3	1.9	150	0.392

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.0	29.7	25.0	29.0	24.5	28.4	24.1	26.2	28.2	25.7	27.6	25.2	27.1	5.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.7	21.2	27.4	25.1	20.5	26.9	24.7	19.9	26.5	82.4	28.3	80.1	27.8	78.1	27.3	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	9.0	8.3	DB	12.4	31.0	1.1	1.0	11.6	31.8	11.0	32.4	10.4	32.9	9.6	33.7	(4)
(5)			WB	10.7	26.7	0.9	0.6	10.0	27.2	9.5	27.5	9.0	27.9	8.3	28.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.5	25.2	25.9	25.2	23.9	22.1	20.6	19.6	19.3	20.2	21.5	22.6	24.3	(6)	
	DBStd	2.60	1.19	1.25	1.15	1.30	1.46	1.42	1.33	1.44	1.45	1.38	1.41	1.29	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	11	0	0	0	0	0	1	3	6	1	0	0	0	(9)	
	CDD10.0	4563	471	444	471	418	374	319	297	288	307	356	378	442	(10)	
	CDD18.3	1533	212	211	213	168	116	69	42	36	58	97	128	184	(11)	
	CDH23.3	7246	1442	1623	1380	707	225	56	14	17	66	212	453	1052	(12)	
(13)	CDH26.7	858	205	285	176	46	3	0	0	0	1	3	17	123	(13)	
(14)	Wind	WSAvg	4.6	5.0	5.1	4.8	4.7	4.3	4.2	4.1	4.0	4.3	4.7	4.8	4.8	(14)
(15) Precipitation	PrecAvg	1454	173	183	215	161	114	116	97	97	74	53	73	98	(15)	
	PrecMax	2388	427	637	499	598	260	289	478	219	312	122	346	268	(16)	
	PrecMin	1026	37	53	85	31	28	33	11	31	8	12	12	21	(17)	
	PrecStd	330	98	133	105	118	59	68	93	46	71	36	68	68	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.1	31.1	30.3	29.1	27.1	25.9	24.7	24.8	26.2	27.0	28.1	29.8	(19)	
		MCWB	25.2	26.4	25.4	24.9	23.0	22.5	20.5	20.6	21.1	21.7	23.1	24.0	(20)	
	2%	DB	29.2	29.8	29.1	27.9	26.1	24.7	23.6	23.7	24.9	26.0	27.1	28.8	(21)	
		MCWB	24.4	25.4	24.7	24.0	22.3	21.4	19.8	19.7	20.2	21.2	22.5	23.5	(22)	
	5%	DB	28.5	29.1	28.3	27.1	25.3	23.9	22.8	22.9	24.0	25.3	26.4	28.0	(23)	
		MCWB	24.0	25.0	24.4	23.5	21.8	20.5	19.1	19.0	19.5	20.6	21.8	23.1	(24)	
	10%	DB	27.9	28.4	27.7	26.4	24.6	23.2	22.2	22.2	23.3	24.6	25.7	27.3	(25)	
		MCWB	23.6	24.5	24.0	23.0	21.3	20.0	18.5	18.4	19.0	20.1	21.2	22.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	27.1	26.5	25.7	24.4	23.7	22.4	22.5	22.6	23.3	24.7	25.2	(27)	
		MCDB	28.3	29.5	28.4	27.7	25.6	24.8	23.3	23.2	24.4	25.1	26.1	27.5	(28)	
	2%	WB	25.8	26.5	25.7	25.1	23.6	22.6	21.4	21.4	21.7	22.5	23.7	24.7	(29)	
		MCDB	27.7	28.6	27.8	26.9	24.9	23.8	22.7	22.6	23.4	24.7	25.6	27.1	(30)	
	5%	WB	25.3	26.0	25.3	24.5	23.0	21.7	20.6	20.4	20.9	21.8	23.0	24.2	(31)	
		MCDB	27.2	27.9	27.1	26.2	24.5	23.1	22.1	22.0	22.8	24.1	25.2	26.6	(32)	
	10%	WB	24.8	25.4	24.9	23.9	22.3	20.8	19.7	19.6	20.2	21.2	22.3	23.7	(33)	
		MCDB	26.7	27.4	26.6	25.6	23.9	22.5	21.3	21.3	22.2	23.4	24.6	26.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	5.0	4.8	4.8	5.0	5.0	5.2	5.7	6.1	5.9	5.9	5.7	(35)	
		MCDBR	5.9	5.6	5.5	5.3	5.4	5.4	5.8	6.2	6.6	6.5	6.3	6.5	(36)	
	5% WB	MCWBR	2.4	2.3	2.4	2.5	2.8	3.0	3.2	3.4	3.2	2.9	2.7	2.5	(37)	
		MCWBR	4.7	5.0	4.6	4.6	4.4	4.2	4.3	4.7	5.2	5.5	5.4	5.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.375	0.376	0.372	0.360	0.348	0.340	0.321	0.326	0.341	0.352	0.355	0.364	(40)	
		taud	2.617	2.622	2.640	2.653	2.641	2.649	2.689	2.672	2.596	2.587	2.603	2.622	(41)	
	Ebn at Noon		969	955	933	903	875	863	896	925	948	966	982	980	(42)	
		Edh at Noon	103	101	95	87	81	77	76	84	97	103	104	103	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.74	6.44	5.45	4.57	3.73	3.31	3.66	4.43	5.67	6.41	6.89	7.12	(44)	
	RadStd		0.50	0.46	0.41	0.41	0.28	0.26	0.25	0.34	0.33	0.34	0.46	0.47	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page