

TARAWA BETIO, Kiribati

WMO: 916110

Lat: 1.355N

Lon: 172.923E

Elev: 4

StdP: 101.28

Time Zone: 12.00 (E12)

Period: 97-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.9	25.4	N/A	N/A	N/A	N/A	N/A	N/A	11.3	27.1	10.4	27.2	5.2	80	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	2.2	30.2	N/A	30.1	N/A	29.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	9.2	8.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	27.5	27.4	27.4	27.7	27.8	27.9	27.9	28.0	28.3	28.2	28.1	27.8
	DBStd	0.82	0.87	0.79	0.74	0.69	0.74	0.75	0.70	0.81	0.76	0.82	0.84	0.77
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6513	543	488	541	531	553	538	555	559	549	563	543	551
	CDD18.3	3472	285	254	282	281	295	288	297	301	299	304	293	293
	CDH23.3	41382	3257	2844	3186	3312	3531	3498	3604	3706	3729	3725	3547	3443
	CDH26.7	12603	830	663	773	939	1079	1123	1154	1255	1351	1269	1166	999
(14) Wind	WSAvg	4.5	5.6	6.1	5.3	5.0	3.9	3.5	3.5	3.2	3.8	4.5	4.4	5.2
(15) Precipitation	PrecAvg	2092	288	230	217	198	188	164	168	158	113	121	123	231
	PrecMax	3841	824	542	484	548	621	417	507	507	361	402	477	510
	PrecMin	733	6	7	4	0	3	12	5	6	2	0	1	14
	PrecStd	768	213	144	153	148	134	118	133	135	94	123	130	139
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.0	29.7	29.7	29.7	29.7	29.7	29.9	30.2	30.7	30.6	30.6	30.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	29.7	29.5	29.3	29.4	29.6	29.6	29.7	29.8	30.2	30.2	30.2	29.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	29.4	29.2	29.0	29.2	29.3	29.4	29.5	29.6	29.9	29.9	29.9	29.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	29.1	29.0	28.7	29.0	29.1	29.2	29.2	29.4	29.6	29.6	29.6	29.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	1.5	1.6	1.8	1.8	1.7	1.9	2.1	2.1	2.2	1.9	1.9	1.9
		MCDBR	2.1	2.0	2.2	2.1	2.0	2.0	2.2	2.2	2.6	2.5	2.4	2.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.422	0.424	0.423	0.403	0.389	0.384	0.384	0.380	0.384	0.379	0.389	0.416
	taud		2.502	2.488	2.515	2.587	2.628	2.640	2.644	2.646	2.618	2.631	2.602	2.525
	Ebn at Noon		907	908	902	902	893	885	890	910	925	939	932	907
	Edh at Noon		112	115	111	101	94	91	92	94	99	98	100	108
(44) All-Sky Solar Radiation	RadAvg		5.54	5.92	5.85	5.95	5.95	5.70	5.74	6.13	6.44	6.46	6.15	5.49
	RadStd		0.84	0.77	0.89	0.62	0.39	0.44	0.41	0.48	0.49	0.53	0.44	0.81

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page