

UDU POINT, Fiji

WMO: 916520

Lat: 16.133S

Lon: 179.983W

Elev: 207

StdP: 14.59

Time Zone: 12.00 (PCF)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	67.0	71.5	58.2	73.0	69.8	60.7	79.8	73.3	28.1	75.1	26.1	74.8	13.5	160	0.437

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.8	88.5	80.4	87.5	80.0	86.7	79.6	81.6	86.5	80.9	85.8	80.4	85.2	8.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.1	157.3	84.7	79.5	154.2	84.1	79.0	151.4	83.7	45.5	86.7	44.8	86.1	44.2	85.6	92.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.5	21.3	19.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.6	81.7	81.9	81.5	80.9	79.8	78.0	77.0	77.3	77.9	78.9	79.5	80.6
	DBStd	2.67	1.79	1.90	1.73	1.82	1.67	2.13	1.69	1.84	2.05	1.79	3.69	2.15
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	3	0	0	0	0	0	0	0	0	0	0	3	0
	CDD50	10791	982	892	976	927	924	840	836	846	838	896	885	949
	CDD65	5320	517	472	511	477	459	390	371	381	388	431	438	485
	CDH74	45215	5423	5054	5249	4631	3889	2660	1910	2120	2453	3231	3887	4708
	CDH80	8633	1463	1406	1312	977	579	227	101	158	272	445	705	988
Wind	WSAvg	10.1	8.4	8.4	7.7	10.0	9.2	10.6	12.4	12.2	11.6	11.4	10.0	9.7
Precipitation	PrecAvg	95.0	13.7	13.5	10.2	9.9	5.6	4.7	3.3	3.1	5.0	5.8	9.1	10.9
	PrecMax	128.2	39.0	30.7	21.9	23.7	15.6	17.4	9.1	9.6	14.9	12.2	19.1	24.3
	PrecMin	77.2	2.3	2.1	3.3	1.5	0.7	0.5	0.2	0.5	0.7	0.4	2.0	1.5
	PrecStd	15.7	8.4	6.8	4.4	5.3	3.4	3.9	2.2	2.5	3.4	3.2	5.2	5.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.6	89.6	89.0	88.7	86.9	85.1	83.5	84.3	86.1	86.3	87.3	87.9
		MCWB	79.9	81.0	80.6	79.9	79.7	78.6	77.0	76.9	77.7	78.0	79.7	80.4
	2%	DB	88.1	88.3	87.4	86.9	85.3	83.5	82.1	83.0	84.2	84.6	85.9	86.8
		MCWB	79.8	80.7	80.3	79.3	78.3	77.3	75.8	76.3	77.0	77.1	78.5	79.6
	5%	DB	87.1	87.3	86.4	85.8	84.2	82.3	81.2	81.8	83.0	83.6	85.0	85.6
		MCWB	79.5	80.3	79.8	78.7	77.6	76.1	75.0	75.5	76.2	76.5	77.9	78.9
	10%	DB	86.0	86.2	85.5	84.6	83.0	81.3	80.2	80.6	81.6	82.6	83.9	84.5
		MCWB	79.0	79.8	79.3	78.1	76.8	75.4	74.2	74.7	75.3	76.0	77.3	78.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.6	82.5	81.9	81.1	81.0	79.8	78.4	78.3	79.0	79.1	81.1	81.8
		MCDB	87.2	87.4	87.0	86.1	85.3	84.0	82.0	81.9	83.1	84.2	85.6	86.5
	2%	WB	80.7	81.7	81.0	80.2	79.3	78.3	77.4	77.4	78.0	78.2	79.7	80.6
		MCDB	86.6	86.5	86.1	85.3	83.5	82.1	80.6	80.9	82.2	82.9	84.4	84.6
	5%	WB	80.0	81.0	80.4	79.5	78.5	77.5	76.5	76.6	77.1	77.5	78.9	79.8
		MCDB	85.6	85.7	85.3	84.3	82.5	80.9	79.6	80.0	81.2	81.9	83.3	83.8
	10%	WB	79.4	80.4	79.7	78.8	77.8	76.7	75.6	75.8	76.3	76.9	78.1	79.1
		MCDB	84.7	85.0	84.3	83.5	81.7	79.9	78.5	79.2	80.3	80.9	82.4	83.0
Mean Daily Temperature Range	5% DB	MDBR	8.1	7.8	7.8	7.0	6.8	6.4	6.1	6.5	6.8	7.0	7.4	7.4
		MCDBR	9.5	9.2	8.9	8.6	8.0	7.3	7.1	7.8	8.4	8.2	8.6	8.5
		MCWBR	4.6	4.6	4.6	4.4	4.4	4.1	3.9	4.1	4.0	4.0	4.3	4.2
	5% WB	MCDBR	8.7	8.6	8.4	7.8	7.0	6.9	6.5	7.3	8.1	7.7	8.2	7.8
		MCWBR	4.5	4.6	4.5	4.3	4.3	4.0	3.9	4.0	4.3	4.0	4.5	4.3
Clear-Sky Solar Irradiance	taub	0.387	0.383	0.379	0.384	0.383	0.384	0.377	0.381	0.396	0.389	0.387	0.389	
	taud	2.623	2.642	2.660	2.636	2.620	2.598	2.605	2.591	2.547	2.579	2.605	2.613	
	Ebn at Noon	304	302	297	284	273	267	272	281	287	297	302	303	
	Edh at Noon	32	31	30	29	28	27	28	30	33	33	33	33	
All-Sky Solar Radiation	RadAvg	1911	1808	1728	1510	1356	1242	1325	1495	1687	1820	1865	1856	
	RadStd	220	184	133	118	101	83	59	111	102	139	167	118	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page