

UDU POINT, Fiji

WMO: 916520

Lat: 16.133S

Lon: 179.983W

Elev: 63

StdP: 100.57

Time Zone: 12.00 (PCF)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	21.9	14.6	10.4	21.0	15.9	11.4	22.9	12.6	23.9	11.7	23.8	6.0	160	0.437

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.3	31.4	26.9	30.8	26.7	30.4	26.4	27.6	30.3	27.2	29.9	26.9	29.6	3.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.5	29.3	26.4	22.0	29.0	26.1	21.6	28.7	87.9	30.4	86.4	30.0	85.0	29.8	33.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.5	8.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.4	27.6	27.7	27.5	27.2	26.6	25.6	25.0	25.2	25.5	26.1	26.4	27.0
	DBStd	1.49	1.00	1.05	0.96	1.01	0.93	1.18	0.94	1.02	1.14	0.99	2.05	1.20
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	2	0	0	0	0	0	0	0	0	0	0	2	0
	CDD10.0	5995	546	496	542	515	513	467	464	470	466	498	492	527
	CDD18.3	2956	287	262	284	265	255	217	206	212	216	239	243	269
	CDH23.3	25119	3013	2808	2916	2573	2161	1478	1061	1178	1363	1795	2159	2616
(14) Wind	WSAvg	4.5	3.7	3.7	3.4	4.5	4.1	4.7	5.5	5.4	5.2	5.1	4.5	4.3
	PrecAvg	2413	347	342	260	252	143	120	84	78	126	148	231	277
	PrecMax	3257	991	781	555	601	396	441	232	245	378	310	485	617
	PrecMin	1962	59	53	84	37	17	13	5	13	18	10	51	38
	PrecStd	400	213	172	113	135	87	98	55	63	86	82	132	149
	DB	32.0	32.0	31.6	31.5	30.5	29.5	28.6	29.1	30.1	30.2	30.7	31.1	31.9
	MCWB	26.6	27.2	27.0	26.6	26.5	25.9	25.0	24.9	25.4	25.6	26.5	26.9	27.0
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	31.2	31.3	30.8	30.5	29.6	28.6	27.9	28.3	29.0	29.2	30.0	30.4	31.1
	2% MCWB	26.6	27.0	26.8	26.3	25.7	25.2	24.3	24.6	25.0	25.0	25.8	26.4	27.0
	5% DB	30.6	30.7	30.2	29.9	29.0	28.0	27.3	27.6	28.3	28.6	29.4	29.8	30.4
	5% MCWB	26.4	26.8	26.5	25.9	25.3	24.5	23.9	24.2	24.5	24.7	25.5	26.1	26.6
	10% DB	30.0	30.1	29.7	29.2	28.3	27.4	26.8	27.0	27.6	28.1	28.8	29.2	29.8
	10% MCWB	26.1	26.6	26.3	25.6	24.9	24.1	23.4	23.7	24.1	24.4	25.2	25.7	26.4
	WB	27.5	28.1	27.7	27.3	27.2	26.6	25.8	25.7	26.1	26.2	27.3	27.7	28.4
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	30.7	30.8	30.6	30.1	29.6	28.9	27.8	27.7	28.4	29.0	29.8	30.3	31.1
	2% WB	27.0	27.6	27.2	26.8	26.3	25.7	25.2	25.2	25.5	25.7	26.5	27.0	27.7
	2% MCDB	30.3	30.3	30.1	29.6	28.6	27.9	27.0	27.2	27.9	28.3	29.1	29.2	30.0
	5% WB	26.7	27.2	26.9	26.4	25.8	25.3	24.7	24.8	25.1	25.3	26.1	26.6	27.3
	5% MCDB	29.8	29.8	29.6	29.1	28.1	27.2	26.4	26.7	27.3	27.7	28.5	28.8	29.5
	10% WB	26.4	26.9	26.5	26.0	25.4	24.8	24.2	24.3	24.6	25.0	25.6	26.2	26.8
	10% MCDB	29.3	29.4	29.1	28.6	27.6	26.6	25.9	26.2	26.8	27.2	28.0	28.4	29.1
(35) Mean Daily Temperature Range	MDBR	4.5	4.3	4.4	3.9	3.8	3.6	3.4	3.6	3.8	3.9	4.1	4.1	4.1
	5% DB	5.3	5.1	4.9	4.8	4.5	4.0	4.0	4.3	4.7	4.6	4.8	4.7	4.7
	MCWBR	2.5	2.6	2.6	2.5	2.5	2.3	2.2	2.3	2.2	2.2	2.4	2.3	2.3
	5% WB	4.8	4.8	4.6	4.3	3.9	3.8	3.6	4.1	4.5	4.3	4.5	4.3	4.3
	MCWBR	2.5	2.5	2.5	2.4	2.4	2.2	2.2	2.2	2.4	2.2	2.5	2.4	2.4
(40) Clear-Sky Solar Irradiance	taub	0.387	0.383	0.379	0.384	0.383	0.384	0.377	0.381	0.396	0.389	0.387	0.389	0.389
	taud	2.623	2.642	2.660	2.636	2.620	2.598	2.605	2.591	2.547	2.579	2.605	2.613	2.613
	Ebn at Noon	957	952	935	895	862	842	859	885	905	935	951	955	955
	Edh at Noon	102	99	95	91	87	86	88	94	104	105	103	103	103
(44) All-Sky Solar Radiation	RadAvg	6.02	5.70	5.45	4.76	4.28	3.92	4.18	4.71	5.32	5.74	5.88	5.85	5.85
	RadStd	0.69	0.58	0.42	0.37	0.32	0.26	0.18	0.35	0.32	0.44	0.53	0.37	0.37

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page