

NABOUWALU, Fiji

WMO: 916590

Lat: 17.000S

Lon: 178.700E

Elev: 118

StdP: 14.63

Time Zone: 12.00 (PCF)

Period: 82-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	69.6	70.7	57.5	70.8	73.6	59.4	75.9	73.9	33.3	72.9	28.3	74.5	9.4	120	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.3	88.2	79.9	87.2	79.4	86.3	78.9	81.2	86.4	80.5	85.7	79.9	84.9	6.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.7	154.8	85.3	79.0	151.0	84.5	78.3	147.7	83.7	45.1	86.9	44.3	86.0	43.6	85.2	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.0	21.1	19.2		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
				DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
				WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.6	81.1	81.2	81.1	80.3	78.3	77.1	75.7	75.8	76.7	77.4	78.8	80.1
	DBStd	2.75	1.74	1.66	1.61	1.85	1.74	1.78	1.90	2.17	2.17	2.09	2.02	1.84
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10449	964	874	965	909	877	814	798	800	800	851	865	932
	CDD65	4974	499	454	500	459	412	364	333	335	350	386	415	467
	CDH74	38317	4947	4550	4960	4203	2989	2131	1367	1487	1883	2362	3198	4240
	CDH80	6568	1226	1150	1200	800	280	106	57	56	132	231	498	832
Wind	WSAvg	8.7	7.0	6.1	5.9	7.0	8.4	9.3	10.5	10.6	11.2	10.9	9.0	8.1
Precipitation	PrecAvg	91.1	13.9	11.1	11.4	9.7	6.9	4.2	3.5	4.3	4.2	6.3	7.3	9.7
	PrecMax	140.6	50.4	22.0	21.6	28.0	16.4	10.4	8.7	13.6	15.4	17.0	21.8	16.6
	PrecMin	53.2	3.8	3.7	4.0	2.6	1.7	0.7	0.6	0.5	0.4	0.3	1.7	2.8
	PrecStd	20.4	9.1	4.4	4.6	5.6	3.9	2.4	2.0	3.1	3.0	4.8	4.7	3.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.1	89.0	89.2	88.6	86.3	84.1	83.7	83.3	84.4	85.5	87.3	88.0
		MCWB	80.4	80.5	80.9	80.1	78.3	76.4	76.6	74.9	77.5	76.8	78.9	79.5
	2%	DB	87.6	87.7	87.7	86.6	84.2	82.2	81.5	81.6	82.8	83.8	85.5	86.5
		MCWB	79.5	79.9	79.8	79.2	77.2	75.7	74.6	74.5	76.0	76.5	77.7	78.7
	5%	DB	86.6	86.7	86.4	85.3	82.7	81.1	80.1	80.3	81.6	82.6	84.3	85.3
		MCWB	79.0	79.3	79.1	78.5	75.9	74.9	73.7	73.9	75.1	75.5	77.1	78.0
	10%	DB	85.4	85.5	85.2	84.1	81.5	80.1	78.9	79.1	80.2	81.2	83.0	84.0
		MCWB	78.3	78.7	78.6	77.8	75.1	74.2	72.7	73.1	74.3	74.5	76.3	77.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	82.2	82.2	81.3	79.2	77.9	77.9	77.0	78.3	79.1	80.5	81.0
		MCDB	87.1	86.9	87.6	86.7	84.2	81.8	82.4	80.8	83.0	84.3	86.2	86.2
	2%	WB	80.7	81.0	80.9	80.1	78.2	76.9	76.3	75.9	76.9	77.6	79.0	79.9
		MCDB	86.1	86.0	86.1	85.3	82.9	80.9	80.1	79.8	81.5	82.4	84.0	85.0
	5%	WB	79.9	80.2	80.0	79.2	77.3	76.2	75.3	75.2	76.1	76.6	78.1	79.0
		MCDB	85.1	85.2	84.9	84.0	81.5	80.0	78.8	79.1	80.3	81.1	82.8	84.0
	10%	WB	79.0	79.5	79.2	78.5	76.5	75.5	74.4	74.4	75.2	75.8	77.2	78.2
		MCDB	84.0	84.3	83.9	83.0	80.4	79.1	77.8	78.4	79.3	80.1	81.8	82.9
Mean Daily Temperature Range	5% DB	MDBR	8.4	8.3	8.3	7.5	6.4	6.0	6.0	6.0	6.3	6.7	7.4	7.6
		MCDBR	10.0	10.0	10.1	9.5	8.3	7.4	7.7	7.3	7.9	8.5	9.3	9.4
		MCWBR	5.2	5.4	5.4	5.1	4.8	4.5	4.7	3.8	4.6	4.6	5.2	5.1
	5% WB	MCDBR	9.5	9.4	9.4	9.0	8.0	7.1	6.8	6.5	7.3	7.9	8.9	8.9
		MCWBR	5.5	5.6	5.6	5.3	4.9	4.8	4.9	4.1	4.9	4.9	5.6	5.6
Clear-Sky Solar Irradiance	taub	0.390	0.383	0.379	0.379	0.381	0.378	0.367	0.368	0.385	0.387	0.386	0.386	
	taud	2.611	2.641	2.660	2.650	2.610	2.604	2.628	2.628	2.567	2.580	2.605	2.621	
	Ebn at Noon	303	302	296	285	273	268	275	285	290	297	302	304	
	Edh at Noon	33	31	30	29	28	27	27	29	32	33	33	32	
All-Sky Solar Radiation	RadAvg	1913	1792	1685	1480	1326	1210	1290	1442	1641	1802	1864	1875	
	RadStd	202	163	130	111	93	82	56	124	111	138	179	100	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	+0.32	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+121	+119

Nomenclature: See separate page