

LAUTOKA, Fiji

WMO: 916790

Lat: 17.600S

Lon: 177.450E

Elev: 0

StdP: 14.70

Time Zone: 12.00 (PCF)

Period: 98-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	68.3	69.5	N/A	N/A	N/A	N/A	N/A	N/A	19.4	79.3	17.4	78.6	3.6	130	0.296

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	8.3	87.9	N/A	86.9	N/A	86.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.9	15.9	13.4	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.9	81.3	81.4	81.5	80.7	78.8	77.4	75.5	75.7	77.0	78.0	79.5	80.6		
	DBStd	2.79	1.72	1.66	1.36	1.50	1.79	1.97	1.97	2.14	2.08	2.00	1.57	1.67		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	10561	970	880	976	922	893	821	791	795	810	868	886	949		
	CDD65	5086	505	460	511	472	428	371	326	330	360	403	436	484		
	CDH74	45635	5488	4917	5510	4815	3663	2662	1760	1891	2556	3275	4113	4985		
(13)	CDH80	9484	1582	1382	1539	1207	632	285	72	93	241	407	793	1251		
(14)	Wind	WSAvg	5.0	6.0	5.5	5.7	4.6	4.2	4.4	4.7	4.6	4.8	5.0	5.3		
(15) Precipitation	PrecAvg	76.7	14.0	11.7	12.2	6.9	3.6	2.7	2.2	3.1	3.2	3.4	5.2	8.3		
	PrecMax	137.4	44.5	25.9	26.1	19.5	12.5	12.0	7.2	10.2	8.7	10.9	12.4	21.1		
	PrecMin	37.7	3.3	1.3	3.6	1.4	0.0	0.2	0.2	0.0	0.1	0.4	0.2	1.1		
	PrecStd	25.0	10.2	6.4	6.0	4.4	3.2	2.7	1.5	2.7	2.4	2.5	3.0	4.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.1	89.5	88.3	88.7	86.3	85.1	82.8	83.5	85.1	85.5	86.5	88.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	87.2	87.4	87.1	86.8	84.9	83.6	81.7	81.9	83.5	84.2	85.2	86.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	86.2	86.4	86.2	85.7	84.1	82.5	80.8	81.0	82.3	83.1	84.3	85.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	85.4	85.5	85.4	84.8	83.2	81.7	79.9	80.2	81.4	82.2	83.5	84.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	8.5	8.3	8.8	8.8	8.5	8.8	8.5	8.5	8.1	8.4	8.4		
		MCDBR	9.1	9.5	9.1	9.6	9.4	9.1	9.1	9.3	9.3	9.0	9.1	9.1		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.389	0.386	0.378	0.376	0.366	0.365	0.358	0.361	0.374	0.380	0.381	0.381		
	taud		2.593	2.609	2.649	2.642	2.643	2.627	2.632	2.631	2.580	2.578	2.599	2.614		
	Ebn at Noon		303	301	297	285	277	272	277	286	293	299	304	305		
	Edh at Noon		33	32	30	29	27	26	27	29	32	33	33	33		
(44) All-Sky Solar Radiation	RadAvg		1947	1838	1702	1512	1351	1264	1327	1477	1697	1852	1947	1974		
	RadStd		205	158	127	114	102	70	71	135	123	121	171	95		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.32	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+121	+119

Nomenclature: See separate page