

NADI, Fiji

WMO: 916800

Lat: 17.755S

Lon: 177.443E

Elev: 59

StdP: 14.66

Time Zone: 12.00 (PCF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	62.3	64.2	55.6	66.0	69.9	57.3	70.2	70.6	18.9	79.0	17.6	78.8	4.9	120	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.0	90.0	78.1	89.4	78.0	88.2	77.9	80.8	87.0	80.1	86.3	79.6	85.6	11.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.4	84.2	78.7	149.2	83.8	77.7	144.1	82.8	44.6	87.5	43.8	86.9	43.3	86.0	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.2	16.1	14.3	DB	58.4	93.7	1.8	2.1	57.1	95.2	56.0	96.4	55.0	97.6	53.6	99.1
			WB	56.6	83.2	1.8	1.3	55.3	84.1	54.3	84.9	53.3	85.6	52.0	86.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.4	81.1	81.1	81.0	79.9	77.5	76.0	74.7	74.9	76.4	77.9	79.5	80.6
	DBStd	3.20	1.73	1.71	1.50	1.63	2.24	2.67	2.60	2.66	2.68	2.40	1.81	1.74
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10356	964	871	961	898	853	781	765	771	793	866	885	948
	CDD65	4881	499	451	496	448	388	331	300	306	343	401	435	483
	CDH74	41317	4971	4391	4684	3916	2911	2232	1878	1941	2459	3280	3926	4728
	CDH80	12627	1750	1529	1610	1274	789	521	346	372	583	915	1273	1665
Wind	WSAvg	6.4	6.5	6.3	5.8	5.6	5.8	6.1	6.4	6.6	6.9	7.2	6.9	6.6
Precipitation	PrecAvg	73.0	13.1	12.8	13.0	7.0	3.4	2.4	1.9	2.6	3.1	3.7	5.3	7.5
	PrecMax	129.5	46.5	31.0	36.1	22.8	13.0	12.3	7.5	10.1	12.9	13.5	18.1	22.1
	PrecMin	34.0	0.5	1.8	3.0	0.9	0.0	0.0	0.0	0.0	0.0	0.1	0.3	1.0
	PrecStd	19.2	8.9	6.9	6.8	4.8	3.1	2.5	1.9	2.4	2.8	3.2	3.3	4.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.5	91.6	91.0	89.9	88.1	87.8	86.8	87.5	89.0	89.7	90.1	91.4
		MCWB	78.8	79.5	79.4	78.3	76.9	76.3	74.7	74.3	74.8	75.6	76.8	77.8
	2%	DB	89.7	89.7	89.4	88.2	86.4	85.9	84.5	84.9	86.3	87.5	88.1	89.4
		MCWB	78.4	78.9	79.0	78.1	76.4	75.6	73.8	73.4	74.3	75.1	76.5	77.4
	5%	DB	88.1	88.2	88.0	87.5	85.7	84.4	83.1	83.8	84.5	86.0	86.7	88.0
		MCWB	78.4	78.7	78.8	78.0	76.0	75.0	73.0	73.0	73.9	74.9	76.2	77.4
	10%	DB	87.5	87.5	87.4	86.2	84.3	82.9	82.2	82.3	83.2	84.5	85.9	86.6
		MCWB	78.3	78.6	78.6	77.4	75.0	73.9	72.5	72.4	73.3	74.4	76.0	77.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.2	81.8	81.7	80.8	79.2	78.7	77.4	77.2	78.0	78.9	79.9	80.7
		MCDB	87.7	88.0	87.4	86.7	85.3	84.8	83.0	83.6	84.3	85.1	86.7	87.2
	2%	WB	80.2	80.6	80.5	79.7	78.3	77.4	76.2	75.7	76.5	77.7	78.7	79.6
		MCDB	86.6	87.0	86.5	85.7	84.2	83.4	81.9	82.0	83.1	84.0	85.1	86.1
	5%	WB	79.5	79.9	79.8	79.0	77.5	76.4	75.1	74.7	75.6	76.7	77.9	78.9
		MCDB	85.8	86.0	85.7	84.9	83.2	82.2	81.0	80.8	82.3	83.1	84.4	85.4
	10%	WB	78.9	79.2	79.1	78.3	76.4	75.4	74.1	73.7	74.7	75.9	77.1	78.2
		MCDB	85.0	85.0	84.9	84.0	82.0	81.2	79.9	79.8	81.2	82.3	83.6	84.6
Mean Daily Temperature Range	5% DB	MDBR	13.0	13.2	13.1	13.4	14.4	15.0	15.6	15.1	14.7	14.3	13.8	13.6
		MCDBR	14.5	14.7	14.3	15.0	15.2	15.8	16.5	16.6	16.0	15.6	14.9	14.9
		MCWBR	6.5	6.7	6.6	7.0	7.3	7.8	8.0	7.9	7.6	7.2	7.0	6.6
	5% WB	MCDBR	13.1	13.2	13.3	13.3	13.5	14.2	14.4	14.4	14.3	13.5	13.4	13.3
		MCWBR	6.5	6.5	6.6	6.8	7.2	7.7	7.9	7.8	7.5	7.0	6.9	6.6
Clear-Sky Solar Irradiance	taub		0.389	0.386	0.378	0.375	0.364	0.363	0.357	0.359	0.373	0.380	0.380	0.380
	taud		2.589	2.606	2.643	2.637	2.645	2.628	2.633	2.632	2.575	2.574	2.595	2.611
	Ebn at Noon		303	301	296	285	278	272	278	287	293	299	304	306
	Edh at Noon		34	33	30	29	27	26	27	29	32	33	33	33
All-Sky Solar Radiation	RadAvg		1960	1855	1713	1508	1343	1247	1311	1464	1690	1848	1947	1983
	RadStd		204	155	125	113	100	72	70	134	126	123	174	97

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	+0.36	+0.41	N/A	N/A	+108	+108	
(47)	Regional (7 neighbors)	+0.32	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+121	+119	

Nomenclature: See separate page